

THESE DRAWINGS AND DESIGNS ARE THE PROPERTY OF PROFICIENT ENGINEERING, INC. AND SHALL NOT BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF PROFICIENT ENGINEERING, INC. ALL DIMENSIONS SHALL BE AS SHOWN UNLESS OTHERWISE SPECIFIED. THE CONTRACTOR AND SUBCONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING THE ACCURACY OF ALL DIMENSIONS AND DISCREPANCIES BEFORE PROCEEDING WITH CONSTRUCTION. NO SCALE.

PLUMBING FIXTURE SCHEDULE							WATER RUNOUT		WATER CONN.		SPECIFICATION
MARK	DESCRIPTION	WASTE INOUT	WASTE IN	CW	HW	CW	HW				
1.1	RESTROOM (ADA) - WASH BASIN	1/2"	1/2"	1/2"	1/2"	3/8"	3/8"	WALL MOUNT LAVATORY (AMERICAN STANDARD) 12" X 16" (OR 21" X 21") WITH CONFORMABLE ASB GASKET MOUNTING (CUNI 21 23 1). PROVIDE 0.5 GPM SINGLE HANDLE FAUCETS WITH POLISHED CHROME FINISH (DELTA 50 114-HIGH-ARC). MANICURE EXAM OFFER WOOD DRAIN (ENH 25746-PCS) AND CHROME PLATED 1/2" DIA. DRAIN (22521). 1/2" CHROME PLATED BRASS ANGLE SUPPLY STOPS WITH FLEX SUPPLIES (BAGLINE H 105). 3/8" ANGLE OFFSET, TRAP AND SUPPLY LINES (TRUERO 14VGLAND 1 1/2) (2) (E-2). PROVIDE 1/4" ANGLE VALVE TO TEMPER HOT WATER TO 1/2" (2) (2) (3) (4) (5) (6) (7) (8) (9) (10) (11) (12) (13) (14) (15) (16) (17) (18) (19) (20) (21) (22) (23) (24) (25) (26) (27) (28) (29) (30) (31) (32) (33) (34) (35) (36) (37) (38) (39) (40) (41) (42) (43) (44) (45) (46) (47) (48) (49) (50) (51) (52) (53) (54) (55) (56) (57) (58) (59) (60) (61) (62) (63) (64) (65) (66) (67) (68) (69) (70) (71) (72) (73) (74) (75) (76) (77) (78) (79) (80) (81) (82) (83) (84) (85) (86) (87) (88) (89) (90) (91) (92) (93) (94) (95) (96) (97) (98) (99) (100)			
WC-1	WATER CLOSET (ADA) - TANK TYPE	4"	3"	2"	1/2"	1/2"	---	FLOOR MOUNTED, FLUSHVALVE ADA TANK TYPE WATER CLOSET (AMERICAN STANDARD) (SICOT 18) (RIGHT HEIGHT) 21" (S.A.) (1) (2) (3) (4) (5) (6) (7) (8) (9) (10) (11) (12) (13) (14) (15) (16) (17) (18) (19) (20) (21) (22) (23) (24) (25) (26) (27) (28) (29) (30) (31) (32) (33) (34) (35) (36) (37) (38) (39) (40) (41) (42) (43) (44) (45) (46) (47) (48) (49) (50) (51) (52) (53) (54) (55) (56) (57) (58) (59) (60) (61) (62) (63) (64) (65) (66) (67) (68) (69) (70) (71) (72) (73) (74) (75) (76) (77) (78) (79) (80) (81) (82) (83) (84) (85) (86) (87) (88) (89) (90) (91) (92) (93) (94) (95) (96) (97) (98) (99) (100)			
EW-1	WATER COOLER (ADA) - BLEVEL	2"	1 1/2"	2"	1/2"	---	1/2"	BLEVEL WATER COOLER (DELTA 15251251). OFFSET AT 28" AND 31" TAB OFF. 0.8 GPM OF COLD WATER @ 60°F TO ROOM TEMPERATURE. PROVIDE ACCESSORY PARTS (AS FURNISHED) IF INSTALLED ON AN EXPOSED WALL FOR CARE DETECTION. MOUNT WITH WALL CARRIER (LWH 1225 88).			
CK-1	STAINLESS STEEL SINK, DRAIN RILL SINGLE BOWL (ADA)	2"	1 1/2"	2"	1/2"	1/2"	3/8"	STAINLESS STEEL SINK WITH DRAIN RILL (KORONA 14805). 4 HOLES. 15.75" W, 6.8" D. ADA COMPLIANT AND FAUCET WITH 1.5 GPM OPERATION AND SPRAY (DELTA T-COLUNA 1440-105). MANICURE CHROME PLATED P-TRAP (KORONA 14805). 1/2" CHROME PLATED BRASS ANGLE SUPPLY STOPS. 1/2" (LONG X 3/8" FLEX SUPPLIES). 3/8" ANGLE OFFSET (BAGLINE H 105).			
MS-1	MIXER	3"	3"	2"	1/2"	1/2"	1/2"	3/4" X 1/2" FLOOR MOUNT (MSE-2424) AND SERVICE FAUCETS WITH WAGUUM BREAKER, REDUCER STOPS. 3/4" NPT AND 3/4" HOSE THREAD ON SHOUT (250-6A). PROVIDE HOSE AND BRACKET (333-AN) MOP HANGER (250-6C). STAINLESS STEEL, UNFINISHED 16-00-AN) AND STAINLESS STEEL WALL GUARD (MCE-24A).			
ET-1	POTABLE WATER EXPANSION TANK	---	---	---	---	---	---	LEAD-FREE POTABLE WATER EXPANSION TANK (WATTS 111-5). 2.1 GALLONS TOTAL VOLUME. 0.6 GALLONS MAXIMUM ACCEPTABLE VOLUME. TANK SHALL BE PRE-CHARGED TO THE SYSTEM PRESSURE PRIOR TO INSTALLATION (CONTRACTOR TO FIELD VERIFY).			
MDF-1	KC MARKER/REPAIR/REMOVE BOX	---	---	---	---	---	---	1/2" MARKER CONNECTION BOX (WATTS 430 10 16415). 6" X 6". 1/4" THICK BRASS VALVE WITH INTEGRAL FACTORY ACTUATOR (3/4" O.D. WATER TIGHTNESS INDICATOR). PROVIDE BACKFLOW PREVENTER IN SUPPLY LINE (EATON 5125). ANGLE (105 21).			
FDB-1	FRESHFLOW OF HOSE REEL	---	---	---	---	---	---	WOODFORD MODEL 25 AUTOMATIC DRAWING FREEFLOW HOSE REEL WITH 3/4" HOSE CONNECTION AND WHEEL HANDLE.			
DSP-1	DOWNSPOUT (NOY)	---	---	---	---	---	---	ANGULAR OFFSET CAST IRON DOWNSPOUT BOOT WITH 3/8" CLEANOUT (2 R. HX) AND 3/8" IN-LETS ON APPROVED EQUAL. PROVIDE STAINLESS STEEL HOUSING WHEN ATTACHING TO ANCHOR MASONRY WALL SURFACE. REFER TO PLAN FOR SIZE.			
RD-1	ROOF DRAIN	---	---	---	---	---	---	GENERAL PURPOSE ROOF DRAIN WITH CAST IRON BODY (2 R. SMITH 1010-10). SEE PLAN FOR SIZE. (2) (3) (4) (5) (6) (7) (8) (9) (10) (11) (12) (13) (14) (15) (16) (17) (18) (19) (20) (21) (22) (23) (24) (25) (26) (27) (28) (29) (30) (31) (32) (33) (34) (35) (36) (37) (38) (39) (40) (41) (42) (43) (44) (45) (46) (47) (48) (49) (50) (51) (52) (53) (54) (55) (56) (57) (58) (59) (60) (61) (62) (63) (64) (65) (66) (67) (68) (69) (70) (71) (72) (73) (74) (75) (76) (77) (78) (79) (80) (81) (82) (83) (84) (85) (86) (87) (88) (89) (90) (91) (92) (93) (94) (95) (96) (97) (98) (99) (100)			
ERD-1	EMERGENCY ROOF DRAIN	---	---	---	---	---	---	1/2" (2) (3) (4) (5) (6) (7) (8) (9) (10) (11) (12) (13) (14) (15) (16) (17) (18) (19) (20) (21) (22) (23) (24) (25) (26) (27) (28) (29) (30) (31) (32) (33) (34) (35) (36) (37) (38) (39) (40) (41) (42) (43) (44) (45) (46) (47) (48) (49) (50) (51) (52) (53) (54) (55) (56) (57) (58) (59) (60) (61) (62) (63) (64) (65) (66) (67) (68) (69) (70) (71) (72) (73) (74) (75) (76) (77) (78) (79) (80) (81) (82) (83) (84) (85) (86) (87) (88) (89) (90) (91) (92) (93) (94) (95) (96) (97) (98) (99) (100)			
UEN-1	URINAL DRAIN NOZZLE	---	---	---	---	---	---	FORM DRAINAGE DOWNSPOUT NOZZLE WITH WALL FLANGE (2 R. SMITH 1170). REFER TO PLANS FOR SIZE.			

**ELEVATOR SUMP PUMP SCHEDULE**

MARK	CAPACITY	ELECTRICAL	BASIS	NOTES
ESP-1	50 GPM @ 20' HEAD	1/2 HP	STANDARD WIRE MESH BX 80	URYS SMALL PUMP EFFICIENT WITHOUT ELECTRICAL HYPNEALIC PLING TO SPARE. CO. BREAKER SHALL PROVIDE PROTECTIVE DISCONNECT TO SEPARATELY CAL FROM WATER PRESSURE EXCHANGE.

PRIOR TO SUBMITTAL OR PURCHASE THE PLUMBING CONTRACTOR SHALL VERIFY THE APPROPRIATE ELECTRICAL CHARACTERISTICS OF THE SELECTED PUMP. COORDINATE DIRECTLY WITH THE ELECTRICAL CONTRACTOR AND THE POWER PANEL SCHEDULES ON THE ELECTRICAL DRAWINGS.


**ELECTRIC WATER HEATER SCHEDULE**

MARK	TANK CAPACITY	RECOVERY	SETPOINT	ELECTRICAL	BASIS
WH-1	50 GAL	15 GPH @ 60° REI	120°	5.0 KW	A.O. SMITH DEL 50

PRIOR TO SUBMITTAL OR PURCHASE THE PLUMBING CONTRACTOR SHALL VERIFY THE APPROPRIATE ELECTRICAL CHARACTERISTICS OF THE SELECTED WATER HEATER. COORDINATE DIRECTLY WITH THE ELECTRICAL CONTRACTOR AND THE POWER PANEL SCHEDULES ON THE ELECTRICAL DRAWINGS.

Order Plans @ WWW.LDLine.com

Life Storage #354  
2020 South College St  
Auburn, AL 36832



ISSUE FOR CONSTRUCTION REVISIONS

NO.	DESCRIPTION

PROJECT NUMBER  
201839  
DATE  
3-15-2019

SHEET NUMBER  
P0.2