GENERAL NOTES

A DESIGN DATA PROVIDED IN ELECTRONIC FORMAT IS FOR INFORMATION PURPOSES ONLY AND SHALL NOT BE USED AT OR FOR CONSTRUCTION PURPOSES AND IS PROVIDED "AS IS" WITHOUT REPRESENTATIONS AND WARRANTIES. ANY CONFLICT BETWEEN THE INFORMATION REFLECTED ON THE LATEST REVISION OF THE SEALED PLANS SHEETS AND THE ATTACHED ELECTRONIC FORMAT SHALL BE RESOLVED IN FAVOR OF THE SEALED PLANS SHEETS

TILITIES THAT ARE MADE ADDITIONAL ESTIMATING TILITIES NOT SHOWN ON THE PLANS SHEETS ARE THE RESPONSIBILITY OF THE CONTRACTOR TO NOTIFY THE ENGINEER AND ASSUMES NO RESPONSIBILITY FOR LOCATIONS SHOWN IN THE FIELD. PRIOR TO EXCAVATION OF ALL EXISTING TILITIES IT IN THE CLIMITS OF CONSTRUCTION NOTIFY THE ENGINEER IF DISCREPANCIES ARE FOUND THAT ALL AFFECT THE CONSTRUCTION PROTECT PROTECT ALL EXISTING TILITIES

C TEMPORARY PROVISIONS SHALL BE MADE FOR ACCESS AND EGRESS TO ALL DRIVEWAYS AND ENTRANCES AT ALL TIMES DURING CONSTRUCTION TEMPORARY PROVISIONS MAY INCLUDE, BUT ARE NOT LIMITED TO ARRICADES, FLAGS INSLIGHTS, FLAGMAN, TEMPORARY PAVEMENT, AND DIRECTIONAL SIGNAGE

D REQUIREMENT STORAGE, DO NOT PARK EQUIPMENT OR STORE MATERIALS IN STATE, CONSTRUCTION, OR CITY RIGHT OF WAY

E NOTIFY THE ENGINEER IN WRITING OF ANY DISCREPANCIES BETWEEN THE FIELD AND THE PLANS BEFORE PROCEEDING WITH ANY CONSTRUCTION

F OBTAIN ALL REQUIRED CONSTRUCTION RELATED PERMITS, INCLUDING DEMOLITION PERMITS, BEFORE STARTING WORK RETAIN COPIES OF ALL PERMITS AT THE PROJECT SITE AT ALL TIMES

G APPROVAL OF THESE PLANS DOES NOT CONSTITUTE APPROVAL OF ANY LAND DISTURBING ACTIVITIES WITHIN STATE AND AREAS CONTRACTOR APPROPRIATE REGULATORY AGENCY FOR APPROVAL OF ANY STATE AND AREA DISTURBANCE

SIGNS LOCATION, NUMBER, AND SIZE ARE NOT APPROVED UNDERSTOOD EQUIPMENT PERMIT A SEPARATE PERMIT IS REQUIRED FOR ONSITE SIGNAGE

I NO CERTIFICATE OF OCCUPANCY (PANCAKE) WILL BE ISSUED UNTIL ALL SITE IMPROVEMENTS ARE COMPLETED ON THE SITE

COMPLETION WILL APPLICABLE STATE, FEDERAL, AND LOCAL BUILDING AND TILITY INSTALLATION CODES ALL MATERIALS AND CONSTRUCTION MEET CODES AND ARE IN ACCORDANCE WITH THESE PLANS AND SPECIFICATIONS UNLESS DEPARTMENT OF TRANSPORTATION STANDARDS OR LOCAL MUNICIPAL STANDARDS ARE MORE STRINGENT

K DO NOT DEVIATE FROM THESE PLANS AND SPECIFICATIONS WITHOUT PRIOR WRITTEN APPROVAL FROM THE ENGINEER OF RECORD

L WORK WITHIN OR RIGHT OF WAY

1 ALL PAVEMENT MARKINGS WITHIN OR RIGHT OF WAY SHALL BE REMOPLASTIC AND IN ACCORDANCE WITH DOT SPECIFICATIONS

RESIDENTIAL AREA, INCLUDING DAMAGED OR DISTURBED, TO ORIGINAL CONDITION OR BETTER

ALL WORK IN DOT RIGHT OF WAY SHALL COMPLY WITH DOT SPECIFICATIONS

M ARRANGE WITH INTENSIVE LIGHTING TO CONCEAL THESE FROM PUBLIC VIEW AND PREVENT INTERFERENCE WITH TRAFFIC

N ENSURE CORRECT ORIENTATION AND VERTICAL ALIGNMENT OF ALL TIES BETWEEN PROPOSED AND EXISTING PAVEMENTS, CURB AND GUTTER, SIDEWALKS, VALLEYS, AND TILITIES BEFORE BEGINNING WORK NOTIFY ENGINEER IF DISCREPANCIES EXIST

TRAFFIC CONTROL

A IF DRAINAGE DOES NOT INDICATE SITE SPECIFIC TRAFFIC CONTROL MEASURES, CONTRACTOR SHALL RESPONSIBLE FOR PROVIDING A TEMPORARY TRAFFIC CONTROL PLAN IN ACCORDANCE WITH THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES MUTCD, LATEST EDITION

ALL TEMPORARY TRAFFIC CONTROL SIGNAGE AND MARKINGS SHALL BE INSTALLED PRIOR TO CONSTRUCTION AND MAINTAINED DURING CONSTRUCTION IN ACCORDANCE WITH THE MUTCD, LATEST EDITION

C CONTACT PROPERTY OWNERS TO EFFECTED CONSTRUCTION AND COORDINATE TEMPORARY DRIVE CLOSURES AND SIDEWALK CROSSING MAINTAIN ACCESS FOR ALL PROPERTY OWNERS DURING CONSTRUCTION

D CONTROL DUST AS NECESSARY TO PREVENT INTERFERENCE WITH TRAFFIC

E INSPECT TRAFFIC CONTROL DEVICES ON A DAILY BASIS TO ENSURE PLACEMENT OF ARRICADES AND FUNCTION OF LIGHTS IS MAINTAINED THROUGHOUT CONSTRUCTION

F COORDINATE ALL LANE CLOSURES WITH THE LOCAL JURISDICTION AND A TORITY

STRUCTURE SITE DEMOLITION

A BRIEF TABLE OF ITEMS TO BE DISCONNECTED AND CAPPED BEFORE STARTING DEMOLITION OPERATIONS

BRIEF TABLE OF ARDOUS MATERIALS ABATEMENT REMEDIATED BEFORE PROCEEDING WITH DEMOLITION OPERATIONS

C ENVIRONMENTAL GEOTECHNICAL REPORTS AND ENVIRONMENTAL AND GEOTECHNICAL REPORTS AN ECOME FAMILIAR WITH ALL ISSUES BEFORE DEMOLITION

D BE SITING TILITIES LOCATED, IDENTIFIED DISCONNECT, AND SEALED, OR CAPPED INDICATED TILITIES SERVING BUILDINGS AND STRUCTURES TO BE DEMOLISHED

1 ARRANGE TO STOP INDICATED TILITIES WITH TILITY COMPANIES

IF REMOVAL RELOCATION, OR ABANDONMENT OF TILITIES AFFECT ADJACENT OCCUPIED BUILDINGS, TENANTS PROVIDE TEMPORARY TILITIES THAT PASS BUILDINGS AND STRUCTURES TO BE DEMOLISHED AND THAT MAINTAIN CONTINUITY OF SERVICE TO OTHER BUILDINGS AND STRUCTURES

DO NOT COMMENCE DEMOLITION OPERATIONS UNTIL TEMPORARY EROSION AND SEDIMENT CONTROL AND PLANT PROTECTION MEASURES ARE IN PLACE

O TAIN TEMPORARY DEMOLITION PERMIT FROM THE LOCAL AUTHORITY PRIOR TO STARTING DEMOLITION ACTITIES

E ISTING FACILITIES PROTECT ADJACENT ALKWAYS, LOADING DOCKS, BUILDING ENTRIES, AND OTHER BUILDING FACILITIES DURING DEMOLITION OPERATIONS MAINTAIN EXISTING FROM EXISTING BUILDINGS PROMPTLY REPAIR ANY FACILITIES DAMAGED CONSTRUCTION OPERATIONS TO OWNER'S SATISFACTION AT NO ADDITIONAL COST TO THE OWNER

E ISTING TILITIES MAINTAIN TILITY SERVICES TO REMAIN AND PROTECT FROM DAMAGE DURING DEMOLITION OPERATIONS

TEMPORARY PROTECTION ERECT TEMPORARY PROTECTION, SUCH AS WALKS, FENCES, RAILINGS, CANOPIES, AND COVERED PASSAGEWAYS, WHERE REQUIRED ARE AUTHORITIES HAVING JURISDICTION AND AS INDICATED

REMOVE TEMPORARY BARRIERS AND PROTECTIONS WHERE AREAS NO LONGER EXIST

WHERE OPEN EXCAVATIONS OR OTHER HAZARDOUS CONDITIONS REMAIN, LEAVE TEMPORARY BARRIERS AND PROTECTIONS IN PLACE

REMOVE DEMOLITION WASTE MATERIALS FROM PROJECT SITE AND LEGALLY DISPOSE OF THEM IN AN EPA APPROVED LANDFILL ACCEPTABLE TO AUTHORITIES HAVING JURISDICTION

10 DO NOT BURN DEMOLISHED MATERIALS UNLESS SPECIAL WRITTEN PERMISSION IS OBTAINED FROM ONER AND ENGINEER

11 CLEAN ADJACENT STRUCTURES AND IMPROVEMENTS OF DUST, DIRT, AND DEBRIS CAUSED BY DEMOLITION OPERATIONS RETURN ADJACENT AREAS TO CONDITION EXISTING BEFORE BUILDING DEMOLITION OPERATIONS BEGAN

SITE CLEARING

1 PROJECT CONDITIONS

A TRAFFIC MINIMIZE INTERFERENCE WITH ADJOINING ROADS, STREETS, ALKS, AND OTHER ADJACENT OCCUPIED FACILITIES DURING SITE CLEARING OPERATIONS

EN IRONMENTAL GEOTECHNICAL REPORTS AND ENVIRONMENTAL AND GEOTECHNICAL REPORTS AND ECOME FAMILIAR WITH ALL ISSUES BEFORE SITE CLEARING

C TILITY LOCATOR SERVICE NOTIFICATION TILITY LOCATOR SERVICE FOR AREA WHERE PROJECT IS LOCATED BEFORE SITE CLEARING

D DO NOT COMMENCE SITE CLEARING OPERATIONS NTIL TEMPORARY EROSION AND SEDIMENTATION-CONTROL AND PLANT-PROTECTION MEASURES ARE IN PLACE.

TEMPORARY EROSION AND SEDIMENTATION CONTROL

A PROVIDE TEMPORARY EROSION AND SEDIMENTATION CONTROL MEASURES TO PREVENT SOIL EROSION AND DISCHARGE OF SOIL EARING AFTER NOFFORAIR ORNED SITE TO AD ACCENT PROPERTIES AND ALKWAYS, ACCORDING TO EROSION AND SEDIMENTATION CONTROL

DRAWINGS AND REQUIREMENTS OF AUTHORITIES HAVING JURISDICTION

ERIFY TAFLOW OF WATER REDIRECTED FROM CONSTRUCTION AREAS OR GENERATED BY CONSTRUCTION ACTIVITIES DO NOT ENTER OR CROSS PROTECTION ONES

C INSPECT, MAINTAIN, AND REPAIR EROSION AND SEDIMENTATION CONTROL MEASURES DURING CONSTRUCTION NTIL PERMANENT EGETATION HAS BEEN ESTABLISHED

D REMOVE EROSION AND SEDIMENTATION CONTROLS ENSITE IS STABILIZED AND RESTORED AND STABILIZED AREAS DISTURBED DURING REMOVAL

TREE AND PLANT PROTECTION

A REPAIR OR REPLACE TREES, SHRUBS, AND OTHER EGETATION INDICATED TO REMAIN OR BE RELOCATED TO AVOID DAMAGED CONSTRUCTION OPERATIONS, IN A MANNER APPROVED BY ENGINEER

E ISTING TILITIES

A LOCATE, IDENTIFY, DISCONNECT, AND SEAL OR CAP UTILITIES INDICATED TO BE REMOVED OR ABANDONED IN PLACE ARRANGE WITH TILITY COMPANIES TO SHUT OFF SERVICE INDICATED TILITIES BEFORE PTING EXISTING TILITIES DO NOT INTERRUPT TILITIES SERVING FACILITIES OCCUPIED OR NEAR OR ERS UNLESS PERMITTED UNDER TERMS AND FOLLOWING CONDITIONS AND TIMEFRAMES AGREED TO BEFORE AFTER ARRANGING TO PROVIDE TEMPORARY TILITY SERVICES ACCORDING TO REQUIREMENTS INDICATED

1 NOTIFY TILITY OWNER NOT LESS THAN DAYS AND ACCEPT DUR OF PROPOSED TILITY INTERRUPTIONS

DO NOT PROCEED WITH TILITY INTERRUPTIONS UNTIL TILITY OWNERS PERMISSION

C POTHOLE EXISTING WATER LINES, NDERGROUND ELECTRICAL LINES, GAS LINES, NDERGROUND TELEPHONE LINES, FIBER OPTIC, AND ANOTHER BURIED UTILITIES BEFORE EXCAVATING, TRENCHING OR DRILLING SITE CLEARING AND DEMOLITION ACTITIES SHALL BE PERFORMED WHERE EXISTING TILITIES ARE LOCATED AND PROVIDE TEMPORARY SERVICE AS REQUIRED FIELD LOCATIONS AND DEPTHS TO BE ENGINEER FOR PERMIT INSTALLATION OF NEW CONSTRUCTION

1 DO NOT REMOVE TREES, SHRUBS, AND OTHER EGETATION INDICATED TO REMAIN OR TO BE RELOCATED

GRIND DOWN STUMPS AND REMOVE ROOTS, OBSTRUCTIONS, AND DEBRIS TO A DEPTH OF 1 FOOT BELOW EXPOSED SURFACES

GRADE AND EXCAVATIONS AND DEMOLITION ACTITIES SHALL BE PERFORMED WHERE EXISTING TILITIES ARE LOCATED AND PROVIDE TEMPORARY SERVICE AS REQUIRED FIELD LOCATIONS AND DEPTHS TO BE ENGINEER FOR PERMIT INSTALLATION OF NEW CONSTRUCTION

A ANY CAST IRON GATE VALVES NOT INDICATED TO BE REMOVED AND ABANDONED IN PLACE ARE TO BE REMOVED AND DISPOSED OF

D CTILE IRON VALVES AND VALVE BOXES NOT INDICATED TO BE REMOVED AND ABANDONED IN PLACE ARE TO BE REMOVED AND DISPOSED OF

A REMOVE EXISTING CONCRETE, ASPHALTREES, SHRUBS, AND OTHER EGETATION TO PERMIT INSTALLATION OF NEW CONSTRUCTION

1 DO NOT REMOVE TREES, SHRUBS, AND OTHER EGETATION INDICATED TO REMAIN OR TO BE RELOCATED

GRIND DOWN STUMPS AND REMOVE ROOTS, OBSTRUCTIONS, AND DEBRIS TO A DEPTH OF 1 FOOT BELOW EXPOSED SURFACES

GRATE AND ACCESSORIES AND DEMOLITION ACTITIES SHALL BE PERFORMED WHERE EXISTING TILITIES ARE LOCATED AND PROVIDE TEMPORARY SERVICE AS REQUIRED FIELD LOCATIONS AND DEPTHS TO BE ENGINEER FOR PERMIT INSTALLATION OF NEW CONSTRUCTION

A TAPPING SLEEVES, VALVES, AND SPECIALTIES ASSEMBLIES SLEEVE AND VALVE COMPATIBLE WITH DRILLING MACHINE

1 STANDARD: MSS SP-60.

TAPPING SLEEVE, CAST OR DUCTILE IRON OR STAINLESS STEEL, TOPIECE OLTED SLEEVE WITH FLANGED OUTLET FOR NEW BRANCH CONNECTION INCLUDING SLEEVE MATCHING SIZE AND TYPE OF PIPE MATERIAL EING TAPPED AND WITH RECESSED FLANGE FOR RANGE VALVE

ALVE, CAST IRON, NONRISING STEM, RESILIENT SEATED GATE ALVE WITH NON-RISING STEM AND TYPE OF PIPE CONNECTION RAISED FACE FLANGE MATING TAPPING SLEEVE FLANGE

VALVE BOXES: COMPLY WITH AWWA M44 FOR CAST-IRON VALVE BOXES INCLUDE TOP SECTION, AND SLIDE-TYPE EXTENSION OF LENGTH REQUIRED FOR DEPTH OF BURIAL OF ALVE, PLUS 6 INCHES LETTERING " ATER," AND OTTOM SECTION WITH ASE TO ACCEPT VALVE AND INSTALLED ARREL APPROPRIATE FOR TILITY INDICATED

ACKFOOT PRE ENTERS

A DOUBLE CHECK, DETECTOR ASSEMBLY ACKFLOW PREVENTERS

1 STANDARDS: ASSE 1048 AND UL LISTED OR FMG APPROVED.

OPERATION CONTINUOUS PRESSURE APPLICATIONS

PRESSURE LOSS PSIG MAXIMUM, TFOR MIDDLE 1 OF FLOW RANGE

BODY: CAST IRON WITH INTERIOR LINING COMPLYING WITH AWWA C550 OR THAT IS FDA APPROVED

END CONNECTIONS FLANGED

CONFIGURATION DESIGNED FOR ORIENTATION, STRAIGHT THROUGH FLOW

ATER METER BOXES

A DESCRIPTION CAST IRON BOX AND COVER FOR DISCRETE METER, IT LETTERING " ATER METER" IN COVER AND IT SLOTTED, OPEN TOP SECTION OF LENGTH TO FIT OVER SERVICE PIPING

CONCRETE ALTS

A DESCRIPTION PRECAST, REINFORCED CONCRETE ALT, DESIGNED FOR AASHTO DESIGNATION ACCORDING TO ASTM C 857 AND MADE ACCORDING TO ASTM C 858.

1 LADDER: ASTM A 36/A 36M, STEEL OR POLYETHYLENE-ENCASED STEEL STEPS,

MANHOLE: ASTM A 48/A 48M CLASS NO. 35A MINIMUM TENSILE STRENGTH, GRADUATED TYPE

FRAME AND COVER

DIMENSION INCHES MINIMUM DIAMETER, NLESS OTHERWISE INDICATED

DRAIN: ASME A112.6.3, CAST-IRON FLOOR DRAIN WITH OUTLET OF SIZE INDICATED, INCLUDING

ODY AND CLAMPING DEVICE, ADJUSTABLE STRAINER, AND FLASHING COLLAR, UNLESS OTHERWISE INDICATED

FIELD INSTALLED DRAIN FEATURES AND ACCESSORIES

10 FIRE HYDRANTS

A DRY-BARREL FIRE HYDRANTS FREESTANDING, IT COMPLYING WITH AWWA C 4-1/2-INCH (NPS 4-1/2) MAIN VALVE INLET INCLUDING INTERIOR COATING ACCORDING TO AWWA C550. HYDRANT SHALL HAVE CAST-IRON BODY.

COMPRESSION TYPE VALVE OPENING AGAINST WATER PRESSURE AND CLOSING WITH PRESSURE

1 STANDARD: AWWA C502.

PRESSURE RATING: PSIG

11 FIRE DEPARTMENT CONNECTIONS

A FIRE DEPARTMENT CONNECTIONS FREESTANDING, IT CAST IRON ENCLOSURE, T READ INLETS ACCORDING TO NFPA 13 AND MATCHING LOCAL FIRE DEPARTMENT HOSE THREADS, AND T READED OUTLET INCLUDING DETAILS, GASKETS, AND CAINS LOCATED IN CONNECTION AND PROVIDE CAPPED FOR EACH CLOSE CONNECTION INLET INCH RASSLEEVE AND PLUG AND ESSENTIC EGHBORHOOD

1 ALL APPLICATIONS

A DRAINAGE INLETS INCLUDE ALL SIZES TYPE SPECIFIC ALL ET PIECES ARE NOT INDICATED T EXCLUSIVE OF IRRIGATION APPLICATIONS

1 NONGRATE INLETS, NPS 3 AND LARGER A CAST IRON, NONRISING STEM, RESILIENT SEATED GATE ALVES IT ALE O

SET LOCALLY ING FOR INLETS IN ALTS AND A OGRATE

GATE ALVES NPS AND SMALLER RATE, NONRISING STEM

GATE ALVES NPS 3 AND LARGER A CAST IRON, OS RISING STEM, RESILIENT SEATED

CHECK VALVES: AWWA C508, SWING TYPE.

FIELD ALITY CONTROL

PIPING TESTS CONDUCT PIPING TESTS BEFORE JOINTS ARE COVERED AND AFTER CONCRETE THRUSTS HAVE CURED

A EXISTING WATER MAINS AND SERVICES

1 PROTECTION

A DESCRIPTION PROTECT EXISTING WATER MAINS AND SERVICES FROM DAMAGE DURING CONSTRUCTION

1 PROTECTION

A DESCRIPTION PROTECT EXISTING WATER MAINS AND SERVICES FROM DAMAGE DURING CONSTRUCTION

SITE WATER DISTRIBUTION

1 GENERAL

A REQUIREMENTS

1 COMPLY WITH REQUIREMENTS OF TILITY COMPANY SPECIFICATIONS APPLICABLE TO WATER MAINS AND ACKFLOW PREVENTION

COMPLY WITH STANDARDS OF AUTHORITIES HAVING JURISDICTION FOR POTABLE WATER SERVICE PIPING, INCLUDING MATERIALS, INSTALLATION, TESTING, AND DISINFECTION

PIPING MATERIALS SHALL BE AS FOLLOWS, UNLESS OTHERWISE INDICATED:

AGENCY

C INTERPRET DRAWINGS AND SPECIFICATIONS WITH RESPECT TO SCALE AND NOTATIONS AND LOCATIONS OF PIPING AND ACCESSORIES

D COORDINATE WITH TILITY COMPANY FOR REQUIREMENTS AND CONNECTION OF WATER MAIN AND SERVICES BEFORE STARTING CONSTRUCTION

COPPER TUBE AND FITTINGS

A SOFT COPPER TUBE ASTM B 88, TYPE K, WATER TUBE, ANNEALED TEMPER.

COPPER, PRESS RESEAL FITTINGS

1 NPS 2 AND SMALLER ROUGHCOPPER FITTING WITH EPDM O-RING SEAL IN EACH END

NPS 2-1/2 TO NPS 4 RON EFITTING WITH STAINLESS STEEL GRIP RING AND EPDM O-RING SEAL IN EACH END

C BRONZE FLANGES ASME B16.24, CLASS 150, WITH SOLDER-JOINT END. FURNISH CLASS 300 FLANGES IF REQUIRED TO MATC PIPING

D COPPER UNIONS MSS SP-123, CAST-COPPER-ALLOY, HEXAGONAL-STOCK BODY WITH

ALL AND SOCKET METAL TO METAL SEATING SURFACES, AND SOLDER OINT OR THREADED ENDS

D CTILE IRON PIPE AND FITTINGS

A MECHANICAL-JOINT, DUCTILE-IRON PIPE: AWWA C151, WITH MECHANICAL-JOINT BELL AND PLAIN SPIGOT END. NLESS GRADED FOR FLANGED ENDS ARE INDICATED

1 MECHANICAL-JOINT, DUCTILE-IRON FITTINGS: AWWA C110, DUCTILE- OR GRAY-IRON STANDARD PATTERN OR AWWA C153, DUCTILE-IRON COMPACT PATTERN

GLANDS, GASKETS, AND BOLTS: AWWA C111, DUCTILE- OR GRAY-IRON GLANDS, RUBBER GASKETS, AND STEEL BOLTS

PUSH-ON-JOINT, DUCTILE-IRON PIPE: AWWA C151, WITH PUSH-ON-JOINT BELL AND PLAIN SPIGOT END. NLESS GROOVED OR FLANGED ENDS ARE INDICATED

C FLANGES: ASME 16.1, CLASS 125, CAST IRON.

PIPE AND FITTINGS

A PVC, SCHEDULE 40 PIPE: ASTM D 1785. PVC, SCHEDULE 40 SOCKET FITTINGS: ASTM D 2466.

PVC, AWWA PIPE: AWWA C900, CLASS 200, WITH BELL END WITH GASKET, AND WITH SPIGOT END.

C MECHANICAL-JOINT, DUCTILE-IRON FITTINGS: AWWA C110, DUCTILE- OR GRAY-IRON STANDARD PATTERN OR AWWA C153, DUCTILE-IRON COMPACT PATTERN.

GATE ALVES

A ANCHORING AND CONNECTING TO EXISTING WATER MAINS

1 STANDARD: AWWA C600.

A DESCRIPTION PRECAST, REINFORCED CONCRETE ALT, DESIGNED FOR AASHTO DESIGNATION ACCORDING TO ASTM C 857 AND MADE ACCORDING TO ASTM C 858.

1 LADDER: ASTM A 36/A 36M, STEEL OR POLYETHYLENE-ENCASED STEEL STEPS,

MANHOLE: ASTM A 48/A 48M CLASS NO. 35A MINIMUM TENSILE STRENGTH, GRADUATED TYPE

FRAME AND COVER

DIMENSION INCHES MINIMUM DIAMETER, NLESS OTHERWISE INDICATED

DRAIN: ASME A112.6.3, CAST-IRON FLOOR DRAIN WITH OUTLET OF SIZE INDICATED, INCLUDING

ODY AND CLAMPING DEVICE, ADJUSTABLE STRAINER, AND FLASHING COLLAR, UNLESS OTHERWISE INDICATED

FIELD INSTALLED DRAIN FEATURES AND ACCESSORIES

10 FIRE HYDRANTS

A DRY-BARREL FIRE HYDRANTS FREESTANDING, IT COMPLYING WITH AWWA C 4-1/2-INCH (NPS 4-1/2) MAIN VALVE INLET INCLUDING INTERIOR COATING ACCORDING TO AWWA C550. HYDRANT SHALL HAVE CAST-IRON BODY.

COMPRESSION TYPE VALVE OPENING AGAINST WATER PRESSURE AND CLOSING WITH PRESSURE

1 STANDARD: AWWA C502.

PRESSURE RATING: PSIG

11 FIRE DEPARTMENT CONNECTIONS

A FIRE DEPARTMENT CONNECTIONS FREESTANDING, IT CAST IRON ENCLOSURE, T READ INLETS ACCORDING TO NFPA 13 AND MATCHING LOCAL FIRE DEPARTMENT HOSE THREADS, AND T READED OUTLET INCLUDING DETAILS, GASKETS, AND CAINS LOCATED IN CONNECTION AND PROVIDE CAPPED FOR EACH CLOSE CONNECTION INLET INCH RASSLEEVE AND PLUG AND ESSENTIC EGHBORHOOD

1 ALL APPLICATIONS

A DRAINAGE INLETS INCLUDE ALL SIZES TYPE SPECIFIC ALL ET PIECES ARE NOT INDICATED T EXCLUSIVE OF IRRIGATION APPLICATIONS

1 NONGRATE INLETS, NPS 3 AND LARGER A CAST IRON, NONRISING STEM, RESILIENT SEATED GATE ALVES IT ALE O

SET LOCALLY ING FOR INLETS IN ALTS AND A OGRATE

GATE ALVES NPS AND SMALLER RATE, NONRISING STEM

GATE ALVES NPS 3 AND LARGER A CAST IRON, OS RISING STEM, RESILIENT SEATED

CHECK VALVES: AWWA C508, SWING TYPE.

FIELD ALITY CONTROL

PIPING TESTS CONDUCT PIPING TESTS BEFORE JOINTS ARE COVERED AND AFTER CONCRETE THRUSTS HAVE CURED

A EXISTING WATER MAINS AND SERVICES

1 PROTECTION

A DESCRIPTION PROTECT EXISTING WATER MAINS AND SERVICES FROM DAMAGE DURING CONSTRUCTION

1 PROTECTION

A DESCRIPTION PROTECT EXISTING WATER MAINS AND SERVICES FROM DAMAGE DURING CONSTRUCTION

SITE SANITARY SEWERS

1 PROJECT CONDITIONS

A TILITY INTERRUPTION OF SERVICE SITING SANITARY SEWERAGE SERVICE COORDINATE AS REQUIRED IT TE LOCAL SANITARY SEWERAGE AUTHORITY BEFORE STARTING CONSTRUCTION

TILITY LOCATOR SERVICE NOTIFY TILITY LOCATOR SERVICE FOR AREA WHERE PROJECTS LOCATED BEFORE BEGINNING SANITARY SEWERAGE INSTALLATION OPERATIONS FIELD VERIFY ALL EXISTING TILITIES AND PROVIDE ORIGINAL AND ERTICAL LOCATION INFORMATION TO THE ENGINEER TO DETERMINE OF ANY CONFLICTS TILITIES ILL CONFLICT WITH THE PROPOSED DESIGN

D CTILE IRON, GRAY IRON, AND SERVICE PIPE AND FITTINGS

A PIPE: ASTM A 746, FOR PUSH-ON JOINTS.

PIPE FOR INTERIOR DRAINAGE PIPING: AWWA C153, DUCTILE IRON, FOR PUSH-ON JOINTS.

C GASKETS: AWWA C111, RUBBER.

PC PIPE AND FITTINGS

A PC CLEANO TS PC PIPING ASTM F 679, T1 ALL THICKNESS, PC GRADE 1T SERVICE PIPE WITH BELL-AND-SPIGOT ENDS AND WITH INTEGRAL ASTM F 477, ELASTOMERIC SEALS FOR GASKETED JOINTS

CLEANO TS

A CAST IRON CLEANO TS

1 DESCRIPTION: ASME A112.36.2M, ROUND, GRAY-IRON HOUSING WITH CLAMPING DEVICE AND NO HUB ENDS FOR SERVICE WITH SHIELDS AND SNS. RED, SCORIATED, GRAY IRON CO ER INCLUDING GRATE AND FRAME. IRON FERR LE IT INSIDE CALK OR SPIGOT CONNECTION AND COVERS NK, TAPERED THREAD, RASS CLOSURE PLUG TOP LOADING CLASSIFICATION TRAFFIC RATED, EADER TYPE, IN ALL PAVED AREAS AND AREAS SUBJECT TO VEHICULAR TRAFFIC

SEWER PIPE FITTING AND RISER TO CLEANOUT: ASTM A 74. SERVICE CLASS, CAST-IRON SOIL PIPE AND FITTINGS

P PC CLEANO TS PC COUPLING PC PIPE AND IT PC CT READED PLUG INCLUDING DEPOSITED SEALANT COMPOUND AT SEALANT JOINTS

RISER TO CLEANOUT FOR SAME MATERIAL AS SERVICE PIPING SERVING TYPE APPLICATIONS WHERE TERMINATING IN PEDESTRIAN TRAFFIC ONLY OR IN LANDSCAPED AREAS

MANHOLES

A STANDARD PRECAST CONCRETE MANHOLES

1 DESCRIPTION ASTM C 478, PRECAST, REINFORCED CONCRETE, OF DEPTH INDICATED, IT PROVISION FOR SEALANT JOINTS

DIAMETER INCHES MINIMUM, NLESS OTHERWISE INDICATED

ALLOWANCE FOR INCREASE THICKNESS OF PRECAST CONCRETE SECTIONS OR ADD CONCRETE TO ASE SECTION AS REQUIRED TO PREVENT FLOTATION

ASE SECTION INCLUDING MINIMUM THICKNESS FOR FLOOR SLAB AND INCLUDING MINIMUM THICKNESS FOR ALLS AND ASE RISER SECTION, AND SEPARATE ASE SLAB OR ASE SECTION INTEGRAL FLOOR

RISER SECTIONS INCLUDING MINIMUM THICKNESS, OF LENGTH TO PROVIDE DEPTH INDICATED

TOP SECTION ECCENTRIC CONE TYPE UNLESS CONCENTRIC CONE OR FLAT SLAB TOP TYPE IS INDICATED, AND PROVISION OF CONE OF SIGHT ATMATCHES GRADE RINGS

OINT SEALANT ASTM C 990, IT MEN OR TYLER

RESILIENT PIPE CONNECTORS ASTM C 923, CAST OR FITTED INTO MANHOLE WALLS, FOR EACH PIPE CONNECTION

STEPS INDIVIDUAL FRP STEPS OR FRP LADDER, IDENTICAL TO ALLOWANCE TO PLACE OT FEET ON ONE STEP AND DESIGNED TO PREVENT LATERAL SLIPPAGE OFF STEP CAST OR ANCHOR STEPS INTO SIDE WALLS AT 1 TO 1 INCH INTERVALS OMIT STEPS IF TOTAL DEPTH FROM FLOOR OF MANHOLE TO FINISHED GRADE IS LESS THAN INCHES

10 ADJUSTING RINGS INTERLOCKING TYPE RINGS, IT LEVELING SLOPED EDGE INTENDED FOR USE AND DIAMETER TO MATCH MANHOLE RING AND COVER, IT ELASTOMERIC SEALANT, AND STAINLESS STEEL BANDS AND CLAMPING DEVICE, INCLUDING SEALANT RECOMMENDED BY RING MANUFACTURER.

11 GRADE RINGS REINFORCED CONCRETE RINGS, OF TO INCH THICKNESS, WITH INSIDE DIAMETER MATCHING MANHOLE FRAME AND COVER, AND IT LEVELING SEALANT TO ADJUST MANHOLE FRAME AND COVER TO INDICATED ELEVATION AND SLOPE

MANHOLE FRAMES AND COVERS

1 DESCRIPTION FERROUS CASTINGS INCLUDING FRAME AND GRATE, IT LETTERING CAST INTO COVER, SIZED FOR USE WITH CLOSED-TYPE RISER, IT ACCESS HOLE

MATERIAL: ASTM A 536, GRADE 60-40-18 DUCTILE IRON, UNLESS OTHERWISE INDICATED.

IDENTIFICATION

A ARRANGE FOR INSTALLATION OF GREEN WARNING TAPES DIRECTLY OVER PIPING AND AT OUTSIDE EDGES OF UNDERGROUND MANHOLES

1 USE WARNING TAPE OR DETECTABLE WARNING TAPE OVER FERROUS PIPING.

USE DETECTABLE WARNING TAPE OVER NONFERROUS PIPING AND DUCTEDGES OF UNDERGROUND MANHOLES

FIELD QUALITY CONTROL

INSPECTIONS, TESTS, AND PREPARATIONS FOR TERMINAL EFFLUENT LINE DISPLACEMENT OR OTHER DAMAGE AS OCCURRED PROJECT INSPECT AFTER APPROXIMATELY INCHES OF ACKFILL IS IN PLACE, AND AGAIN AT COMPLETION OF PROJECT

C CORRECTIVE PROCEDURES IF LEAKAGE CORRECTION INCLUDES REMOVING AND REPLACING PIPE AND REALIGNMENT LESS THAN FULL DIAMETER OF INSIDE OF PIPE IS ISILET EEN JOINTS

D REPLACE LEAKING PIPING USING NEW MATERIALS, AND REPEAT TESTING NTIL LEAKAGE IS WITHIN ALLOWANCES SPECIFIED

SITE STORM TILITY DRAINAGE PIPING

1 PIPE AND FITTINGS GENERAL

A ALL STORM ATER PIPE, INLETS, END ALLS, AND RELATED APPURTENANCES SHALL MEET LOCAL DOT STANDARDS

ALL STORM ATER PIPES ALL EINSTALLED IN ACCORDANCE IT PIPE MANUFACTURERS INSTRUCTIONS

STEEL PIPE AND FITTINGS

A CORRUGATED-STEEL PIPE AND FITTINGS: ASTM A 760/A 760M, TYPE I WITH FITTINGS OF SIMILAR FORM AND CONSTRUCTION AS PIPE

1 STANDARD JOINTS AND CORRUGATED STEEL

COATING ALMINUM OR MINUM

PE PIPE AND FITTINGS

A CORRUGATED PE DRAINAGE PIPE AND FITTINGS NPS 3 TO NPS 10: AASHTO M252M; NPS 12 TO NPS 48: AASHTO M294M TYPE S, WITH SMOOTH WATERWAY FOR COUPLING JOINTS.

SILTTIGHT COUPLING: PE SLEEVE WITH ASTM D 1056, TYPE 2, CLASS A, GRADE 2 GASKET MATERIAL TATMATERIALS IT TEAND FITTINGS

P CORRUGATED PIPE AND FITTINGS

A CORRUGATED PE DRAINAGE PIPE AND FITTINGS NPS TO NPS SMOOTH INTERIOR, ASTM F PSI STIFFNESS ENTESTED IN ACCORDANCE IT ASTM D 1 P COMPONENTS AND A MINIMUM CELL CLASSIFICATION OF 1 AS DEFINED IN ASTM D1 FITTINGS SMOOTH INTERIOR, ASTM F SECTION ORFACTORY SECTION JOINTS ALL EMADE IT AMANUFACTURER INTEGRALLY FORMED ELL AND SPIGOT GASKETED CONNECTIONS MANUFACTURER ALL PROVIDE DOCUMENTATION SHOWING NO LEAKAGE EN GASKETED PIPE JOINTS AS TESTED IN ACCORDANCE IT ASTM D 1 ELASTOMERIC SEALS GASKETS SATISFACTORY TO ASTM F

CONCRETE PIPE AND FITTINGS

A REINFORCED CONCRETE SERVICE PIPE AND FITTINGS ASTM C 76, WITH BELL AND SPIGOT ENDS, TONGUE AND GROOVE ENDS AND GASKETED JOINTS IT ASTM C 443, RUBBER GASKET FOR SEALANT JOINTS IT ASTM C 990, BITUMEN OR BUTYL-RUBBER SEALANT, CLASS WALL B.

CAST-IRON AREA DRAINS: ASME A112.6.3 GRAY-IRON ROUND BODY WITH FLANGE AND NO GRATE INCLUDE OTTOM OUTLET FOR CAST-IRON SPIGOT CONNECTION, OF SIZE INDICATED

MANHOLES

A STANDARD PRECAST CONCRETE MANHOLES

1 DESCRIPTION ASTM C 478, PRECAST, REINFORCED CONCRETE, OF DEPTH INDICATED, IT PROVISION FOR SEALANT JOINTS

DIAMETER INCHES MINIMUM, NLESS OTHERWISE INDICATED

ALLOWANCE FOR INCREASE THICKNESS OF PRECAST CONCRETE SECTIONS OR ADD CONCRETE TO ASE SECTION AS REQUIRED TO PREVENT FL