

Panel Name:		LD	M/D or Main C.B.:	M/D							
Panel Location:		BACKROOM HALL A 153	Surface or Flush:	SURFACE							
Voltage:		120/208V	Surface or Flush:	225							
Phase/Wire:		3PH/4W	Grounding:	EQUIPMENT GROUND							
Minimum Interrupting Rating:		2,520	Sections:	TWO SECTION							
New/Existing:		NEW	Panel Rating:	NEMA 1							
Lead VA	LOAD TYPE	Branch Load Data	Wires	Breaker	Panel	Wires	Branch Load Data	LOAD TYPE	Lead VA		
1886	REF	CLOCKST REACH-IN	20 1 1 e 2 20 1	20 1	20 1	20 1	TABLE COM OUTLETS	R	1175		
1886	REF	CLOCKST REACH-IN	20 1 3 b 4 20 1	20 1	20 1	WORKSTATION - FLY ZAP	R	838			
1440	K	CLOCKST HOT CABS	20 2 7 e 8 20 1	20 1	20 1	LIGHTS ABOVE MEAT COOLER	L	72			
800	Z	CLOCKST DOGS	20 1 9 b 10 20 1	20 1	20 1	LIGHT AT OF CABINET	L	38			
1800	R	REC/REF MONITOR	20 1 11 b 12 20 1	20 1	20 1	MEAT GRINDER	R	1320			
1800	R	SEAFOOD WRAPPER	20 1 13 b 14 20 1	20 1	20 1	SEAFOOD WRAPPER	R	1800			
1800	R	SEAFOOD STORAGE FREEZER	20 1 15 b 16 20 2	20 2	20 2	MERCHANDISER	REF	1800			
1800	R	SEAFOOD TABLE/WORKER	20 1 17 e 18 20 1	20 1	20 1	MERCHANDISER	REF	1800			
1800	R	SEAFOOD STEAMER	20 1 19 e 20 20 1	20 1	20 1	MERCHANDISER	REF	1800			
1800	R	SEAFOOD ICE FLAKER	20 2 23 e 24 20 2	20 2	20 2	MERCHANDISER	REF	1800			
1200	R	MEAT BELT SEALER	20 1 25 e 26 20 1	20 1	20 1	TOILET/BATH REC/LTS	R	1689			
1200	R	3-ROLL WRAPPER	20 1 27 e 28 20 1	20 1	20 1	VENDED MACHINE	R	1800			
2000	R	MEAT SAW	20 3 35 e 36 20 1	20 1	20 1	WORKSTATION	R	1775			
1800	R	SEF SWIRL/SLICER/MONITOR	20 1 37 e 38 20 1	20 1	20 1	CONV. REC - SERVICE MEAT	R	180			
1800	R	SPARE	20 1 39 b 40 20 1	20 1	20 1	REC - OF CABINET	R	540			
1800	R	SPARE	20 1 41 e 42 20 1	20 1	20 1	FLOOR ROUBBER CHARGER	S	2400			
1800	R	SPARE	20 1 43 e 44 20 1	20 1	20 1	FLOOR ROUBBER CHARGER	S	2400			
1800	R	SPARE	20 1 45 b 46 20 1	20 1	20 1	ROOF RECEPTACLES	R	180			
1800	R	SPARE	20 1 47 e 48 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 49 e 50 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 51 b 52 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 53 e 54 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 55 e 56 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 57 b 58 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 59 e 60 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 61 e 62 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 63 b 64 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 65 e 66 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 67 e 68 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 69 b 70 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 71 e 72 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 73 e 74 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 75 b 76 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 77 e 78 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 79 e 80 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 81 b 82 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
1800	R	SPARE	20 1 83 e 84 20 1	20 1	20 1	ROOF RECEPTACLES	R	360			
11958	12423	10386	Sum per phase (VA) left side			Sum per phase (VA) right side			10071	8252	10977
10071	8252	10977	Sum per phase (VA) left side			Sum per phase (VA) right side					
22028	20565	21363	Sum per phase (VA) panel			Sum per phase (VA) panel					
85	154	150	Load Balance			Load Balance					
154	150	150	Largest Phase Load			Largest Phase Load					
150	150	150	Minimum Feeder Rating			Minimum Feeder Rating					
			Total Connected (VA):			Total Connected (VA):			Total Connected (VA):		
			Calculated Load (Amps) @ 75%			Calculated Load (Amps) @ 75%			Calculated Load (Amps) @ 75%		

Panel Name:		LE	M/D or Main C.B.:	M/D							
Panel Location:		ELEC ROOM 183	Surface or Flush:	FLUSH							
Voltage:		120/208V	Surface or Flush:	150							
Phase/Wire:		3PH/4W	Grounding:	EQUIPMENT GROUND							
Minimum Interrupting Rating:		13,671	Sections:	TWO SECTION							
New/Existing:		NEW	Panel Rating:	NEMA 1							
Lead VA	LOAD TYPE	Branch Load Data	Wires	Breaker	Panel	Wires	Branch Load Data	LOAD TYPE	Lead VA		
1331	L	WALLS LIGHTS	20 1 1 e 2 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	582		
1331	L	WALLS LIGHTS	20 1 3 b 4 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	444		
1140	L	WALLS LIGHTS	20 1 5 e 6 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	440		
1140	L	WALLS LIGHTS	20 1 7 e 8 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	78		
1140	L	WALLS LIGHTS	20 1 9 b 10 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	440		
1140	L	WALLS LIGHTS	20 1 11 e 12 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	440		
1800	L	WALLS LIGHTS	20 1 13 b 14 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	180		
1800	L	WALLS LIGHTS	20 1 15 b 16 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	180		
1800	L	WALLS LIGHTS	20 1 17 e 18 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	180		
1800	L	WALLS LIGHTS	20 1 19 e 20 20 1	20 1	20 1	20 1	WALLS LIGHTS	C42 L	180		
360	R	REC - HOSE BIBS	20 1 21 b 22 20 1	20 1	20 1	20 1	NET FOOD BAR - 4'	REF	2640		
450	R	REC - HOSE BIBS/SCALE	20 1 23 e 24 20 1	20 1	20 1	20 1	PET MERCHANDISER	R	1800		
180	R	GONDOLA POWER	20 1 25 e 26 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 27 b 28 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 29 e 30 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 31 e 32 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 33 b 34 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 35 e 36 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 37 e 38 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 39 b 40 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 41 e 42 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 43 e 44 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 45 b 46 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
180	R	GONDOLA POWER	20 1 47 e 48 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	S.S. TABLE SERV/BEER DOOR	20 1 49 e 50 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 51 b 52 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 53 e 54 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 55 e 56 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 57 b 58 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 59 e 60 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 61 e 62 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 63 b 64 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 65 e 66 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 67 e 68 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 69 b 70 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 71 e 72 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 73 e 74 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 75 b 76 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 77 e 78 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 79 e 80 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 81 b 82 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
1440	Z	KPR MONITORS	20 1 83 e 84 20 1	20 1	20 1	20 1	GONDOLA POWER	R	180		
8311	8251	8374	Sum per phase (VA) left side			Sum per phase (VA) right side			3674	5816	3700
3674	5816	3700	Sum per phase (VA) left side			Sum per phase (VA) right side					
12885	13867	13074	Sum per phase (VA) panel			Sum per phase (VA) panel					
75	118	150	Load Balance			Load Balance					
118	150	150	Largest Phase Load			Largest Phase Load					
150	150	150	Minimum Feeder Rating			Minimum Feeder Rating					
			Total Connected (VA):			Total Connected (VA):			Total Connected (VA):		
			Calculated Load (Amps) @ 100%			Calculated Load (Amps) @ 100%			Calculated Load (Amps) @ 100%		

Panel Name:		LH	M/D or Main C.B.:	M/D					
Panel Location:		ELEC ROOM 183	Surface or Flush:	FLUSH					
Voltage:		120/208V	Surface or Flush:	400					
Phase/Wire:		3PH/4W	Grounding:	EQUIPMENT GROUND					
Minimum Interrupting Rating:		6,238	Sections:	TWO SECTION					
New/Existing:		NEW	Panel Rating:	NEMA 1					
Lead VA	LOAD TYPE	Branch Load Data	Wires	Breaker	Panel	Wires	Branch Load Data	LOAD TYPE	Lead VA
1408	CP	PHARMACY REC	20 1 1 e 2 20 1	20 1	20 1	20 1	FIRE ALARM PANEL	CP	800
1408	CP	PHARMACY REC	20 1 3 b 4 20 1	20 1	20 1	20 1	U-SHOW ATTENDANT STATION	CP	1820
1408	CP	PHARMACY REC	20 1 5 e 6 20 1	20 1	20 1	20 1	U-SHOW ATTENDANT STATION	CP	1820
1200	CP	FAS CONTROLLER FRONT	20 1 7 e 8 20 1	20 1	20 1	20 1	U-SHOW ATTENDANT STATION	CP	1820
1878	CP	PHARMACY WORKSTATIONS	20 1 9 b 10 20 1	20 1	20 1	20 1	ATTENDANT/FAS	CP	1880
1878	CP	PHARMACY WORKSTATIONS	20 1 11 e 12 20 1	20 1	20 1	20 1	U-SHOW LANE	CP	1880
1208	CP	PHARMACY WORKSTATIONS	20 1 13 b 14 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1818	CP	PHARMACY WORKSTATIONS	20 1 15 b 16 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1818	CP	PHARMACY WORKSTATIONS	20 1 17 e 18 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1500	CP	PHARMACY PRINTERS	20 1 19 e 20 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1500	CP	DRIVE THRU DEDICATED	20 1 21 b 22 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1500	CP	DRIVE THRU DEDICATED	20 1 23 e 24 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1500	CP	DRIVE THRU DEDICATED	20 1 25 e 26 20 1	20 1	20 1	20 1	CHECKOUT	CP	500
1440									