



Order Plans @ WWW.LDILine.com



1 CC1 SAMPLE SCHEMATIC REFRIGERATED CASE W/ ELECTRIC DEFROST SCALE: NONE




2 CC2 SAMPLE SCHEMATIC CASE & WALK-IN W/O ELECTRIC DEFROST SCALE: NONE

SYMBOL	DESCRIPTION
	REFRIGERATION CIRCUIT DESIGNATION
	ANALOG TEMPERATURE SENSOR
	DOOR ALARM
	VARIABLE TEMPERATURE SENSOR
	CASE CONTROLLER

- NOTES
- ALL HVAC SENSORS (I.E. ANALOG TEMPERATURE SENSORS, RELATIVE HUMIDITY SENSORS, CO2 SENSORS) TO BE MOUNTED AT 7'-6" ABOVE FINISHED FLOOR.
  - LIGHTING OVERRIDE SWITCHES TO BE MOUNTED AT 6'-4" ABOVE FINISHED FLOOR.
  - DOOR ALARM OUTPUTS TO BE WIRED TO THE SPARE DIGITAL INPUT OF CASE CONTROLLER. MULTIPLE EVAPORATORS IN A BOX SHOULD BE DAISY-CHAINED TOGETHER.
  - ISLAND DESIGNATED AS DUAL TEMP WILL HAVE AN OEM INSTALLED TOGGLE SWITCH ON EACH SECTION WIRED TO THE RESPECTIVE CASE CONTROLLER SPARE DIGITAL INPUT.
  - REFER TO DETAIL 2/EM5.0 FOR CC2 HUSSMANN SAMPLE SCHEMATIC.

LEGEND

	UNIT 'A' MODBUS COMM WIRING
	UNIT 'B' MODBUS COMM WIRING
	UNIT 'C' MODBUS COMM WIRING
	UNIT 'D' MODBUS COMM WIRING
	UNIT 'E' MODBUS COMM WIRING



KEY PLAN  
SCALE: NOT TO SCALE

**Kroger**  
KROGER  
STORE #473  
2013 UNIVERSITY AVENUE  
OXFORD, MISSISSIPPI 38655  
A DEVELOPMENT OF THE KROGER COMPANY

**naos**  
Naos Design Group Of Mississippi, PLLC.  
MARC BREETZ, ARCHITECT  
645 Lakeland East Drive Suite 101  
Flowood, Mississippi 39232  
(p) 303.759.5777  
(f) 720.360.4281  
ARCHITECT OF RECORD

**CDS**  
COMMERCIAL DESIGN SYSTEMS, INC.  
13825 SW GALLEREAH DRIVE  
SHERWOOD, OREGON 97140  
503.855.7000 (P) 503.855.8902  
INTERIOR DECOR

**Pickering**  
Pickering Firm, Inc.  
Architecture - Engineering  
Planning - Surveying  
6775 Lenox Center Court, Suite 300  
Memphis, TN 38115  
901.726.8810  
ENGINEER OF RECORD:  
STRUCTURAL  
MECHANICAL  
ELECTRICAL  
CIVIL ENGINEER

**V-SOFT**  
INFRASTRUCTURE  
11280 CHESTER ROAD  
CINCINNATI, OH 45246  
T: 513-900-3819  
LOW VOLTAGE

**telgian**  
TELGIAN CORPORATION  
10230 SOUTH 60TH PLACE  
SUITE 100  
PHOENIX, AZ 85044  
T: (602) 836-4426  
HTTP://WWW.TELGIAN.COM  
FIRE PROTECTION

ISSUE LOG

NO.	REV.	DESCRIPTION	DATE
1	-	PERMIT SET	12/06/18
2	-	BID SET	03/21/19

JOB: 2019041 SCALE: AS SHOWN  
SHEET NO.

**EM2.0.1**  
PARTIAL ENERGY MANAGEMENT REFRIGERATION LAYOUT WEST