



**GENERAL NOTES**

- A. PROVIDE A MINIMUM OF (2) 1" CONDUITS FOR EACH REFRIGERATION CIRCUIT, CONSISTING OF (1) CONDUIT FOR LOW VOLTAGE AND (1) FOR LINE VOLTAGE.
- B. DETROIT WIRING AND SUCTION STOP SOLID CORE CABLES MAY BE COMBINED IN THE SAME CONDUIT, ONLY IF OVERALL FILL DOES NOT EXCEED 40% (FIELD VERIFY).
- C. FURNISH AND INSTALL ALL WIRES AND CABLES. PROVIDE FINAL TERMINATIONS FOR ALL LINE VOLTAGE WIRING AND, REFRIGERATION CONTRACTOR SHALL MAKE FINAL TERMINATIONS AT BOTH ENDS OF LOW VOLTAGE WIRES / CABLES AND DETROIT WIRING. PROVIDE SUFFICIENT SLACK AT BOTH ENDS TO ALLOW FOR SERVICE LOOPS AND TO FACILITATE PROPER TERMINATIONS. FURNISHER, INCLUDING RELATED POWER WIRING SYSTEM ON OTHER DRAWING SHEETS, PROVIDE ALL REQUIRED TERMINATIONS.
- D. IF A DISCREPANCY EXISTS BETWEEN THIS DRAWING AND SPECIFICATIONS, SPECIFICATIONS SHALL PREVAIL.
- E. REFER TO EQUIPMENT SCHEDULES ON IS-SERIES DRAWINGS FOR MOUNTING HEIGHTS AND ADDITIONAL INFORMATION. ALSO SEE DETAILS ON SHEET IS-SERIES DRAWINGS WHERE APPLICABLE.
- F. PROVIDE 10 FEET OF FLEXIBLE CONDUIT FOR REFRIGERATED CASES SERVED FROM WALL JUNCTION BOXES AND 6 FEET FOR REFRIGERATED CASES FOR CONNECTION TO CASES BY THE PHASE II EQUIPMENT CONTRACTOR.
- G. ALL WALL MOUNTED OUTLETS SERVING REFRIGERATED CASES WITH RETURN AIR FLENUM ABOVE SHALL BE ACCESSIBLE (WITH ALL WIRING FLENUM MADE AS/IF APPLICABLE).
- H. REFER TO RSD-11 FOR MOUNTING SPOTS (LOCATIONS, HEIGHTS, ETC.) REGARDING PROTOCOL UNIT ACCESSORIES AND/OR EQUIPMENT.
- I. PROVIDE HOV-RUNDS (FOR INDICATED EQUIPMENT) IN ACCORDANCE TO EXISTING REFRIGERATION UNIT PANTLENS (SEE RSD-11) (HOV-RUNDS) FOR DETROIT CIRCUITS AND ZONE WALL MOUNTED WATER CALLS AND NEW BRANDS CIRCUIT BREAKERS. SEE PH I-ENR-1 FOR REQUIRED SCHEDULE. ALL WIRING AS DIRECTED BY REFRIGERATION VENDOR.
- J. CARE SHALL BE TAKEN IN ALL ROUTING OF CONDUITS TO MINIMIZE INTERFERENCE WITH OTHER SYSTEMS.

**INTERPLAN**  
 ARCHITECTURE  
 ENGINEERING  
 INTERIOR DESIGN  
 PROJECT MANAGEMENT  
 404 COURTLAND STREET  
 SUITE 100  
 ORLANDO, FLORIDA 32804  
 PH: 407.245.5200  
 FX: 407.629.9124

THIS DOCUMENT IS NOT FOR REGULATORY APPROVAL, PERMITTING, OR CONSTRUCTION.

A WITHIN THE WALLS REMODEL FOR:  
**KROGER STORE # 478 - MARIETTA - GA**  
 3162 JOHNSON FERRY RD.,  
 MARIETTA, GA 30062



NO DATE REVISIONS  
 REVISIONS  
 PROJECTING: 2019.0125  
 DATE: 03.18.2019

**EM1.1**  
 ENERGY MANAGEMENT  
 FLOOR PLAN  
 CHECKED: DS DRAWN: VLD