



Order Plans @ www.LDILine.com

PLAN NOTES

1. FURNISH & INSTALL NEW CONCRETE SLAB. PROVIDE A SMOOTH/FLUSH FINISHED SURFACE W/ ADJACENT FLOOR. PROVIDE CONTROL JOINTS TO MATCH ADJACENT EXISTING. COORDINATE EXACT LOCATIONS AND EXTENTS OF WORK FOR EACH AREA WITH PLUMBING/REFRIGERATION DRAWINGS.
2. FURNISH & INSTALL NEW CONCRETE SLAB. MATCH EXISTING SLOPES OF ADJACENT EDGES. DEPRESS SLAB $\frac{3}{8}$ " TO ACCOMMODATE TILE FINISH & INTENT IS TO PROVIDE A SMOOTH/FLUSH FINISHED SURFACE W/ ADJACENT FLOOR AFTER TILE FINISH HAS BEEN INSTALLED. FURNISH & INSTALL NEW TILE FLOOR FINISH ON NEW SLAB WORK TO MATCH EXISTING ADJACENT. COORDINATE EXACT LOCATIONS AND EXTENTS OF WORK FOR EACH AREA WITH PLUMBING DRAWINGS.

GENERAL NOTES

1. ALL NEW SLABS SHALL BE A MINIMUM OF 4" THICK 3,000 PSI CONCRETE OVER A MINIMUM OF 4" THICK OF POROUS FILL PER SPECIFICATION SECTIONS 030180, 033105 & 033110. MATCH EXISTING ADJACENT SLAB THICKNESS.
2. COORDINATE EXACT LOCATIONS OF ALL NEW INTERIOR FLOOR SLABS W/ SHEETS A01.2, A1.1, A4.1, A4.2 & PLUMBING SHEETS.
3. ALL NEW SLABS SHALL RECEIVE CONTROL JOINTS @ MAX. 12'-0" O.C. EACH WAY. NEW SLABS POURED ADJACENT TO EXISTING SLABS SHALL HAVE JOINT LOCATIONS ALIGN W/ EXISTING ADJACENT LOCATIONS.
4. ALL NEW INTERIOR SLABS POURED AGAINST WALLS OR COLUMNS SHALL HAVE A LAYER OF 30# BUILDING FELT FROM BOT. OF POUR UP TO MIN. 6" ABOVE TOP OF SLAB AS BOND BREAK. FELT TO BE TRIMMED DOWN TO TOP OF SLAB AFTER PROPER CURING HAS OCCURRED.
5. ALL NEW SLABS POURED AGAINST EXISTING SLABS SHALL BE DOWELED TOGETHER PER ASD-69.
6. FURNISH & INSTALL NEW TRANSITION STRIPS BETWEEN TILED OR CARPETED FLOORS & EXPOSED CONCRETE FLOORS PER SHEET A1.5.
7. SEE A5 SHEETS FOR ASD & GSD DETAILS.
8. INTENT OF NEW CONCRETE SLAB WORK AT DELI PREP SERVICE LOCATIONS IS TO PROVIDE NEW SLABS THAT MATCH UP WITH EXISTING ADJOINING EDGES TO PROVIDE A SMOOTH TRANSITION ACROSS SLAB-TO-TILED SURFACES.
9. SLABS SHALL BE DEPRESSED $\frac{5}{8}$ " BELOW MAIN FINISHED FLOOR LEVEL IF RECEIVING A TILE FINISH.
10. THE FOLLOWING AREAS OF WORK ARE TO BE PRICED AS ALTERNATES:
 - 10.1. ALTERNATE #1 - ALL WORK IN DELI PREP AREA.
 - 10.2. ALTERNATE #2 - ALL WORK IN FRONT RESTROOMS.
 - 10.3. ALTERNATE #3 - ALL WORK IN REAR RESTROOMS.
 - 10.4. ALTERNATE #4 - ALL WORK IN 'PICK-UP' AREA.
 - 10.5. ALTERNATE #5 - WORK FOR REFRIGERANT LEAK DETECTION SYSTEM.

LEGEND

- INDICATES AREA OF NEW SLAB.
- INDICATES AREA OF NEW DEPRESSED SLAB

4A CONCRETE PLACEMENT PLAN - MAIN LEVEL
SCALE: $\frac{3}{32}$ " = 1'-0"

CAPSTONE
project services, plc
2211 WIDMAN WAY, STE. # 220
FORT MYERS, FL. 33901

STATE OF GEORGIA
JOHN MARK HUGHES
REGISTERED ARCHITECT
4-3-2019

CAPSTONE
PROJECT SERVICES, PLC
ARCHITECTURAL & CONSTRUCTION SERVICES
OFFICE LOCATIONS: RANOCHE, VA & FT. WALTER, FL

A REMODEL FOR:
KROGER GA-214
3199 US HWY 278, N.E. COVINGTON, GA

PROJECT: KROGER ATLANTA
04-01-2019
DATE: CONSTRUCTION SET

CONCRETE PLACEMENT PLAN

REVISIONS		
NO.	DATE	DESCRIPTION

PROJECT NO: CPS2019-017.4
CAD DWG FILE: CPS2019-017.4-A1.2
DRAWN BY: MRL
CHKD BY: JMH

A1.2