

NOTE:
ATTACHMENTS CAN BE MADE TO EITHER TOP CHORD OF JOIST OR UNISTRUT CHANNEL SPANNING TOP JOIST. ATTACHMENT OF FIXTURES TO BOTTOM CHORD OF STEEL OR ROOF METAL DECKING WILL NOT BE PERMITTED.

DETAIL BASED ON:
SPAN & SPACE AND SUPPORT OF PIPING IS USED.

REFRIGERATION PIPE SUPPORT DETAIL	DATE: 6/14/17
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-33

ORIGINAL ISSUE DATE 7/23/12



WALL MOUNTED REFRIGERATION PIPING RISER SUPPORT	DATE: 6/14/17
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-34

ORIGINAL ISSUE DATE 1/14/13



STUD WALL CAVITY REFRIGERATION PIPING RISER	DATE: 6/14/17
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-34A

ORIGINAL ISSUE DATE 11/5/13



FREESTANDING REFRIGERATION PIPING RISER SUPPORT	DATE: 6/14/17
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-34B

ORIGINAL ISSUE DATE 1/20/15



CONVENTIONAL CONTROL ELECTRIC DEFROST WIRING	DATE: 6/14/15
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-[illegible]

ORIGINAL ISSUE DATE 9/11/08



CASE TOP PIPING	DATE: 6/14/17
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-35

ORIGINAL ISSUE DATE 11/5/13



SERVICE CASE AND SINGLE WIDE ISLAND REFRIGERATION RISERS	DATE: 3/9/18
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-36

ORIGINAL ISSUE DATE 6/14/17



LOW AND DOUBLE WIDE ISLAND REFRIGERATION RISERS	DATE: 3/9/18
	SCALE: NONE
	DRAWN: ZAW
MASTER INSTALLATION DETAIL	RISD-36A

ORIGINAL ISSUE DATE 6/14/17

Order Plans @ www.BidLine.com

(CAUTION!)

NOTE:
ALL DRAWINGS AS LISTED ON L-1 SHALL BE REQUIRED AT THE JOBSITE AT ALL TIMES. IT SHALL BE SUBCONTRACTOR'S RESPONSIBILITY TO COMPLY TO ALL APPLICABLE LAWS, CODES, ORDINANCES AND REGULATIONS. ANY DEVIATIONS FROM THESE SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY. ANY CHANGES MADE WITHOUT THE KNOWLEDGE AND CONSENT OF THE ARCHITECT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR MAKING THE CHANGES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO BE FAMILIAR WITH ALL LOCAL CODES AND REGULATIONS WHICH MAY APPLY TO THIS PROJECT. IN THE EVENT OF A CONFLICT BETWEEN THE CONTRACT DOCUMENTS AND LOCAL CODES, THE MORE STRINGENT SHALL APPLY. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO NOTIFY THE ARCHITECT OF ANY CONFLICTS BEFORE PROCEEDING WITH THE WORK. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN ALL PERMITS AND APPROVALS FROM THE AUTHORITIES HAVING JURISDICTION. IT IS THE RESPONSIBILITY OF THE ARCHITECT EMPLOYED BY THE OWNER

ATLANTA
(NEW) NEIGHBORHOOD
2175 PARK LANE DRIVE
ATLANTA, GA
PHONE: (770) 496-7570 FAX: (770) 496-7569

Kroger
GENERAL OFFICE
FACILITY ENGINEERING
1014 VINE ST, CINCINNATI, OHIO 45202
PH 800 [illegible]

WITHIN THE WALLS
GA-214
3139 USHIGHWAY 278 NE
COVINGTON,GA

CURRENT PLAN DATED:
9/24/2018
ORIGINAL PLAN DATED:
9/24/2018
DRAWN: MATT CUMMINGS
CHECKED:
REVISIONS:

STANDARD PLOTTED SCALE:
1/16"=1'-0"

BUILDING STATS

TOTAL SHELVING	2819 LF
SALES AREA	42,780 SF
% OF STORE BUILDING	69 %
BASE STORE	56,557 SF
MEZZANINE	
DOCK / UTILITY	3,370 SF

GROSS BUILDING
62,021 SF

REFRIGERATION STANDARD DETAILS

STEEL PACKAGE ID
Not Applicable

GA-214

SHEET:
R5.1

CAD FILE: GA214R5.1.DWG
PLOTTED ON - Sep 24, 2018 - 2:32pm BY: mcmillan