


LEGEND

---	EXISTING WASTE LINE
---	EXISTING GREASE WASTE LINE
---	EXISTING SANITARY LINE
---	NEW WASTE LINE
---	NEW HUB DRAWN
---	EXISTING FLOOR DRAIN
---	NEW FLOOR DRAIN
---	EXISTING COOLER DRAIN
---	NEW COOLER DRAIN
---	EQUIPMENT TO BE REMOVED
---	EXISTING LINE CAPPED
---	EXISTING CLEAN OUT
---	NEW CLEAN OUT
---	EXISTING DOMESTIC COLD WATER
---	NEW DOMESTIC COLD WATER (DCM)
---	EXISTING DOMESTIC HOT WATER (DHW)
---	NEW DOMESTIC HOT WATER
---	EXISTING VALVE
---	NEW VALVE
---	EXISTING LINE
---	NEW GAS LINE

- KEYED NOTES: M01.1**
- NEW 14'x5' HOOD H-1 BY KROGER. KROGER SUPPLIED, CONTRACTOR INSTALLED. SEE HAS-4
 - 18"x16" GREASE DUCT UP TO EF-1 ON ROOF.
 - HEAT PUMP OUTDOOR UNIT, SEE HSD-11 AND ASD-89
 - HEAT PUMP INDOOR UNIT, SEE HSD-11
 - DEMO EXISTING 14' HOOD, FANS AND ASSOCIATED DUCTWORK. REUSE EXISTING ROOF OPENINGS FOR NEW HOOD EXHAUST.
 - REPLACE EXISTING RESTROOM EXHAUST FAN WITH NEW EXHAUST FAN EF-2.
 - REPLACE EXISTING RESTROOM EXHAUST FAN WITH NEW EXHAUST FAN EF-3.
 - REMOVE EXISTING AIR DISTRIBUTION DEVICES FROM THE EXISTING CEILING. REINSTALL IN NEW CEILING. COORDINATE WITH LIGHTS AND SPRINKLER SYSTEM.

HVAC SYMBOLS AND ABBREVIATIONS

---	SUPPLY AIR DUCT UP/DOWN	CHRW	CHILLED WATER RETURN
---	RETURN/EXHAUST AIR DUCT UP/DOWN	CHWS	CHILLED WATER SUPPLY
---	NEW DUCTWORK	CU-L	CONDENSING UNIT
---	NEW DUCTWORK	DIA.	DIAMETER
---	FLEXIBLE DUCT	EF-F	EXHAUST FAN
---	VOLUME DAMPER	ES	EQUAL SPLIT
---	SUPPLY DIFFUSER	F-F	FILTER
---	RETURN OR EXHAUST GRILLE	FURN-F	FURNACE
---	THERMOSTAT	GA	GAUGE
---	PRESSURE SENSOR	OA	OUTSIDE AIR
---	SMOKE DETECTOR	OE	OPEN ENDED DUCT
---	FIRE DAMPER	SD	SPLITTER DAMPER
---	FIRE/SMOKE DAMPER	U/B	UNDERGROUND
---	PIPE TURNED DOWN	UH-F	UNIT HEATER
---	PIPE TURNED UP	VD	VOLUME DAMPER
---	BRANCH PIPE OFF MAIN	A/C-F	AIR CONDITIONING SYSTEM
---	CFM	AF	ABOVE FINISHED FLOOR
---		AHU-F	AIR HANDLING UNIT



CAPSTONE PROJECT SERVICES, PLC
ARCHITECTURAL & CONSTRUCTION SERVICES
OFFICE LOCATIONS: RAINBOW, VA. & FT. MYERS, FL.

A REMODEL FOR
KROGER GA-214
3139 US HWY 278, N.E. COVINGTON, GA

PROJECT: KROGER ATLANTA
DATE: 04-01-2019
TYPE: CONSTRUCTION SET

HVAC PLAN

PROJECT NO.	QPS2019-017.4
CD NO. FILE	QPS2019-017.4-P01.1
DRAWN BY	SCA
CHECK BY	JBC

M1.1

J. B. Cobb Engineering, LLC
Mechanical/Industrial
Office: (678) 363-8754 Fax: (678) 363-8754
97 Lakewood Drive Dallas, GA 30132
Cell Phone: (404) 403-2126 jbcobbe@bellsouth.net

Order Plans @ www.jbidline.com

4A HAC PLAN SCALE: 3/8" = 1'-0"

