

CONSULTANT

SEAL

ISSUED

4/12/19 LL & PERMIT REVIEW

REVISIONS



OWNER/CLIENT
REEBOK
INTERNATIONAL

PROJECT
CHARLOTTE PREMIUM
OUTLETS

5518 NEW FASHION WAY
SUITE #510
CHARLOTTE, NC 28278

DRAWING TITLE
LIGHTING
FIXTURE
SCHEDULE

DRAWING INFORMATION
Job Number: 219007
Checked By: DFG
Drawn By: PMN
DRAWING NUMBER

E

121

LUMINAIRE SCHEDULE										
REFER TO ARCH DWGS FOR MORE MOUNTING HEIGHTS. ALL FIXTURES DO NOT NECESSARILY APPLY.										
TYPE	SYMBOL	DESCRIPTION	MANUFACTURER	BALLAST	MOUNTING	MODEL NUMBER	INPUT WATTS	VOLTAGE	LAMP	NOTES
C, LT		LUKBEAM TRACK SYSTEM- WHITE LENGTH: 2', 4', 8' LT TRACK: WHITE- SINGLE CIRCUIT LINE VOLTAGE TRACK LENGTH: 2', 4', 8'	CONTECH		VERIFY W/ ARCH. RCP	C2= LB122-2-P C4= LB122-4-P C8= LB122-8-P C2-LT= LT-2-P C4-LT= LT-4-P C8-LT= LT-8-P		120V		
T		TRACK HEAD	CONTECH	ELECTRONIC	TRACK-MOUNTED	GTL603-P	20	120V	(1) 20W LED	FOCUS HEAD PER ARCH. RCP
WW		WALL WASHER (FOR 4' x 8' TRACKS)	CONTECH	ELECTRONIC	TRACK-MOUNTED	GTL14224-HO-P	55	120V	(2) 24W T8-HO	FOCUS HEAD PER ARCH. RCP
B		16' LED HIGHBAY PENDANT	SPECTRUM		VERIFY W/ ARCH. RCP- PENDANT HUNG	FRDDH16LEDGV-55W-35K-D8101 /SC/IN5/HACT2 DIFFUSER OPTIONS (MOUNTING/LENS) BC16/CNFR	55	120V	(1) 55W LED	PROVIDE DIM. DIMMING BALLAST FOR 0-10V DIMMING
B		16' LED HANGING PENDANT	SPECTRUM		VERIFY W/ ARCH. RCP- HANGING HUNG	FRDDH16LEDGV-55W-35K-D8101 /SC/IN5/HACT2 DIFFUSER OPTIONS (MOUNTING/LENS) BC16/CNFR	55	120V	(1) 55W LED	PROVIDE DIM. DIMMING BALLAST FOR 0-10V DIMMING
P		18' GALVANIZED FINISH PENDANT	ANP LIGHTING		VERIFY W/ ARCH. RCP- PENDANT MOUNTED	D618-RBHC-20WFL-48	42	120V	(1) 42W CFL	
R		6' RECESSED LED CAN DOWNLIGHT	CONTECH		CEILING	RA61NC-430K-12D1 (TRIAC DIMMING BALLAST)		120V	7.9W LED	C6T6322L6-CLR-REFLECTOR
A		ACP LINEAR LED 2x4 RECESSED	MERCURY	ELECTRONIC	RECESSED	35E-2-32-OCT-9A-ELED-UNI (ELV DIMMING BALLAST)		120V	45690 (2) 15W/48-3500	FIXTURES WITH EMNL DESIGNATION SHALL BE PROVIDED W/ BATTERY BACKUP - 'BPBA'
J		LINEAR LED 2 LT TANDEM STRIP LENGTH: 4', 8'	MERCURY	ELECTRONIC	VERIFY W/ ARCH. RCP	J4= MM-232-OCT-CAN-2D-UNI J8= MM-232-OCT/8T-2D-2D-UNI (ELV DIMMING BALLAST)	62 114	120V	45690 (2) 15W/48-3500 45690 (4) 15W/48-3500	FIXTURES WITH EMNL DESIGNATION SHALL BE PROVIDED WITH BATTERY BACKUP - 'BPBA'
L		15' LINEAR DIRECT LED PENDANT, CABLE SUSPENDED	SPECTRUM		SUSPENDED FROM CABLE	FRDDH15LEDGV-55W-35K-D8101 /SC/IN5/HACT2 DIFFUSER OPTIONS (MOUNTING/LENS) BC15/CNFR 5W/15W/30W/42W/55W/70W/84W DIFFUSER OPTIONS (MOUNTING/LENS) BC15/CNFR	55	120V	LED	
L		15' LINEAR DIRECT LED PENDANT, CABLE SUSPENDED WITH 90 MINUTE EMERGENCY BATTERY BACKUP	SPECTRUM		SUSPENDED FROM CABLE	FRDDH15LEDGV-55W-35K-D8101 /SC/IN5/HACT2 DIFFUSER OPTIONS (MOUNTING/LENS) BC15/CNFR 5W/15W/30W/42W/55W/70W/84W DIFFUSER OPTIONS (MOUNTING/LENS) BC15/CNFR	55	120V	LED	WITH 90 MINUTE EMERGENCY BATTERY
EM		EMERGENCY LIGHT	LIGHTALARM	ELECTRONIC	WALL	LCA-2MR8-WHITE	12	120V	(2) 12W INCAND	
EXIT		EXIT SINGLE FACE EXIT SIGN WITH REMOTE LEADS	LIGHTALARM	ELECTRONIC	VERIFY W/ ARCH. RCP # IN FIELD	QLXN500R-N LAL UNIVERSAL LED EXIT UQLXN500R-OR-ID	3	120V	(1) 3W LED	
LCP		LEVITON GREEN MAX 4 CURRENT LIMITER PANEL	LEVITON	ELECTRONIC	WALL	PER SUBMITTALS		120V		
OS		LEVITON OCCUPANCY SENSOR	LEVITON	ELECTRONIC	WALL	OD615-IDW + 80301-5W		120V		
C		PAR38 LED ITW	PHILIPS			43539-6 PHILIPS 11PAR38/F25/830 DIM AF 60 3000K				
A, W, EM		LED T8 LAMP	PHILIPS			45690 PHILIPS 15W/48-3500				
WW		T8 HO FLUORESCENT	PHILIPS			25019 PHILIPS F24T5/830/HO				

REFER TO ARCHITECTURAL RCP FOR EXISTING DECK HEIGHTS

