



WALL MOUNTED EMERGENCY FIXTURE E-XML5CWZ (BLG000012) TO BE CENTERED ABOVE DOOR AND MOUNTED AT 9 FT A.F.G.

SECURITY BACK-UP BATTERY MUST BE MOUNTED ABOVE WALL SOFFIT WHERE TEMPERATURES SHOULD NOT REACH BELOW FREEZING

LUM. NO.	LABEL	MTG. HT.
1	A4	25
2	A4	25
3	A4B	25
4	A4B	25
5	A4B	25
6	A4B	25
7	A4B	25
8	S	10

LABEL	AVG	MAX	MIN	AVG/MIN	MAX/MIN
PAVED AREA	21.06	91.1	4.6	4.58	19.80
UNDEFINED AREA	3.72	91.1	0.0	N.A.	N.A.

NOTE: ALL AREA LIGHTS ON NEW 22 FT. POLES MOUNTED ON 3 FT. CONCRETE BASES

SYMBOL	QTY	LABEL	ARRANGEMENT	LUMENS	LLF	BUG RATING	WATTS/LUMINAIRE	TOTAL WATTS	MANUFACTURER	DESCRIPTION
☐	2	A4	SINGLE	14076	1.000	B3-U0-G3	140	280	Cree Inc	STR-LWY-4ME-HT-1-F-UL-BK-A-57K
☐	5	A4B	SINGLE	8972	1.040	B1-U0-G2	140	700	Cree Inc	STR-LWY-4ME-HT-1-F-UL-BK-A-57K + STRLWY-BLS1
☐	1	S	SINGLE	1074	1.000	B1-U0-G0	17.619	17.619	Cree, Inc	KR6-13L-40K-120V-EB7 with KR6T-SSGC
☐	3	X-EM	SINGLE	190	1.000	N/A	2.5	7.5	Cree Inc	E-XML5CWZ (BLG000012)

REV	BY	DATE	DESCRIPTION
R1	BJM	3/05/19	REVISED LAYOUT TO SHOW LUX PER CITY REQUIREMENT

SCALE: 1" = 30'  
DATE: 3/17/19  
LAWYER: EJM  
DWG NO: D

PROJECT NAME: TIRE DISCOUNTERS ATHENS, AL  
DRAWING NUMBER: RL-5902-S1-R1

