2012 APPENDIX B
BUILDING CODE SUMMARY
FOR ALL COMMERCIAL PROJECTS
(EXCEPT 1 AND 2-FAMILY DWELLINGS AND TOWNHOUSES)
(Reproduce the following data on the building plans sheet 1 or 2)

Name of Project: LINDSEY PETRIS CAFETERIA & DINING SERVICES ADDITION VOL. 1
Address: 1042 WEST HAMLET AVE., HAMLET N.C. Zip Code: 28345
Proposed Use: BUSINESS
Owner/Authorized Agent: RICHMOND COMMUNITY COLLEGE Phone #: (910) 410 – 1700
Owned By: ■ City/County ☐ Private ☐ State
Code Enforcement Jurisdiction: ☐ City ■ County ☐ State

LEAD DESIGN PROFESSIONAL: JAMES G. POWELL, ARCHITECT

DESIGNER	FIRM	NAME	LICENSE #	TELEPHONE #	E-MAIL
Architectural	ADW ARCHITECTS, PA	JAMES POWELL	5424	704.379.1919	JPOWELL@ADWARCHITECTS.COM
Civil	MORGAN ENGINEERING	MICHAEL MORGAN	15871	704.376.4946	MMORGAN@MORGANENG.COM
Electrical	OPTIMUM ENGINEERING	KARL EARL	26537	704.376.1212	KEARL@OPTIMUMENG.COM
Fire Alarm	OPTIMUM ENGINEERING	KARL EARL	26537	704.376.1212	KEARL@OPTIMUMENG.COM
Plumbing	OPTIMUM ENGINEERING	BRANDON HOBBS	29551	704.376.1212	BHOBBS@OPTIMUMENG.COM
Mechanical	OPTIMUM ENGINEERING	ROBERT MOORE	25221	704.376.1212	RMOORE@OPTIMUMENG.COM
Sprinkler-Standpipe				( )	
Structural	STEWART ENGINEERING	LARRY STEWART	20965	704.521.2887	LSTEWART@STEWARTENGINEERING.COM
Retaining Walls >5' High				( )	
Other				( )	

2012 EDITION OF NC CODE FOR: ☐ New Construction ■ Addition ☐ Upfit
EXISTING: ☐ Reconstruction ☐ Alteration ☐ Repair ☐ Renovation
CONSTRUCTED: (date) 1968 **ORIGINAL USE(S)** (Ch. 3): BUSINESS
RENOVATED: (date) 2004 **CURRENT USE(S)** (Ch. 3): BUSINESS
PROPOSED USE(S) (Ch. 3): BUSINESS

BASIC BUILDING DATA
Construction Type: (check all that apply) ☐ I-A ☐ I-B ■ II-A ☐ II-B ☐ III-A ☐ III-B ☐ IV ☐ V-A ☐ V-B
Sprinklers: ■ No ☐ Partial ☐ Yes ☐ NFPA 13 ☐ NFPA 13R ☐ NFPA 13D
Standpipes: ■ No ☐ Yes Class: ☐ I ☐ II ☐ III ☐ Wet ☐ Dry
Fire District: ☐ No ■ Yes (Primary) **Flood Hazard Area:** ■ No ☐ Yes
Building Height: (feet) 21'-0"
Gross Building Area:

Floor	EXISTING (Sq Ft)	NEW (Sq Ft)	Site Total
6th Floor			
5th Floor			
4th Floor			
3rd Floor			
2nd Floor			
Mezzanine			
1st Floor	39500	6946	45146
Basement			
TOTAL	39502	6944	45146

2012 NC Administrative Code and Policies

ALLOWABLE AREA

Occupancy:
Assembly ☐ A-1 ☐ A-2 ☐ A-3 ☐ A-4 ☐ A-5
Business ■
Educational ☐
Factory ☐ F-1 Moderate ☐ F-2 Low
Hazardous ☐ H-1 Detonate ☐ H-2 Deflagrate ☐ H-3 Combust ☐ H-4 Health ☐ H-5 HPM
Institutional ☐ I-1 ☐ I-2 ☐ I-3 ☐ I-4 I-3 Condition ☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5
Mercantile ☐
Residential ☐ R-1 ☐ R-2 ☐ R-3 ☐ R-4
Storage ☐ S-1 Moderate ☐ S-2 Low ☐ High-piled ☐ Parking Garage ☐ Open ☐ Enclosed ☐ Repair Garage
Utility and Miscellaneous ☐

Accessory Occupancies:
Assembly ☐ A-1 ■ A-2 ☐ A-3 ☐ A-4 ☐ A-5
Business ☐
Educational ☐
Factory ☐ F-1 Moderate ☐ F-2 Low
Hazardous ☐ H-1 Detonate ☐ H-2 Deflagrate ☐ H-3 Combust ☐ H-4 Health ☐ H-5 HPM
Institutional ☐ I-1 ☐ I-2 ☐ I-3 ☐ I-4 I-3 Condition ☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5
Mercantile ☐
Residential ☐ R-1 ☐ R-2 ☐ R-3 ☐ R-4
Storage ☐ S-1 Moderate ☐ S-2 Low ☐ High-piled ☐ Parking Garage ☐ Open ☐ Enclosed ☐ Repair Garage
Utility and Miscellaneous ☐

Incidental Uses (Table 508.2.5):
☐ Furnace room where any piece of equipment is over 400,000 Btu per hour input
☐ Rooms with boilers where the largest piece of equipment is over 15 psi and 10 horsepower
☐ Refrigerant machine room
☐ Hydrogen cutoff rooms, not classified as Group H
☐ Incinerator rooms
☐ Paint shops, not classified as Group H, located in occupancies other than Group F
☐ Laboratories and vocational shops, not classified as Group H, located in a Group E or I-2 occupancy
☐ Laundry rooms over 100 square feet
☐ Group I-3 cells equipped with padded surfaces
☐ Group I-2 waste and linen collection rooms
☐ Waste and linen collection rooms over 100 square feet
☐ Stationary storage battery systems having a liquid electrolyte capacity of more than 1,000 gallons, or a lithium-ion capacity of 1,000 pounds used for facility standby power, emergency power or uninterruptible power supplies
☐ Rooms containing fire pumps
☐ Group I-2 storage rooms over 100 square feet
☐ Group I-2 commercial kitchens
☐ Group I-2 laundries equal to or less than 100 square feet
☐ Group I-2 rooms or spaces that contain fuel-fired heating equipment

Special Uses: ☐ 402 ☐ 403 ☐ 404 ☐ 405 ☐ 406 ☐ 407 ☐ 408 ☐ 409 ☐ 410 ☐ 411 ☐ 412 ☐ 413 ☐ 414 ☐ 415 ☐ 416 ☐ 417 ☐ 418 ☐ 419 ☐ 420 ☐ 421 ☐ 422 ☐ 423 ☐ 424 ☐ 425 ☐ 426 ☐ 427

Special Provisions: ☐ 509.2 ☐ 509.3 ☐ 509.4 ☐ 509.5 ☐ 509.6 ☐ 509.7 ☐ 509.8 ☐ 509.9
Mixed Occupancy: ■ No ☐ Yes Separation: ____ Hr. Exceptions: ____
☐ Incidental Use Separation (508.2.5)
2012 NC Administrative Code and Policies

This separation is not exempt as a Non-Separated Use (see exceptions).

■ Non-Separated Use (508.3)
The required type of construction for the building shall be determined by applying the height and area limitations for each of the applicable occupancies to the entire building. The most restrictive type of construction, so determined, shall apply to the entire building.

☐ Separated Use (508.4) – See below for area calculations
For each story, the area of the occupancy shall be such that the sum of the ratios of the actual floor area of each use divided by the allowable floor area for each use shall not exceed 1.

$$\frac{\text{Actual Area of Occupancy A}}{\text{Allowable Area of Occupancy A}} + \frac{\text{Actual Area of Occupancy B}}{\text{Allowable Area of Occupancy B}} \leq 1$$

____ + ____ + ... = ____ ≤ 1.00

STORY NO.	DESCRIPTION OF USE(S)	(A) ACTUAL AREA PER STORY (SQ FT)	(B) TABLE 503 ALLOWABLE AREA	(C) ALLOWABLE AREA INCREASES (SQ FT)	(D) ALLOWABLE AREA REDUCTIONS (SQ FT)	(E) ALLOWABLE AREA PER STORY (SQ FT)	(F) MAXIMUM AREA PER STORY (SQ FT)
1	BUSINESS	43146	37500	15000	-	-	52,500

[1] Frontage area increases from Section 506.2 are computed thus:
a. Perimeter which fronts a public way or open space having 20 feet minimum width = ____ (F)
b. Total Building Perimeter = ____ (P)
c. Ratio (F/P) = ____ (F/P)
d. W = Minimum width of public way = ____ (W)
e. Percent of frontage increase $I = 100\,[F/P - 0.25] \times W/30 =$ ____ (%)

[2] The sprinkler increase per Section 506.3 is as follows:
a. Multi-story building I = 200 percent
b. Single story building I = 300 percent

[3] Unlimited area applicable under conditions of Section 507.

[4] Maximum Building Area = total number of stories in the building x E (506.4)

[5] The maximum area of open parking garages must comply with Table 406.3.5. The maximum area of air traffic control towers must comply with Table 412.1.2.

ALLOWABLE HEIGHT

	USE GROUP(S) (Table 503)	INCREASE FOR SPRINKLERS	SHOWN ON PLANS	CODE REFERENCE
Type of Construction	Type IIA		Type IIA	TABLE 503
Building Height in Feet	65'	Feet = H + 20' = N/A	20'-0"	TABLE 503
Building Height in Stories	5	Stories = 1 + N/A	1	TABLE 503

2012 NC Administrative Code and Policies

FIRE PROTECTION REQUIREMENTS

BUILDING ELEMENT	FIRE SEPARATION DISTANCE (FEET)	RATING (hr) PRIMARY FUNCTION	RATING (hr) SEPARATION	DETAIL # AND SHEET #	DESIGN # FOR RATED ASSEMBLY	DESIGN # FOR WATER PENETRATION	DESIGN # FOR MATER PENETRATION
Structural frame, including columns, girders, trusses	N/A	1	1	7/A003 8/A003 9/A003	P717 X764 X771	N/A	
Bearing Walls							
Exterior							
North	N/A	1	N/A	N/A	N/A	N/A	N/A
East	N/A	1	N/A	N/A	N/A	N/A	N/A
West	N/A	1	N/A	N/A	N/A	N/A	N/A
South	N/A	1	N/A	N/A	N/A	N/A	N/A
Interior	N/A	1	N/A	N/A	N/A	N/A	N/A
Nonbearing Walls and Partitions							
Exterior walls							
North	> 30'	0	0	N/A	N/A	N/A	N/A
East	21'-30'	1	1	N/A	U419	N/A	N/A
West	> 30'	0	0	N/A	N/A	N/A	N/A
South	> 30'	0	0	N/A	N/A	N/A	N/A
Interior walls and partitions	> 30'	0	0	N/A	N/A	N/A	N/A
Floor Construction							
Including supporting beams and joists		1	N/A	N/A	N/A	N/A	N/A
Roof Construction Including supporting beams and joists		1	1	7/A003	P717	N/A	N/A
Shaft Enclosures		N/A	N/A	N/A	N/A	N/A	N/A
Stairway Enclosures		N/A	N/A	N/A	N/A	N/A	N/A
Corridor Separation			1	N/A	N/A	N/A	N/A
Occupancy Separation			N/A	N/A	N/A	N/A	N/A
Party/Fire Wall Separation			N/A	N/A	N/A	N/A	N/A
Smoke Barrier Separation			N/A	N/A	N/A	N/A	N/A
Tenant Separation			N/A	N/A	N/A	N/A	N/A
Incidental Use Separation			N/A	N/A	N/A	N/A	N/A

* Indicate positive number permitting reduction

LIFE SAFETY SYSTEM REQUIREMENTS

Emergency Lighting:	☐ No	■ Yes
Exit Signs:	☐ No	■ Yes
Fire Alarm:	☐ No	■ Yes
Smoke Detection Systems:	☐ No	■ Yes ■ Partial _____
Panic Hardware:	☐ No	■ Yes

LIFE SAFETY PLAN REQUIREMENTS

Life Safety Plan Sheet #: A002

■ Fire and/or smoke rated wall locations (Chapter 7)
■ Assumed and real property line locations
■ Exterior wall opening area with respect to distance to assumed property lines (705.8)

2012 NC Administrative Code and Policies

■ Existing structures within 30' of the proposed building
■ Occupancy types for each area as it relates to occupant load calculation (Table 1004.1.1)
■ Occupant loads for each area
■ Exit access travel distances (1016)
■ Common path of travel distances (1014.3 & 1028.8)
☐ Dead end lengths (1018.4)
■ Clear exit widths for each exit door
■ Maximum calculated occupant load capacity each exit door can accommodate based on egress width (1005.1)
■ Actual occupant load for each exit door
☐ A separate schematic plan indicating where fire rated floor/ceiling and/or roof structure is provided for purposes of occupancy separation
■ Location of doors with panic hardware (1008.1.10)
☐ Location of doors with delayed egress locks and the amount of delay (1008.1.9.7)
☐ Location of doors with electromagnetic egress locks (1008.1.9.8)
☐ Location of doors equipped with hold-open devices
☐ Location of emergency escape windows (1029)
☐ The square footage of each fire area (902)
☐ The square footage of each smoke compartment (407.4)
☐ Note any code exceptions or table notes that may have been utilized regarding the items above.

ACCESSIBLE DWELLING UNITS
(SECTION 1107)

TOTAL DWELLING UNITS	ACCESSIBLE UNITS REQUIRED	ACCESSIBLE UNITS PROVIDED	TYPE A UNITS REQUIRED	TYPE A UNITS PROVIDED	TYPE B UNITS REQUIRED	TYPE B UNITS PROVIDED	TOTAL ACCESSIBLE UNITS PROVIDED
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

ACCESSIBLE PARKING EXISTING CAMPUS
(SECTION 1106)

LOT OR PARKING AREA	TOTAL # OF PARKING SPACES		# OF ACCESSIBLE SPACES PROVIDED				TOT % ACCESSIBLE PROVIDED
	REQUIRED	PROVIDED	REGULAR SIGNS 5' ACCESS AISLE	VAN SIGNS 132" ACCESS AISLE	8' ACCESS AISLE		
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
TOTAL	N/A	N/A	N/A	N/A	N/A	N/A	N/A

STRUCTURAL DESIGN

DESIGN LOADS:

Importance Factors: Wind (I_w) 1.15; Snow (I_s) 1.1; Seismic (I_e) 1.25

Live Loads: Roof 20 psf; Mezzanine N/A psf; Floor 100 psf

Ground Snow Load: 10 psf

2012 NC Administrative Code and Policies

Wind Design: Basic Wind Speed 95 mph (ASCE-7); Exposure Category C; Wind Base Shears (for MWFRS) Vx = 26 k Vy = 38 k

SEISMIC DESIGN CATEGORY: ☐ A ☐ B ☒ C ☐ D
Provide the following Seismic Design Parameters:
Occupancy Category (Table 1604.5) ☐ I ☐ II ☒ III ☐ IV
Spectral Response Acceleration S_s 28.8 %g S_1 ____ %g
Site Classification (Table 1613.5.2) ☐ A ☐ B ☐ C ☒ D ☐ E ☐ F
Data Source: ☐ Field Test ☒ Presumptive ☐ Historical Data
Basic structural system (check one)
☐ Bearing Wall ☐ Dual w/Special Moment Frame
☒ Building Frame ☐ Dual w/Intermediate R/C or Special Steel
☐ Moment Frame ☐ Inverted Pendulum
Seismic base shear: Vx = 30k Vy = 30k
Analysis Procedure: ☐ Simplified ☒ Equivalent Lateral Force ☐ Dynamic
Architectural, Mechanical, Components anchored? ☒ Yes ☐ No

LATERAL DESIGN CONTROL: Earthquake ☐ Wind ☒

SOIL BEARING CAPACITIES:
Field Test (provide copy of test report) 2000 psf
Presumptive Bearing capacity ____ psf
Pile type, type, and capacity: ____

SPECIAL INSPECTIONS REQUIRED: ☒ Yes ☐ No

PLUMBING FIXTURE REQUIREMENTS
(TABLE 2902.1)

196 OCCUPANTS WITH 98 MALES - 98 FEMALES

USE		WATER CLOSETS (STOOLS)		URINALS	LAVATORIES		DRINKING FOUNTAINS	SERVICE SINK(S)	
		MALE	FEMALE		MALE	FEMALE	(NOZZLES)	RESTROOM	ANCILLARY
SPACE	CONDITION	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	NEW	1	2	1	2	2	N/A	1	1
	REQUIRED	2	2	N/A	2	2	N/A	1	1

SPECIAL APPROVALS

Special approval: (Local Jurisdiction, Department of Insurance, OSC, DPI, DHHS, JCC, etc., describe below)

RICHMOND COUNTY AND NORTH CAROLINA STATE CONSTRUCTION OFFICE

2012 NC Administrative Code and Policies

ENERGY SUMMARY

ENERGY REQUIREMENTS:
The following data shall be considered minimum and any special attribute required to meet the energy code shall also be provided. Each Designer shall furnish the required portions of the project information for the plan data sheet. If performance method, state the annual energy cost for the standard reference design vs annual energy cost for the proposed design.

Climate Zone: ☒ 3 ☐ 4 ☐ 5

Method of Compliance:
☒ Prescriptive (Energy Code)
☐ Performance (Energy Code)
☐ Prescriptive (ASHRAE 90.1)
☐ Performance (ASHRAE 90.1)

THERMAL ENVELOPE

Roof/ceiling Assembly (each assembly)
Description of assembly: 1-ply PVC, ½" cover board, 3" rigid polyiso ins., 1-1/2" metal deck.
U-Value of total assembly: U-0.032
R-Value of insulation: R-34
Skylights in each assembly: 0
U-Value of skylight: 0
total square footage of skylights in each assembly: 0

Exterior Walls (each assembly)
Description of assembly: 2/8" appx., 6" metal studs w/R-19 batt insulation, vapor retarder, 7/8" rigid ins., air space and brick veneer.
U-Value of total assembly: U-0.074
R-Value of insulation: R-19+R-10= 19
Openings (windows or doors with glazing)
U-Value of assembly: 0.31
Solar heat gain coefficient: 0.27
projection factor: 0.5
Door R-Value: 0.5

Walls below grade (each assembly)
Description of assembly: None
U-Value of total assembly: 0
R-Value of insulation: 0

Floors over unconditioned space (each assembly)
Description of assembly: None
U-Value of total assembly: 0
R-Value of insulation: 0

Floor slab on grade
Description of assembly: Compacted fill, crushed stone, vapor barrier, 4" concrete
U-Value of total assembly: 0
R-Value of insulation: 0
Horizontal/vertical requirement: 0
slab heated: 0

2012 NC Administrative Code and Policies

MECHANICAL SUMMARY

MECHANICAL SYSTEMS, SERVICE SYSTEMS AND EQUIPMENT

Thermal Zone
winter dry bulb: 22
summer dry bulb: 94

Interior design conditions:
winter dry bulb: 72
summer dry bulb: 75
relative humidity: 50% - 60%

Building heating load: 220,600 btuh

Building cooling load: 216,500 btuh

Mechanical Spacing Conditioning System
Unitary
description of unit: single zone dx rooftop units with gas heat and split system heat pumps
heating efficiency: 83%
cooling efficiency: RTU-1,2,5 = 13.0 SEER; RTU-4,26 = 11.2 EER; RTU-4,27 = 13.0 SEER
size category of unit: RTU-4,25 = 3 ton; RTU-4,26 = 7.5 ton; RTU-4,27 = 4 ton
Boiler
Size category, If oversized, state reason.: n/a
Chiller
Size category, If oversized, state reason.: n/a
List equipment efficiencies:

ELECTRICAL SUMMARY

ELECTRICAL SYSTEM AND EQUIPMENT

Method of Compliance:
Energy Code: ☒ Prescriptive ☐ Performance
ASHRAE 90.1: ☐ Prescriptive ☐ Performance

Lighting schedule (each fixture type)

Fixture ID	Lamp	# of Lamps	Ballast	Wattage
EL1	LED	LED	LED	18 W
EL2	LED	LED	LED	30 W
VTL1	LED	LED	LED	35 W
VTL1A	LED	LED	LED	35 W
STL1	LED	LED	LED	80 W
RTL1	LED	LED	LED	46 W
PLL1	LED	LED	LED	25 W
PLL2	LED	LED	LED	32 W

2012 NC Administrative Code and Policies

interior wattage specified: 13652 W
interior wattage allowed: 17168.4 W
exterior wattage specified vs. allowed: N/A

Additional Prescriptive Compliance
☐ 506.2.1 More Efficient Mechanical Equipment
☒ 506.2.2 Reduced Lighting Power Density
☐ 506.2.3 Energy Recovery Ventilation Systems
☐ 506.2.4 Higher Efficiency Service Water Heating
☐ 506.2.5 On-Site Supply of Renewable Energy
☐ 506.2.6 Automatic Daylighting Control Systems

adw architects
environments for life
architecture planning interiors
2815 COLISEUM CENTRE DRIVE
SUITE 500
CHARLOTTE, NORTH CAROLINA 28217
P 704.379.1919
F 704.379.1920
www.adwarchitects.com

RICHMOND COMMUNITY COLLEGE

SCO #16-15889-02A

RICHMOND COMMUNITY COLLEGE

LINDSEY-PETRIS CAFETERIA/DINING ADDITION VOL.1

BID DOCUMENTS

CODE INFORMATION - APPENDIX B

DATE: 04.05.2019
PROJECT NO: 16063

REVISIONS
NO: DATE: DESCRIPTION:

THIS DRAWING IS THE PROPERTY OF ADW ARCHITECTS, PA, AND SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR PART. IT SHALL NOT BE USED ON ANY OTHER PROJECT OR GIVEN TO ANY OTHER COMPANY OR AGENCY WITHOUT THE CONSENT OF ADW ARCHITECTS, PA.

4-5-2019

SHEET NUMBER
A001

Order Plans @ WWW.LDILine.com