



System No. W-L-5029

UL Rating	UL Rating	UL Rating
F Rating — 1, 2 and 3 Hr (See Items 1, 3 and 4)	FT Rating — 0, 1/2, 1 and 1-1/4 Hr (See Item 3)	FTH Rating — 1, 2 and 3 Hr (See Items 1, 2 and 4)
At Ambient — 4 CFMSq Ft	At Ambient — 4 CFMSq Ft	At Ambient — 4 CFMSq Ft
L Rating At 400 F — Less Than 1 CFMSq Ft	L Rating At 400 F — Less Than 1 CFMSq Ft	L Rating At 400 F — Less Than 1 CFMSq Ft

11 PENETRATION DETAIL
NO SCALE

adwarchitects
environmentsforlife
architecture planning interiors
8 coliseum centre,
2815 coliseum drive, suite 500
charlotte, north carolina 28217
tj 704 379 1919
fj 704 379 1920
www.adwarchitects.com

optima engineering
1927 South Tryon St., Suite 305, Charlotte, NC 28203
150 Fayetteville St., Suite 520, Raleigh, NC 27601
Phone: 704-359-1292 • www.optimaengineering.com

RICHMOND
COMMUNITY COLLEGE
SCO #16-15889-02A

RICHMOND
COMMUNITY COLLEGE
LINDSEY-PETRIS
CAFETERIA / DINING
ADDITION VOL. 1

BID DOCUMENTS

DETAILS - PLUMBING

DATE	PROJECT NO
4-5-2019	16063

REVISIONS

NO	DATE	DESCRIPTION

THIS DRAWING IS THE PROPERTY OF ADW ARCHITECTS, P.A. AND SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT SHALL NOT BE USED ON ANY OTHER PROJECT OR GIVEN TO ANY OTHER COMPANY OR AGENCY WITHOUT THE CONSENT OF ADW ARCHITECTS, P.A.

SEAL

North Carolina Professional Engineer
C. FOWLER, III
28023
04/2019

P003
SHEET NUMBER
3 OF 7
OPTIMA # 17-0017

Order Plans @ WWW.WORKPLANS.COM