



1927 South Tryon St., Suite 300, Charlotte, NC 28203
150 Fayetteville St., Suite 520, Raleigh, NC 27601



SCO #16-15889-02A

RICHMOND
COMMUNITY
COLLEGE

LINDSEY-PETRIS
CAFETERIA / DINING
ADDITION VOL.1

BID DOCUMENTS

FLOOR PLAN -
POWER

DATE 4-5-2019
PROJECT NO 16063

REVISIONS

NO	DATE	DESCRIPTION

THIS DRAWING IS THE PROPERTY OF ADW ARCHITECTS, P.A. AND SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART, IT SHALL NOT BE USED ON ANY OTHER PROJECT OR GIVEN TO ANY OTHER COMPANY OR AGENCY WITHOUT THE CONSENT OF ADW ARCHITECTS, P.A.



SEAL 04/02/19

SHEET NUMBER
9 OF 11
OPTIMA # 17-0017

E201

Order Plans @

1 FLOOR PLAN - POWER 1/4" = 1'-0"

- GENERAL NOTES:
- COORDINATE DEMO LOCATIONS IN CAFE WITH ARCHITECT PRIOR TO ROUGH-IN.
 - COORDINATE EXACT LOCATION OF MECHANICAL EQUIPMENT WITH MECHANICAL DRAWINGS.
 - REFER TO MECHANICAL AND PLUMBING EQUIPMENT CONNECTION SCHEDULES ON SHEET E-008 FOR EQUIPMENT DETAILS.
- KEYED NOTES: (K)
- DISCONNECT ON SECONDARY SIDE OF TRANSFORMER SHALL BE NEMA 3R.
 - IT PANEL LOCATION, COORDINATE EXACT LOCATIONS AND REQUIREMENTS WITH OWNER PRIOR TO ROUGH-IN.
 - SECURITY PANEL LOCATION, COORDINATE EXACT LOCATION AND REQUIREMENTS WITH OWNER PRIOR TO ROUGH-IN.
 - CONNECT ROOFTOP RECEPTACLE TO CIRCUIT DLP1-8.

2 OVERALL BUILDING PLAN 1" = 30'-0"

