



1927 South Tryon St., Suite 300, Charlotte, NC 28203
150 Fayetteville St., Suite 520, Raleigh, NC 27601



SCO #16-15889-02A

**RICHMOND
COMMUNITY
COLLEGE**

LINDSEY-PETRIS
CAFETERIA / DINING
ADDITION VOL.1

BID DOCUMENTS

**CEILING PLAN -
SYSTEM**

DATE 4-5-2019
PROJECT NO 16063

REVISIONS

NO	DATE	DESCRIPTION

THIS DRAWING IS THE PROPERTY OF ADW ARCHITECTS, P.A. AND SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART, IT SHALL NOT BE USED ON ANY OTHER PROJECT OR GIVEN TO ANY OTHER COMPANY OR AGENCY WITHOUT THE CONSENT OF ADW ARCHITECTS, P.A.



SEAL 04/05/19

SHEET NUMBER
11 OF 11
OPTIMA # 17.0017

E301

Order Plans @

1 CEILING PLAN - SYSTEMS
1/4" = 1'-0"

- GENERAL NOTES:
- CONNECT NEW FIRE ALARM DEVICES TO EXISTING SYSTEM. COORDINATE WITH FIRE ALARM CONTRACTOR FOR COMPATIBILITY.
 - PROVIDE NAC/BOOSTER, AS NEEDED FOR CONNECTION TO EXISTING FIRE ALARM SYSTEM. WHERE NAC/BOOSTER NEEDED, PROVIDE SMOKE DETECTOR WITHIN 15' OF NEW EQUIPMENT.

- KEYED NOTES:
- 2" CONDUIT WITH PULL STRING RUN FROM ABOVE CEILING IN OFFICE LOT TO ABOVE CEILING IN EXISTING DINING AREA FOR OWNER TELECOM CABLE REQUIREMENTS. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH OWNER PRIOR TO ROUGH-IN.

2 OVERALL BUILDING PLAN
1" = 30'-0"

