


**1 CEILING PLAN - SYSTEMS**



- GENERAL NOTES:**
- CONNECT ALL EXISTING DEVICES TO NEW FIRE ALARM SYSTEM. VERIFY COMPATIBILITY WITH NEW SYSTEM.
- KEYED NOTES:**
- EXISTING FIRE ALARM DEVICES RELIANT.
  - NEW FACP LOCATION SHALL BE CAPABLE OF ACCEPTING EXISTING SYSTEM NOTIFICATION DEVICES. IF IT IS RECOMMENDED TO INSTALL NEW FACP, PRE-PROGRAM FACP TO DEMONSTRATE EXISTING FACP TO WORK IN OPERATION. EXISTING FIRE ALARM DEVICES TO REMAIN. FIBER SENSING LOCATION, FIBER OPTIC OR MORE INFORMATION, FIBER CONNECTION BY OWNER.

Over Plans @

**adwarchitects**  
environmentsforlife

architecture planning interiors

6 coliseum centre,  
2815 coliseum drive, suite 600  
charlotte, north carolina 28217  
tj 704 379 1919  
fj 704 379 1920  
www.adwarchitects.com



SCO #16-15889-02A

**RICHMOND COMMUNITY COLLEGE**

LEE BUILDING  
STUDENT SERVICES &  
CAREER CENTER  
VOL.2

BID DOCUMENTS


**CEILING PLAN - SYSTEMS**

DATE 4-5-2019  
PROJECT NO 16063

REVISIONS

NO	DATE	DESCRIPTION

THIS DRAWING IS THE PROPERTY OF ADW ARCHITECTS, P.A. AND SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART, IT SHALL NOT BE USED ON ANY OTHER PROJECT OR GIVEN TO ANY OTHER COMPANY OR AGENCY WITHOUT THE CONSENT OF ADW ARCHITECTS, P.A.



SEAL

SHEET NUMBER  
18 OF 16  
OPTIMA # 17.0317

**E301**