

ELECTRICAL ABBREVIATIONS table listing symbols and descriptions for various electrical components like switches, outlets, and conduits.

ELECTRICAL SYMBOL LEGEND table with columns for SYMBOL and DESCRIPTION, detailing symbols for fluorescent fixtures, pendant lights, switches, and receptacles.

LIGHTING FIXTURE SCHEDULE table with columns for DESCRIPTION, LAMPS, MOUNTING, and REMARKS, listing specific lighting fixtures and their specifications.

NOTES: 1. ALL LIGHTS FIXTURES ARE 120V. 2. LIGHTING FIXTURES IN AREAS WHERE FOOD IS PREPARED... 3. LIGHTING INTENSITY SHALL NOT BE LESS THAN 50 FOOT CANDLES... 4. FOOD AND UTENSIL STORAGE ROOMS... 5. LIGHTING INTENSITY SHALL NOT BE LESS THAN 20 FOOTCANDLES... 6. ALL EXPOSED CONDUIT SHALL BE INSTALLED AT LEAST 6" OFF THE FLOOR... 7. REFER TO EQUIPMENT PLANS... 8. NOT ALL LIGHTING FIXTURES MAY APPEAR ON DRAWINGS... 9. ALL LIGHT FIXTURES AND LAMPS TO BE PROVIDED BY OWNER...

ELECTRICAL SCHEDULE table with columns for NO., VOLTS, PH., AMPS, HEIGHT A.F.F., NEMA OUTLET TYPE, and TO OPERATE/REMARKS, providing detailed specifications for each electrical item.

NOTE: ALL RECEPTACLE COVERS AND DISCONNECT SWITCHES TO BE LABELED WITH SUPPLYING PANELBOARD AND CIRCUIT NUMBER. COORDINATE EXACT MOUNTING HEIGHTS WITH FOOD SERVICE EQUIPMENT DRAWINGS. CONFIRM CIRCUIT BREAKER AND FEEDER SIZES WITH EQUIPMENT SUPPLIER.