

LEGEND			
	HEAT DETECTOR - RATE OF RISE		FIRE ALARM CONTROL PANEL
	HEAT DETECTOR - FIXED TEMP.		FIRE ALARM SYSTEM ANNUNCIATOR
	PHOTOELECTRIC SMOKE DETECTOR		NOTIFICATION APPLIANCE CERT.
	FIRE ALARM HORN/STROBE ANNUN.		RTU MOUNTED SMOKE DETECTOR
	FIRE ALARM STROBE		SPRINKLER FLOW
	FIRE ALARM PULL STATION		SPRINKLER TAMPER
			END OF LINE

GENERAL NOTES:


1. FIRE ALARM SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 72, LATEST EDITION. PROVIDE 3/4\"/>

KEYNOTES: (X)

1. FIRE ALARM CONTROL PANEL TO BE MOUNTED 96\"/>

**FLORIDA ADMINISTRATIVE CODE
CHAPTER 61G15-32 NOTES**

- A. ALL FIRE PROTECTION SYSTEM CONTROL VALVES SHALL BE PROVIDED WITH TAMPER SWITCHES AND INTERFACE WITH THE FACP ON THE SUPERVISORY CIRCUIT. ALL FLOW SWITCHES SHALL INTERFACE WITH THE FACP ON THE ALARM CIRCUIT.
- B. FIRE ALARM CONTROL PANEL TO BE MOUNTED 96\"/>



1 FIRE ALARM DEVICE PLAN
1/8\"/>

Order Plans @ www.ediline.com

1925 Prospect Ave.
Orlando, FL 32814
P (407) 661-9100
F (407) 661-9101
www.efp.com



CLIENT NAME
WAWA
280 WEST BALTIMORE PIKE
WAWA, PENNSYLVANIA 19083

PROJECT NAME
WAWA F85FB 2019.01 STORE #5357-DOR
NW 87TH AVE. & NW 33RD ST.
DORAL, FLORIDA

SHEET TITLE
FIRE ALARM SPECIFICATIONS PLAN

No.	Revision	Description	Date
1	PRELIMINARY	PRELIMINARY	08/17/2019
2	REVISED	REVISED	08/20/2019
3	REVISED	REVISED	08/20/2019

PROJECT NO.	271708
DATE	08-03-2019
DRAWN	WAWA
CHECKED	JPM