



| | | | |
|---|-------------------------------------|----|-------------------------------------|
| 24 VAC / CO ₂ + | <input checked="" type="checkbox"/> | 1 | <input checked="" type="checkbox"/> |
| 24 VAC / CO ₂ - | <input checked="" type="checkbox"/> | 2 | <input checked="" type="checkbox"/> |
| 24 VDC PWR / ILS + | <input checked="" type="checkbox"/> | 3 | <input checked="" type="checkbox"/> |
| 24 VDC PWR / ILS - | <input checked="" type="checkbox"/> | 4 | <input checked="" type="checkbox"/> |
| ILS SIGNAL + | <input checked="" type="checkbox"/> | 5 | <input checked="" type="checkbox"/> |
| CO ₂ + SIGNAL IN | <input checked="" type="checkbox"/> | 6 | <input checked="" type="checkbox"/> |
| CO ₂ SIGNAL OUT (SALES FLOOR HVAC) | <input checked="" type="checkbox"/> | 7 | <input checked="" type="checkbox"/> |
| OUTDOOR AIR TEMPERATURE | <input checked="" type="checkbox"/> | 8 | <input checked="" type="checkbox"/> |
| OUTDOOR LIGHT | <input checked="" type="checkbox"/> | 9 | <input checked="" type="checkbox"/> |
| EMPLOYEE OVERRIDE | <input checked="" type="checkbox"/> | 10 | <input checked="" type="checkbox"/> |
| EXTERIOR OVERRIDE | <input checked="" type="checkbox"/> | 11 | <input checked="" type="checkbox"/> |
| BACNET NETWORK | <input checked="" type="checkbox"/> | 12 | <input checked="" type="checkbox"/> |
| SHLD | <input checked="" type="checkbox"/> | 13 | <input checked="" type="checkbox"/> |
| V+ | <input checked="" type="checkbox"/> | 14 | <input checked="" type="checkbox"/> |
| DATA- | <input checked="" type="checkbox"/> | 15 | <input checked="" type="checkbox"/> |
| DATA+ | <input checked="" type="checkbox"/> | 16 | <input checked="" type="checkbox"/> |
| GND | <input checked="" type="checkbox"/> | 17 | <input checked="" type="checkbox"/> |
| MODBUS NETWORK / ND ENERGY METER | <input checked="" type="checkbox"/> | 18 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 19 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 20 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 21 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 22 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 23 | <input checked="" type="checkbox"/> |
| | <input checked="" type="checkbox"/> | 24 | <input checked="" type="checkbox"/> |

- JUMPER SETTINGS**
- JP1
 - JP2
 - JP3
 - JP4
 - JP5
 - JP6
 - JP7
 - JP8
 - JP19

VIEW C-C
 VIEW C-C SHOWS JUMPER JP-22 SET TO 19200 BAUD ACCOMMODATING THE AUNTUMBRA OVERRIDE

INTERFACE PANEL & eSC WIRING DETAILS
 SCALE: None

VIEW D-D
 VIEW D-D SHOWS TB8 MAXIMUM TIGHTENING TORQUE
 UL 4.4 lb-in / SEV 0.5 Nm

DOLLAR TREE
EQUIPMENT DETAILS
 (FOR REFERENCE ONLY NOT TO SCALE)

| | | |
|---------------------------------|----------------|------------|
| REVISION: 7 | DATE: 07/10/18 | ECN#: 2306 |
| UPDATE TO CURRENT CYLON ADDRESS | | |
| REVISION: 8 | DATE: 09/27/18 | ECN#: 2339 |
| ADD METER | | |
| REVISION: | DATE: | ECN#: |
| REVISION: | DATE: | ECN#: |
| DRAWN: WPC | ENGINEER: CGP | |
| PART #: 94-339 | OPTION: P | |