

5. UNITS SHALL A CLEAR FLOOR OR GROUND SPACE COMPLYING WITH SECTION 11B-305 POSITIONED FOR A FORWARD APPROACH AND CENTERED ON THE UNIT. KNEE AND TOE CLEARANCE COMPLYING WITH SECTION 11B-306 SHALL BE PROVIDED. (SECTION 11B-602.2)

6. A PARALLEL APPROACH COMPLYING WITH SECTION 11B-305 SHALL BE PERMITTED AT UNITS FOR CHILDRENS USE WHERE THE SPOUT IS 30 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND AND IS 3/4 INCHES MAXIMUM FROM THE FRONT EDGE OF THE UNIT, INCLUDING BUMPERS. (SECTION 11B-602.2 - SEE EXCEPTION)

7. SPOUT OUTLETS SHALL BE 36 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. (SECTION 11B-602.4)

8. THE SPOUT SHALL BE LOCATED 15 INCHES MINIMUM FROM THE VERTICAL SUPPORT AND 5 INCHES MAXIMUM FROM THE FRONT EDGE OF THE UNIT, INCLUDING BUMPERS. (SECTION 11B-602.5)

9. THE SPOUT SHALL PROVIDE A FLOW OF WATER 4 INCHES HIGH MINIMUM AND SHALL BE LOCATED 5 INCHES MAXIMUM FROM THE FRONT OF THE UNIT. THE ANGLE OF THE WATER STREAM SHALL BE MEASURED HORIZONTALLY RELATIVE TO THE FRONT FACE OF THE UNIT. WHERE SPOUTS ARE LOCATED LESS THAN 3 INCHES FROM THE FRONT OF THE UNIT, THE ANGLE OF THE WATER STREAM SHALL BE 30 DEGREES MAXIMUM. WHERE SPOUTS ARE LOCATED BETWEEN 3 INCHES AND 5 INCHES MAXIMUM FROM THE FRONT OF THE UNIT, THE ANGLE OF THE WATER STREAM SHALL BE 15 DEGREES MAXIMUM. (SECTION 11B-602.6)

10. SPOUT OUTLETS OF DRINKING FOUNTAINS FOR STANDING PERSONS SHALL BE 38 INCHES MINIMUM AND 43 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. (SECTION 11B-602.7)

11. WALL AND POST MOUNTED CANTILEVERED DRINKING FOUNTAINS SHALL BE 18 INCHES MINIMUM AND 19 INCHES MAXIMUM IN DEPTH. (SECTION 11B-602.8)

12. ALL DRINKING FOUNTAINS SHALL EITHER BE LOCATED COMPLETELY WITHIN ALCOVES, POSITIONED COMPLETELY BETWEEN WING WALLS, OR OTHERWISE POSITIONED SO AS NOT TO ENCRoACH INTO PEDESTRIAN WAYS. THE PROTECTED AREA WITHIN SUCH A DRINKING FOUNTAIN IS LOCATED SHALL BE 32 INCHES WIDE MINIMUM AND 18 INCHES DEEP MINIMUM, AND SHALL COMPLY WITH SECTION 11B-305.7 MANEUVERING CLEARANCE. WHEN USED, WING WALLS OR BARRIERS SHALL PROTECT HORIZONTALLY AT LEAST AS FAR AS THE DRINKING FOUNTAIN AND TO WITHIN 6 INCHES VERTICALLY FROM THE FLOOR OR GROUND SURFACE. (SECTION 11B-602.9)

TOILET AND BATHING ROOM CLEARANCES

13. WHERE TOILET FACILITIES AND BATHING FACILITIES ARE PROVIDED, THEY SHALL COMPLY WITH SECTION 11B-213 WHERE TOILET FACILITIES AND BATHING FACILITIES ARE PROVIDED IN FACILITIES PERMITTED BY 11B-206.2.3 EXCEPTIONS 1 NOT TO CONNECT STORIES BY AN ACCESSIBLE ROUTE, TOILET FACILITIES AND BATHING FACILITIES SHALL BE PROVIDED ON A STORY CONNECTED BY AN ACCESSIBLE ROUTE TO AN ACCESSIBLE ENTRANCE. (SECTION 11B-213.1)

14. WHERE SEPARATE TOILET FACILITIES ARE PROVIDED FOR THE EXCLUSIVE USE OF SEPARATE USER GROUPS, THE TOILET FACILITIES SERVING EACH USER GROUP SHALL COMPLY WITH 11B-213 TOILET FACILITIES AND BATHING FACILITIES. (SECTION 11B-213.1.1)

15. WHERE TOILET ROOMS ARE PROVIDED, EACH TOILET ROOM SHALL COMPLY WITH 11B-603 TOILET AND BATHING ROOMS, WHERE BATHING ROOMS ARE PROVIDED, EACH BATHING ROOM SHALL COMPLY WITH 11B-603 TOILET AND BATHING ROOMS. (SECTION 11B-213.2 - SEE EXCEPTION)

16. UNISEX TOILET ROOMS SHALL CONTAIN NOT MORE THAN ONE LAVATORY, AND NOT MORE THAN TWO WATER CLOSETS WITHOUT URINALS OR ONE WATER CLOSET AND ONE URINAL. UNISEX BATHING ROOMS SHALL CONTAIN ONE SHOWER OR ONE BATHTUB AND ONE BATHTUB, ONE LAVATORY, AND ONE WATER CLOSET. DOORS TO UNISEX TOILET ROOMS AND UNISEX BATHING ROOMS SHALL HAVE PRIVACY LATCHES. (SECTION 11B-213.1.1)

17. COMMON-USE UNISEX TOILET ROOMS FOR EXCLUSIVE PATIENT USE NOT LOCATED WITHIN PATIENT BEDROOMS SHALL CONTAIN A LAVATORY AND ONE WATER CLOSET. (SECTION 11B-213.2.2)

18. COMMON-USE UNISEX BATHING ROOMS FOR EXCLUSIVE PATIENT USE NOT LOCATED WITHIN PATIENT BEDROOMS SHALL CONTAIN ONE SHOWER OR ONE BATHTUB, ONE LAVATORY, AND ONE WATER CLOSET. (SECTION 11B-213.2.3)

19. PLUMBING FIXTURES AND ACCESSORIES PROVIDED IN A TOILET ROOM OR BATHING ROOM REQUIRED TO COMPLY WITH 11B-213.2 TOILET AND BATHING ROOMS SHALL COMPLY WITH 11B-213.3 PLUMBING FIXTURES AND ACCESSORIES. (SECTION 11B-213.3)

20. DOORS SHALL NOT SWING INTO THE CLEAR FLOOR SPACE OR CLEARANCE REQUIRED FOR ANY FIXTURE. DOORS NOT LOCATED ABOVE THE LAVATORIES OR COUNTERTOPS SHALL BE PERMITTED TO ENCRoACH INTO THE TURNING SPACE WITHOUT LIMITATIONS. OTHER THAN DOORS TO ACCESSIBLE WATER CLOSET COMPARTMENTS, A DOOR, IN ANY POSITION SHALL BE PERMITTED TO ENCRoACH ONTO TURNING SPACE BY 12 INCHES MAXIMUM. (SECTION 11B-603.2.3)

21. WHERE THE TOILET ROOM OR BATHING ROOM IS FOR INDIVIDUAL USE AND A CLEAR FLOOR SPACE COMPLYING WITH SECTION 11B-305 IS PROVIDED, THE TOILET ROOM SHALL BE LOCATED ON THE DOOR SWING. DOORS SHALL BE PERMITTED TO SWING INTO THE CLEAR FLOOR SPACE OR CLEARANCE REQUIRED FOR ANY FIXTURE. (SECTION 11B-603.3 - SEE EXCEPTION)

22. MIRRORS LOCATED ABOVE THE LAVATORIES OR COUNTERTOPS SHALL BE INSTALLED WITHIN THE BOTTOM EDGE OF THE REFLECTING SURFACE 40 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. MIRRORS NOT LOCATED ABOVE THE LAVATORIES OR COUNTERTOPS SHALL BE INSTALLED WITH THE BOTTOM EDGE OF THE REFLECTING SURFACE 35 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. (SECTION 11B-603.3)

23. COAT HOOKS SHALL BE LOCATED WITHIN ONE OF THE REACH RANGES SPECIFIED IN SECTION 11B-308. SHELVES SHALL BE LOCATED 40 INCHES MINIMUM AND 48 INCHES MAXIMUM ABOVE THE FINISH FLOOR. THERE SHALL BE A USABLE SHELF WITH A USABLE SHELF NO HIGHER THAN 44 INCHES MAXIMUM ABOVE THE FINISH FLOOR. (SECTION 11B-603.4)

24. WHERE TOWEL OR SANITARY NAPKIN DISPENSERS, WASTE RECEPTACLES, OR OTHER ACCESSORIES ARE PROVIDED IN TOILET FACILITIES, AT LEAST ONE OF EACH TYPE SHALL BE LOCATED ON AN ACCESSIBLE ROUTE. ALL OPERABLE PARTS, INCLUDING COIN SLOTS, SHALL BE 40 INCHES MAXIMUM ABOVE THE FINISH FLOOR. (SECTION 11B-603.5)

25. TOILET AND BATHING ROOMS WITHIN GUEST ROOMS THAT ARE NOT REQUIRED TO PROVIDE MOBILITY FEATURES COMPLYING WITH SECTION 11B-806.2 GUEST ROOMS WITH MOBILITY FEATURES SHALL PROVIDE ALL TOILET AND BATHING FIXTURES IN A LOCATION THAT ALLOWS A PERSON USING A WHEELCHAIR MEASURING 30 INCHES BY 48 INCHES TO TOUCH THE WHEELCHAIR TO ANY LAVATORY, URINAL, WATER CLOSET, SHOWER, SHOWER STALL & ANY OTHER SIMILAR SANITARY INSTALLATION, IF PROVIDED. (SECTION 11B-603.6)

WATER CLOSETS AND TOILET COMPARTMENT

26. THE WATER CLOSET SHALL BE POSITIONED WITH A WALL OR PARTITION TO THE REAR AND TO ONE SIDE. THE CENTERLINE OF THE WATER CLOSET SHALL BE 17 INCHES MINIMUM AND 18 INCHES MAXIMUM FROM THE SIDE WALL OR PARTITION, EXCEPT THAT THE WATER CLOSET SHALL BE 17 INCHES MINIMUM TO 19 INCHES MAXIMUM FROM THE SIDE WALL OR PARTITION IN THE AMBULATORY ACCESSIBLE TOILET COMPARTMENT SPECIFIED IN SECTION 11B-604.2. AMBULATORY ACCESSIBLE COMPARTMENTS, WATER CLOSET SHALL BE APPROACHED FROM A LEFT-HAND OR RIGHT-HAND APPROACH. (SECTION 11B-604.2)

27. CLEARANCE AROUND A WATER CLOSET SHALL BE 60 INCHES MINIMUM MEASURED PERPENDICULAR FROM THE SIDE WALL AND 56 INCHES MINIMUM MEASURED PERPENDICULAR FROM THE REAR WALL. A MINIMUM 60 INCHES WIDE AND 48 INCHES DEEP MANEUVERING SPACE SHALL BE PROVIDED IN FRONT OF THE WATER CLOSET. (SECTION 11B-604.3)

28. THE SEAT HEIGHT OF A WATER CLOSET ABOVE THE FINISH FLOOR SHALL BE 17 INCHES MINIMUM AND 19 INCHES MAXIMUM MEASURED TO THE TOP OF THE SEAT. SEATS SHALL NOT BE SPRUNG THE RETURN TO A LIFTED POSITION. SEATS SHALL BE 2 INCHES HIGH MAXIMUM. (SECTION 11B-604.4 - SEE EXCEPTION FOR RESIDENTIAL UNITS)

29. GRAB BARS FOR WATER CLOSETS SHALL COMPLY WITH SECTION 11B-609. GRAB BARS SHALL BE PROVIDED ON THE SIDE WALL CLOSEST TO THE WATER CLOSET AND ON THE REAR WALL. WHERE SEPARATE GRAB BARS ARE REQUIRED ON ADJACENT WALLS AT A COMMON MOUNTING HEIGHT, AND L-SHAPED GRAB BAR MEETING THE DIMENSIONAL REQUIREMENTS OF SECTIONS 11B-604.5.1 SIDE WALL AND 11B-604.5.2 REAR WALL SHALL BE PERMITTED. (SECTION 11B-604.5)

30. THE SIDE WALL GRAB BARS SHALL BE 42 INCHES LONG MINIMUM, LOCATED 12 INCHES MAXIMUM FROM THE REAR WALL AND EXTENDING 54 INCHES MINIMUM FROM THE REAR WALL WITH THE FRONT END POSITIONED 24 INCHES MINIMUM IN FRONT OF THE WATER CLOSET. (SECTION 11B-604.5.1)

31. THE REAR GRAB BAR SHALL BE 36 INCHES LONG MINIMUM AND EXTEND FROM THE WATER CLOSET TO THE OTHER SIDE. (SECTION 11B-604.5.2 - SEE EXCEPTIONS)

32. FLUSH CONTROLS SHALL BE HAND OPERATED OR AUTOMATIC. HAND OPERATED FLUSH CONTROLS SHALL COMPLY WITH SECTION 11B-309 EXCEPT THEY SHALL BE LOCATED 44 INCHES MAXIMUM ABOVE THE FLOOR. FLUSH CONTROLS SHALL BE LOCATED ON THE OPEN SIDE OF THE WATER CLOSET EXCEPT IN AMBULATORY ACCESSIBLE COMPARTMENTS COMPLYING WITH SECTION 11B-604.8.2 AMBULATORY ACCESSIBLE COMPARTMENT. (SECTION 11B-604.6)

33. TOILET PAPER DISPENSERS SHALL COMPLY WITH SECTION 11B-309.4 OPERATION AND SHALL BE 7 INCHES MINIMUM AND 9 INCHES MAXIMUM IN FRONT OF THE WATER CLOSET MEASURED TO THE CENTERLINE OF THE DISPENSER. THE OUTLET OF THE DISPENSER SHALL BELOW THE GRAB BARS, 19 INCHES MINIMUM ABOVE THE FINISH FLOOR AND SHALL NOT BE LOCATED BEHIND THE GRAB BARS. DISPENSERS SHALL NOT BE OF A TYPE THAT CONTROL DELIVERY OR THAT DOES NOT ALLOW CONTINUOUS PAPER FLOW. (SECTION 11B-604.7)

34. WHEELCHAIR ACCESSIBLE TOILET COMPARTMENTS SHALL MEET THE REQUIREMENTS OF SECTION 11B-604.8.1 WHEELCHAIR ACCESSIBLE COMPARTMENTS AND 11B-604.8.3 COAT HOOKS AND SHELVES. COMPARTMENTS CONTAINING MORE THAN ONE PLUMBING FIXTURE SHALL COMPLY WITH SECTION 11B-603 TOILET & BATHING ROOMS. AMBULATORY ACCESSIBLE COMPARTMENTS SHALL COMPLY WITH SECTIONS 11B-604.8.2 AMBULATORY ACCESSIBLE COMPARTMENTS AND 11B-604.8.3 COAT HOOKS AND SHELVES. (SECTION 11B-604.8)

35. WHEELCHAIR ACCESSIBLE COMPARTMENTS SHALL BE 60 INCHES WIDE MINIMUM MEASURED PERPENDICULAR TO THE SIDE WALL, AND 56 INCHES DEEP MINIMUM FOR WALL HUNG WATER CLOSETS AND 59 INCHES DEEP MINIMUM FOR FLOOR MOUNTED WATER CLOSETS MEASURED PERPENDICULAR TO THE REAR WALL. WHEELCHAIR ACCESSIBLE COMPARTMENTS SHALL ADDITIONALLY PROVIDE MANEUVERING SPACE COMPLYING WITH SECTION 11B-614.8.1.1, 11B-604.8.1.1.2, 11B-604.8.1.1.3 AS APPLICABLE. WHEELCHAIR ACCESSIBLE COMPARTMENTS FOR CHILDRENS USE SHALL BE 60 INCHES WIDE MINIMUM MEASURED PERPENDICULAR TO THE SIDE WALL, AND 59 INCHES DEEP MINIMUM FOR WALL HUNG AND FLOOR MOUNTED WATER CLOSETS MEASURED PERPENDICULAR TO THE REAR WALL. (SECTION 11B-604.8.1.1)

36. IN A WHEELCHAIR ACCESSIBLE COMPARTMENT WITH AN IN-SWING DOOR, A MINIMUM 60 INCHES WIDE BY 36 INCHES DEEP MANEUVERING SPACE SHALL BE PROVIDED IN FRONT OF THE CLEARANCE REQUIRED IN SECTION 11B-604.8.1.1 WHEELCHAIR ACCESSIBLE COMPARTMENT SIZE. (SECTION 11B-604.8.1.1.1, FIGURES 11B-604.8.1.1.2(B) & 11B-604.8.1.1.3(B))

37. IN A WHEELCHAIR ACCESSIBLE COMPARTMENT WITH A DOOR LOCATED IN THE SIDE WALL OR PARTITION, EITHER IN-SWINGING OR OUT-SWINGING, A MINIMUM 60 INCHES WIDE AND 60 INCHES DEEP MANEUVERING SPACE SHALL BE PROVIDED IN FRONT OF THE WATER CLOSET. (SECTION 11B-604.8.1.2, FIGURE 11B-604.8.1.2)

38. IN A WHEELCHAIR ACCESSIBLE COMPARTMENT WITH END-OPENING DOOR (FACING WATER CLOSET), EITHER IN-SWINGING OR OUT-SWINGING, A MINIMUM 60 INCHES WIDE AND 48 INCHES DEEP MANEUVERING SPACE SHALL BE PROVIDED IN FRONT OF THE WATER CLOSET. (SECTION 11B-604.8.1.3, FIGURE 11B-604.8.1.3)

39. TOILET COMPARTMENT DOORS, INCLUDING DOOR HARDWARE, SHALL COMPLY WITH SECTION 11B-404 DOORS, DOORWAYS, AND GATES EXCEPT THAT IF THE APPROACH IS FROM THE PUSH SIDE OF THE COMPARTMENT DOOR, CLEARANCE BETWEEN THE DOOR SIDE OF THE COMPARTMENT AND ANY OBSTRUCTION SHALL BE 48 INCHES MINIMUM MEASURED PERPENDICULAR TO THE COMPARTMENT DOOR IN ITS CLOSED POSITION. DOOR SHALL BE LOCATED IN FRONT PARTITION OR IN THE SIDE WALL OR PARTITION FARTHEST FROM THE WATER CLOSET. WHERE LOCATED IN THE FRONT PARTITION, THE DOOR OPENING SHALL BE 4 INCHES MAXIMUM FROM THE SIDE WALL OR PARTITION FARTHEST FROM THE WATER CLOSET. WHERE LOCATED IN THE SIDE WALL OR PARTITION, THE DOOR OPENING SHALL BE 4 INCHES MAXIMUM FROM THE FRONT PARTITION. THE DOOR SHALL BE SELF CLOSING. A DOOR PULL COMPLYING WITH SECTION 11B-404.2.7 SHALL BE PLACED ON BOTH SIDES OF THE DOOR NEAR THE LATCH. DOORS SHALL NOT SWING INTO THE CLEAR FLOOR SPACE OR CLEARANCE REQUIRED FOR ANY FIXTURES. DOORS MAY SWING INTO THAT PORTION OF MANEUVERING SPACE WHICH DOES NOT OVERLAP THE CLEARANCE REQUIRED AT A WATER CLOSET. (SECTION 11B-604.8.1.2)

40. WHEN LOCATED AT THE SIDE OF A TOILET COMPARTMENT, THE TOILET COMPARTMENT DOOR OPENING SHALL PROVIDE WIDTH OF 34 INCHES MINIMUM. (SECTION 11B-604.8.1.2 - SEE EXCEPTION)

41. AT LEAST ONE SIDE PARTITION SHALL PROVIDE A TOE CLEARANCE OF 9 INCHES MINIMUM ABOVE THE FINISH FLOOR AND 6 INCHES DEEP MINIMUM BEYOND THE COMPARTMENT-SIDE FACE OF THE PARTITION, EXCLUSIVE OF PARTITION SUPPORT MEMBERS. PARTITION COMPONENTS AT TOE CLEARANCES SHALL BE SMOOTH WITHOUT SHARP EDGES OR ABRASIVE SURFACES. COMPARTMENTS FOR CHILDRENS USE SHALL PROVIDE A TOE CLEARANCE OF 12 INCHES MINIMUM ABOVE THE FINISH FLOOR. (SECTION 11B-604.8.1.4)

42. GRAB BARS SHALL COMPLY WITH SECTION 11B-609 GRAB BARS. A SIDE-WALL GRAB BAR COMPLYING WITH SECTION 11B-604.5.1 SIDE WALL SHALL BE PROVIDED AND SHALL BE LOCATED ON THE WALL CLOSEST TO THE WATER HEATER. IN ADDITION, A REAR-WALL GRAB BARR COMPLYING WITH SECTION 11B-604.5.2 REAR WALL SHALL BE PROVIDED. WHERE SEPARATE GRAB BARS ARE REQUIRED ON ADJACENT WALLS AT A COMMON MOUNTING HEIGHT, AN L-SHAPED GRAB BAR MEETING THE DIMENSIONAL REQUIREMENTS OF SECTIONS 11B-604.5.1 SIDE WALL AND 11B-604.5.2 REAR WALL SHALL BE PERMITTED. (SECTION 11B-604.5.1)

43. AMBULATORY ACCESSIBLE COMPARTMENTS SHALL HAVE A DEPTH OF 60 INCHES MINIMUM AND A WIDTH OF 35 INCHES MINIMUM AND 37 INCHES MAXIMUM. (SECTION 11B-604.8.2.1)

44. WATER CLOSETS AND TOILET COMPARTMENTS FOR CHILDRENS USE SHALL COMPLY WITH SECTION 11B-604.9 WATER CLOSETS AND TOILET COMPARTMENTS FOR CHILDRENS USE. WHEN THE ENTRANCE IN SECTION 11B-604.9 IS USED, THE DIMENSIONED DIMENSIONS OF TABLE 11B-604.9 FOR A SINGLE AGE GROUP SHALL BE APPLIED CONSISTENTLY TO THE INSTALLATION OF A WATER CLOSET TO ALL ASSOCIATED COMPONENTS. (SECTION 11B-604.9)

45. URINALS SHALL BE THE STALL TYPE OR THE WALL-MOUNTING TYPE WITH THE RIM 17 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. URINALS SHALL BE 13 1/2 INCHES DEEP MINIMUM MEASURED FROM THE OUTER FACE OF THE URINAL RIM TO THE BACK OF THE FIXTURE. (SECTION 11B-605.2)

46. A CLEAR FLOOR SPACE OR GROUND SPACE COMPLYING WITH SECTION 11B-305 CLEAR FLOOR OR GROUND SPACE POSITIONED FOR FORWARD APPROACH SHALL BE PROVIDED. (SECTION 11B-605.3)

47. FLUSH CONTROLS SHALL BE HAND OPERATED OR AUTOMATIC. HAND OPERATED FLUSH CONTROLS SHALL COMPLY WITH SECTION 11B-309 OPERABLE PARTS EXCEPT THAT THE FLUSH CONTROL SHALL BE MOUNTED AT A MAXIMUM HEIGHT OF 44 INCHES ABOVE THE FINISH FLOOR. (SECTION 11B-605.4)

48. LAVATORIES AND SINKS SHALL COMPLY WITH SECTION 11B-806 LAVATORIES AND SINKS. (SECTION 11B-606.1)

49. FOR LAVATORIES AND SINKS, A CLEAR FLOOR SPACE COMPLYING WITH SECTION 11B-305 CLEAR FLOOR OR GROUND SURFACES, POSITIONED FOR A FORWARD APPROACH, AND KNEE AND TOE CLEARANCE COMPLYING WITH SECTION 11B-306 KNEE AND TOE CLEARANCE SHALL BE PROVIDED. (SECTION 11B-606.2)

50. LAVATORIES AND SINKS SHALL BE INSTALLED WITH THE FRONT OF THE HIGHER OF THE RIM OR COUNTER SURFACE 34 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND. (SECTION 11B-606.3)

SHOWER COMPARTMENTS

51. SHOWER COMPARTMENTS SHALL BE EITHER:

A. STANDARD ROLL-IN TYPE SHOWER COMPARTMENT: 30 INCHES WIDE MINIMUM BY 60 INCHES DEEP MINIMUM WITH CLEAR INSIDE DIMENSIONS MEASURED AT CENTER POINTS OF OPPOSING SIDES WITH A FULL OPENING WIDTH ON THE LONG SIDE. A 36 INCH WIDE MINIMUM BY 60 INCH LONG MINIMUM CLEARANCE SHALL BE PROVIDED ADJACENT TO THE OPEN FACE OF THE SHOWER COMPARTMENT. (SECTION 11B-608.2.2) OR

B. ALTERNATE ROLL-IN TYPE SHOWER COMPARTMENT: 36 INCHES WIDE AND 60 INCHES DEEP MINIMUM CLEAR INSIDE DIMENSIONS MEASURED AT CENTER POINTS OF OPPOSING SIDES. A 36 INCH WIDE MINIMUM ENTRY SHALL BE PROVIDED AT ONE END OF THE LONG SIDE OF THE COMPARTMENT. (SECTION 11B-608.2.3)

52. GRAB BARS WITH CIRCULAR CROSS SECTIONS IN TOILET FACILITIES AND BATHING FACILITIES SHALL HAVE AN OUTSIDE DIAMETER OF 1/4 INCHES MINIMUM AND 2 INCHES MAXIMUM. (SECTION 11B-609.2.1)

53. GRAB BARS WITH NON-CIRCULAR CROSS SECTIONS SHALL HAVE A CROSS-SECTION DIMENSION OF 2 INCHES MAXIMUM AND A PERIMETER DIMENSION OF 4 INCHES MINIMUM AND 4.8 INCHES MAXIMUM. (SECTION 11B-609.2.2)

54. SPACE BETWEEN THE WALLS AND THE GRAB BAR SHALL BE 1/2 INCHES. THE SPACE BETWEEN THE GRAB BAR AND PROJECTING OBJECTS BELOW AND AT THE END SHALL BE 1/2 INCHES MINIMUM. THE SPACE BETWEEN THE GRAB BARS AND PROJECTING OBJECTS ABOVE THE 12 INCHES MINIMUM. (SECTION 11B-609.3)

55. GRAB BARS SHALL BE INSTALLED IN A HORIZONTAL POSITION, 33 INCHES MINIMUM AND 36 INCHES MAXIMUM ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE, EXCEPT THAT AT WATER CLOSETS FOR CHILDRENS USE COMPLYING WITH SECTION 11B-604.9 WATER CLOSETS AND TOILET COMPARTMENTS FOR CHILDRENS USE, GRAB BARS SHALL BE INSTALLED IN A VERTICAL POSITION 18 INCHES MINIMUM AND 27 INCHES MAXIMUM ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE. THE HEIGHT OF THE REAR GRAB BAR ON THE BACK WALL OF A BATHTUB SHALL COMPLY WITH SECTION 11B-607.4. (SECTION 11B-609.4)

56. THE TOP OF BATHTUB SEATS SHALL BE 15 INCHES MINIMUM AND 19 INCHES MAXIMUM ABOVE THE FINISH FLOOR. THE LENGTH OF A REMOVABLE IN-TUB SEAT SHALL BE 15 INCHES MINIMUM AND 18 INCHES MAXIMUM. THE SEAT SHALL BE CAPABLE OF SECURE PLACEMENT. PERMANENT SEATS AT THE HEAD END OF THE BATHTUB SHALL BE 15 INCHES DEEP MINIMUM. SEATS SHALL EXTEND FROM THE BACK WALL TO OR BEYOND THE OUTER EDGE OF THE BATHTUB. (SECTION 11B-610.2)

57. SEAT IN A STANDARD ROLL-IN SHOWER COMPARTMENT SHALL BE A FOLDING TYPE. SEAT SHALL BE INSTALLED ON THE SIDE WALL ADJACENT TO THE CONTROLS, AND SHALL EXTEND FROM THE BACK WALL TO A POINT WITHIN 3 INCHES OF THE COMPARTMENT ENTRY. IN AN ALTERNATE ROLL-IN TYPE SHOWER COMPARTMENT SHALL BE A FOLDING TYPE. SEAT SHALL BE INSTALLED ON THE FRONT WALL OPPOSITE THE BACK WALL, AND SHALL EXTEND FROM THE ADJACENT SIDE WALL TO A POINT WITHIN 3 INCHES OF THE COMPARTMENT ENTRY. THE ADJACENT SIDE WALL SHALL BE 17 INCHES MINIMUM AND 19 INCHES MAXIMUM ABOVE THE BATHROOM FINISH FLOOR. WHEN FOLDED, THE SEAT SHALL EXTEND 6 INCHES MAXIMUM FROM THE MOUNTING WALL. SEATS SHALL COMPLY WITH SECTION 11B-610.3.1. OR 11B-610.3.2. (SECTION 11B-610.3)

F. COMMUNICATION ELEMENTS AND FEATURES

FIRE ALARM SYSTEMS

1. WHERE FIRE ALARM SYSTEMS AND CARBON MONOXIDE ALARM SYSTEMS PROVIDE AUDIBLE ALARM COVERAGE, ALARMS SHALL COMPLY WITH 11B-215 FIRE ALARM SYSTEMS. (SECTION 11B-215.1 - SEE EXCEPTION)

2. ALARMS IN PUBLIC USE AREAS AND COMMON USE AREAS SHALL COMPLY WITH CHAPTER 9, SECTION 907.5.2.3.1. (SECTION 11B-215.2)

3. WHERE EMPLOYEE WORK AREAS HAVE AUDIBLE ALARM COVERAGE, THE WIRING SYSTEM SHALL BE DESIGNED SO THAT VISIBLE ALARMS COMPLYING WITH CHAPTER 9, SECTION 907.5.2.3.1 EXCEPTION CAN BE INTEGRATED INTO THE ALARM SYSTEM. (SECTION 11B-215.3)

4. GUEST ROOMS REQUIRED TO COMPLY WITH 11B-224.4 SHALL PROVIDE FIRE ALARMS COMPLYING WITH CHAPTER 9, SECTION 907.5.2.3.2, AND CARBON MONOXIDE ALARMS, WHERE PROVIDED, COMPLYING WITH CHAPTER 4. (SECTION 11B-215.4)

5. WHERE PROVIDED IN RESIDENTIAL DWELLING UNITS REQUIRED TO COMPLY WITH 11B-809.5, FIRE ALARMS SHALL COMPLY WITH CHAPTER 9, SECTION 907.5.2.3.3 AND CARBON MONOXIDE ALARMS SHALL COMPLY WITH CHAPTER 4. (SECTION 11B-215.5)

6. FIRE ALARM SYSTEMS SHALL HAVE PERMANENTLY INSTALLED AUDIBLE AND VISIBLE ALARMS COMPLYING WITH NFPA 72 AND CHAPTER 9, SECTIONS 907.5.2.1 AND 907.5.2.3. (SECTION 11B-702.1)

SIGNS

7. NEW OR ALTERED SIGNS SHALL BE PROVIDED IN ACCORDANCE WITH SECTION 11B-216 AND SHALL COMPLY WITH SECTION 11B-703. THE ADDITION OF OR REPLACEMENT OF SIGNS SHALL NOT TRIGGER ANY ADDITIONAL PATH OF TRAVEL REQUIREMENTS. (SECTION 11B-216.1 - SEE EXCEPTION)

A. BUILDING DIRECTORIES, MENUS, SEAT AND ROW DESIGNATIONS IN ASSEMBLY AREAS, INCLUDING BUILDING ADDRESSES AND COMPANY NAMES AND LOGOS SHALL NOT BE REQUIRED TO COMPLY WITH SECTION 11B-216.

B. TEMPORARY, 7 DAYS OR LESS, SIGNS SHALL NOT BE REQUIRED TO COMPLY WITH SECTION 11B-216.

C. SIGNS AND IDENTIFICATION DEVICES SHALL BE FIELD INSPECTED AFTER INSTALLATION AND APPROVED BY THE ENFORCING AGENCY PRIOR TO THE ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY PER CHAPTER 1, DIVISION II, SECTION 111 OR FINAL APPROVAL WHERE NO CERTIFICATE OF OCCUPANCY IS ISSUED. THE INSPECTION SHALL INCLUDE, BUT NOT BE LIMITED TO, VERIFICATION THAT BRAILLE DOTS AND CELLS ARE PROPERLY SPACED AND THE SIZE, PROPORTION AND TYPE OF RAISED CHARACTERS ARE IN COMPLIANCE WITH THESE REGULATIONS. (SECTION 11B-703.1.1.2)

D. SIGNS IDENTIFYING THE TYPE OF ACCESS PROVIDED ON AMUSEMENT RIDES SHALL BE PROVIDED AT ENTRIES TO QUEUES AND WAITING LINES. IN ADDITION, WHERE ACCESSIBLE UNLOADED AREAS ALSO SERVE AS ACCESSIBLE LOAD AREAS, SIGNS INDICATING THE LOCATION OF THE ACCESSIBLE LOAD AND UNLOADED AREAS SHALL BE PROVIDED AT ENTRIES TO QUEUES AND WAITING LINES. SIGNS SHALL COMPLY WITH 11B-703.5 VISUAL CHARACTERS AND SHALL INCLUDE THE INTERNATIONAL SYMBOL OF ACCESSIBILITY COMPLYING WITH 11B-703.7.2.1. (SECTION 11B-216.12)

19. SIGNS SHALL COMPLY WITH 11B-703 SIGNS, WHERE BOTH VISUAL AND TACTILE CHARACTERS ARE REQUIRED. EITHER ONE SIGN WITH BOTH VISUAL AND TACTILE CHARACTERS, OR TWO SEPARATE SIGNS, ONE WITH VISUAL, AND ONE WITH TACTILE CHARACTERS, SHALL BE PROVIDED. (SECTION 11B-703.1)

A. SIGNS AS SPECIFIED IN SECTION 11B-703 SIGNS, OR IN OTHER SECTIONS OF THIS CODE, WHEN INCLUDED IN THE CONSTRUCTION OF NEW BUILDINGS OR FACILITIES, OR WHEN INCLUDED, ALTERED OR REPLACED DUE TO ADDITIONS, ALTERATIONS OR RENOVATIONS TO EXISTING BUILDINGS OR FACILITIES, AND WHEN A PERMIT IS REQUIRED, SHALL COMPLY WITH 11B-703.1.1.1 PLAN REVIEW AND 11B-703.1.1.2 INSPECTION. (SECTION 11B-703.1.1)

B. PLANS, SPECIFICATIONS OR OTHER INFORMATION INDICATING COMPLIANCE WITH THESE REGULATIONS SHALL BE SUBMITTED TO THE ENFORCING AGENCY FOR REVIEW AND APPROVAL. (SECTION 11B-703.1.1.1)

C. PICTOGRAMS SHALL HAVE A FIELD HEIGHT OF 6 INCHES MINIMUM. CHARACTERS AND BRAILLE SHALL NOT BE LOCATED IN THE PICTOGRAMS FIELD. (SECTION 11B-703.6.1)

D. PICTOGRAMS AND THEIR FIELD SHALL HAVE A NON-GLARE FINISH. PICTOGRAMS SHALL CONTRAST WITH THEIR FIELD WITH EITHER LIGHT PICTOGRAM ON A DARK FIELD OR A DARK PICTOGRAM ON A LIGHT FIELD. (SECTION 11B-703.6.2)

E. PICTOGRAMS SHALL HAVE TEXT DESCRIPTORS LOCATED DIRECTLY BELOW THE PICTOGRAMS FIELD. TEXT DESCRIPTORS SHALL COMPLY WITH 11B-703.5 RAISED CHARACTERS, 11B-703.3 BRAILLE AND 11B-703.4 INSTALLATION HEIGHT AND LOCATION. (SECTION 11B-703.6.3)

11. SPACING BETWEEN THE BASELINES OF SEPARATE LINES OF CHARACTERS WITHIN A MESSAGE SHALL BE 135 PERCENT MINIMUM AND 170 PERCENT MAXIMUM OF THE CHARACTER HEIGHT. (SECTION 11B-703.5.9)

J. TEXT SHALL BE IN A HORIZONTAL FORMAT. (SECTION 11B-703.5.10)

24. PICTOGRAMS SHALL COMPLY WITH THE FOLLOWING:

A. PICTOGRAMS SHALL HAVE A FIELD HEIGHT OF 6 INCHES MINIMUM. CHARACTERS AND BRAILLE SHALL NOT BE LOCATED IN THE PICTOGRAMS FIELD. (SECTION 11B-703.6.1)

B. PICTOGRAMS AND THEIR FIELD SHALL HAVE A NON-GLARE FINISH. PICTOGRAMS SHALL CONTRAST WITH THEIR FIELD WITH EITHER LIGHT PICTOGRAM ON A DARK FIELD OR A DARK PICTOGRAM ON A LIGHT FIELD. (SECTION 11B-703.6.2)

C. PICTOGRAMS SHALL HAVE TEXT DESCRIPTORS LOCATED DIRECTLY BELOW THE PICTOGRAMS FIELD. TEXT DESCRIPTORS SHALL COMPLY WITH 11B-703.5 RAISED CHARACTERS, 11B-703.3 BRAILLE AND 11B-703.4 INSTALLATION HEIGHT AND LOCATION. (SECTION 11B-703.6.3)

21. BRAILLE SHALL BE CONTRACTED (GRADE 2) AND SHALL COMPLY WITH 11B-703.3 BRAILLE AND 11B-703.4 INSTALLATION HEIGHT AND LOCATION. (SECTION 11B-703.3)

A. BRAILLE DOTS SHALL HAVE A DOMED OR ROUNDED SHAPE AND SHALL COMPLY WITH TABLE 11B-703.3.1. THE INDICATION OF AN UPPERCASE LETTER OR LETTER SHALL ONLY BE USED BEFORE THE FIRST WORD OF SENTENCES, PROPER NOUNS AND NAMES, INDIVIDUAL LETTERS OF THE ALPHABET, INITIALS, AND ACRONYMS. (SECTION 11B-703.3.1)

B. BRAILLE SHALL BE POSITIONED BELOW THE CORRESPONDING TEXT IN A HORIZONTAL FORMAT, FLUSH LEFT OR CENTERED. IF TEXT IS MULTI-LINED, BRAILLE SHALL BE PLACED BELOW THE ENTIRE TEXT. BRAILLE SHALL BE SEPARATED 3/8 INCH MINIMUM AND 1/2 INCH MAXIMUM FROM ANY OTHER TACTILE CHARACTERS AND 3/8 INCH MINIMUM FROM RAISED BORDERS AND DECORATIVE ELEMENTS. (SECTION 11B-703.3.2 - SEE EXCEPTION)

22. SIGNS THAT TACTILE CHARACTERS SHALL COMPLY WITH 11B-703.4 INSTALLATION HEIGHT AND LOCATION. (SECTION 11B-703.4)

A. TACTILE CHARACTERS ON SIGNS SHALL BE LOCATED 48 INCHES MINIMUM ABOVE THE FINISH FLOOR OR GROUND SURFACE, MEASURED FROM THE BASELINE OF THE LOWEST TACTILE CHARACTER BRAILLE CELLS AND 60 INCHES MAXIMUM ABOVE THE FINISH FLOOR OR GROUND SURFACE, MEASURED FROM THE BASELINE OF THE HIGHEST TACTILE CHARACTER LINE OF RAISED CHARACTERS. (SECTION 11B-703.4.1 - SEE EXCEPTION)

B. WHERE A TACTILE SIGN IS PROVIDED AT A DOOR, THE SIGN SHALL BE LOCATED ALONGSIDE THE DOOR AT THE LATCH SIDE. WHERE A TACTILE SIGN IS PROVIDED AT DOUBLE DOORS WITH ONE ACTIVE LEAF, THE SIGN SHALL BE LOCATED ON THE INACTIVE LEAF. WHERE A TACTILE SIGN IS PROVIDED AT DOUBLE DOORS WITH TWO ACTIVE LEAFS, THE SIGN SHALL BE LOCATED ON THE INACTIVE LEAF. WHERE THERE IS NO WALL SPACE AT THE LATCH SIDE OF A SINGLE DOOR OR AT THE RIGHT SIDE OF DOUBLE DOORS, SIGNS SHALL BE LOCATED ON THE NEAREST ADJACENT WALL. SIGNS CONTAINING TACTILE CHARACTERS SHALL BE LOCATED SO THAT A CLEAR FLOOR SPACE OF 18 INCHES MINIMUM BY 18 INCHES MINIMUM, CENTERED ON THE TACTILE CHARACTERS, IS PROVIDED BEYOND THE ARC OF ANY DOOR SWING BETWEEN THE CLOSED POSITION AND 45 DEGREE OPEN POSITION. WHERE PROVIDED, SIGNS IDENTIFYING PERMANENT ROOMS AND SPACES SHALL BE LOCATED AT THE ENTRANCE TO, AND OUTSIDE OF THE ROOM OR SPACE. WHERE PROVIDED, SIGNS IDENTIFYING EXITS SHALL BE LOCATED AT THE EXIT DOOR WHEN APPROACHED IN THE DIRECTION OF EGRESS TRAVEL. (SECTION 11B-703.4.2 - SEE EXCEPTION)

23. VISUAL CHARACTERS SHALL COMPLY WITH SECTION 11B-703.5. (SECTION 11B-703.5)

A. CHARACTERS AND THEIR BACKGROUND SHALL HAVE A NON-GLARE FINISH. CHARACTERS SHALL CONTRAST WITH THEIR BACKGROUND WITH EITHER LIGHT CHARACTERS ON A DARK BACKGROUND OR DARK CHARACTERS ON A LIGHT BACKGROUND. (SECTION 11B-703.5.1)

B. CHARACTERS SHALL BE UPPERCASE OR LOWERCASE OR A COMBINATION OF BOTH. (SECTION 11B-703.5.2)

C. CHARACTERS SHALL BE CONVENTIONAL IN FORM. CHARACTERS SHALL NOT BE ITALIC, OBLIQUE, SCRIPT, HIGHLY DECORATIVE, OR OF OTHER UNUSUAL FORMS. (SECTION 11B-703.5.3)

D. CHARACTERS SHALL BE SELECTED FROM FONTS WHERE THE WIDTH OF THE UPPERCASE "O" IS 80 PERCENT MINIMUM AND 110 PERCENT MAXIMUM OF THE HEIGHT OF THE UPPERCASE LETTER "I". (SECTION 11B-703.5.4)

58. THRESHOLDS IN ROLL-IN SHOWER COMPARTMENTS SHALL BE 1/2 INCH HIGH MAXIMUM IN ACCORDANCE WITH SECTION 11B-303. (SECTION 11B-608.7)

59. ENCLOSURES FOR SHOWER COMPARTMENTS SHALL NOT OBSTRUCT CONTROLS, FAUCETS, AND SHOWER SPRAY UNITS OR OBSTRUCT TRANSFER FROM WHEELCHAIRS ONTO SHOWER SEATS. (SECTION 11B-608.8)

60. FLOOR OR GROUND SURFACES OR SHOWERS SHALL COMPLY WITH SECTION 11B-302.1 FLOOR OR GROUND SURFACES GENERAL AND SHALL BE SLOPED AT 1/48 (2.08%) MAXIMUM IN ANY DIRECTION. WHERE DRAINS ARE PROVIDED, GRATE OPENINGS SHALL BE 1/2 INCH MAXIMUM AND FLUSH WITH THE FLOOR SURFACE. (SECTION 11B-608.9)

61. WHEN A SOAP DISH IS PROVIDED, IT SHALL BE LOCATED ON THE CONTROL WALL AT A MAXIMUM HEIGHT OF 40 INCHES ABOVE THE SHOWER FLOOR, AND WITHIN REACH LIMITS FROM THE SEAT. (SECTION 11B-608.10)

GRAB BARS

62. GRAB BARS WITH CIRCULAR CROSS SECTIONS IN TOILET FACILITIES AND BATHING FACILITIES SHALL HAVE AN OUTSIDE DIAMETER OF 1/4 INCHES MINIMUM AND 2 INCHES MAXIMUM. (SECTION 11B-609.2.1)

63. GRAB BARS WITH NON-CIRCULAR CROSS SECTIONS SHALL HAVE A CROSS-SECTION DIMENSION OF 2 INCHES MAXIMUM AND A PERIMETER DIMENSION OF 4 INCHES MINIMUM AND 4.8 INCHES MAXIMUM. (SECTION 11B-609.2.2)

64. SPACE BETWEEN THE WALLS AND THE GRAB BAR SHALL BE 1/2 INCHES. THE SPACE BETWEEN THE GRAB BAR AND PROJECTING OBJECTS BELOW AND AT THE END SHALL BE 1/2 INCHES MINIMUM. THE SPACE BETWEEN THE GRAB BARS AND PROJECTING OBJECTS ABOVE THE 12 INCHES MINIMUM. (SECTION 11B-609.3)

65. GRAB BARS SHALL BE INSTALLED IN A HORIZONTAL POSITION, 33 INCHES MINIMUM AND 36 INCHES MAXIMUM ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE, EXCEPT THAT AT WATER CLOSETS FOR CHILDRENS USE COMPLYING WITH SECTION 11B-604.9 WATER CLOSETS AND TOILET COMPARTMENTS FOR CHILDRENS USE, GRAB BARS SHALL BE INSTALLED IN A VERTICAL POSITION 18 INCHES MINIMUM AND 27 INCHES MAXIMUM ABOVE THE FINISH FLOOR MEASURED TO THE TOP OF THE GRIPPING SURFACE. THE HEIGHT OF THE REAR GRAB BAR ON THE BACK WALL OF A BATHTUB SHALL COMPLY WITH SECTION 11B-607.4. (SECTION 11B-609.4)

66. THE TOP OF BATHTUB SEATS SHALL BE 15 INCHES MINIMUM AND 19 INCHES MAXIMUM ABOVE THE FINISH FLOOR. THE LENGTH OF A REMOVABLE IN-TUB SEAT SHALL BE 15 INCHES MINIMUM AND 18 INCHES MAXIMUM. THE SEAT SHALL BE CAPABLE OF SECURE PLACEMENT. PERMANENT SEATS AT THE HEAD END OF THE BATHTUB SHALL BE 15 INCHES DEEP MINIMUM. SEATS SHALL EXTEND FROM THE BACK WALL TO OR BEYOND THE OUTER EDGE OF THE BATHTUB. (SECTION 11B-610.2)

67. SEAT IN A STANDARD ROLL-IN SHOWER COMPARTMENT SHALL BE A FOLDING TYPE. SEAT SHALL BE INSTALLED ON THE SIDE WALL ADJACENT TO THE CONTROLS, AND SHALL EXTEND FROM THE BACK WALL TO A POINT WITHIN 3 INCHES OF THE COMPARTMENT ENTRY. IN AN ALTERNATE ROLL-IN TYPE SHOWER COMPARTMENT SHALL BE A FOLDING TYPE. SEAT SHALL BE INSTALLED ON THE FRONT WALL OPPOSITE THE BACK WALL, AND SHALL EXTEND FROM THE ADJACENT SIDE WALL TO A POINT WITHIN 3 INCHES OF THE COMPARTMENT ENTRY. THE ADJACENT SIDE WALL SHALL BE 17 INCHES MINIMUM AND 19 INCHES MAXIMUM ABOVE THE BATHROOM FINISH FLOOR. WHEN FOLDED, THE SEAT SHALL EXTEND 6 INCHES MAXIMUM FROM THE MOUNTING WALL. SEATS SHALL COMPLY WITH SECTION 11B-610.3.1. OR 11B-610.3.2. (SECTION 11B-610.3)

F. COMMUNICATION ELEMENTS AND FEATURES

FIRE ALARM SYSTEMS

1. WHERE FIRE ALARM SYSTEMS AND CARBON MONOXIDE ALARM SYSTEMS PROVIDE AUDIBLE ALARM COVERAGE, ALARMS SHALL COMPLY WITH 11B-215 FIRE ALARM SYSTEMS. (SECTION 11B-215.1 - SEE EXCEPTION)

2. ALARMS IN PUBLIC USE AREAS AND COMMON USE AREAS SHALL COMPLY WITH CHAPTER 9, SECTION 907.5.2.3.1. (SECTION 11B-215.2)

3. WHERE EMPLOYEE WORK AREAS HAVE AUDIBLE ALARM COVERAGE, THE WIRING SYSTEM SHALL BE DESIGNED SO THAT VISIBLE ALARMS COMPLYING WITH CHAPTER 9, SECTION 907.5.2.3.1 EXCEPTION CAN BE INTEGRATED INTO THE ALARM SYSTEM. (SECTION 11B-215.3)

4. GUEST ROOMS REQUIRED TO COMPLY WITH 11B-224.4 SHALL PROVIDE FIRE ALARMS COMPLYING WITH CHAPTER 9, SECTION 907.5.2.3.2, AND CARBON MONOXIDE ALARMS, WHERE PROVIDED, COMPLYING WITH CHAPTER 4. (SECTION 11B-215.4)

5. WHERE PROVIDED IN RESIDENTIAL DWELLING UNITS REQUIRED TO COMPLY WITH 11B-809.5, FIRE ALARMS SHALL COMPLY WITH CHAPTER 9, SECTION 907.5.2.3.3 AND CARBON MONOXIDE ALARMS SHALL COMPLY WITH CHAPTER 4. (SECTION 11B-215.5)

6. FIRE ALARM SYSTEMS SHALL HAVE PERMANENTLY INSTALLED AUDIBLE AND VISIBLE ALARMS COMPLYING WITH NFPA 72 AND CHAPTER 9, SECTIONS 907.5.2.1 AND 907.5.2.3. (SECTION 11B-702.1)

SIGNS

7. NEW OR ALTERED SIGNS SHALL BE PROVIDED IN ACCORDANCE WITH SECTION 11B-216 AND SHALL COMPLY WITH SECTION 11B-703. THE ADDITION OF OR REPLACEMENT OF SIGNS SHALL NOT TRIGGER ANY ADDITIONAL PATH OF TRAVEL REQUIREMENTS. (SECTION 11B-216.1 - SEE EXCEPTION)

A. BUILDING DIRECTORIES, MENUS, SEAT AND ROW DESIGNATIONS IN ASSEMBLY AREAS, INCLUDING BUILDING ADDRESSES AND COMPANY NAMES AND LOGOS SHALL NOT BE REQUIRED TO COMPLY WITH SECTION 11B-216.

B. TEMPORARY, 7 DAYS OR LESS, SIGNS SHALL NOT BE REQUIRED TO COMPLY WITH SECTION 11B-216.

C. SIGNS AND IDENTIFICATION DEVICES SHALL BE FIELD INSPECTED AFTER INSTALLATION AND APPROVED BY THE ENFORCING AGENCY PRIOR TO THE ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY PER CHAPTER