


- SHEET NOTES**
- DOOR NOTES
 - 1. CONTRACTOR SHALL COORDINATE ALL DOOR FRAME THROATS WITH STUD WIDTHS AND THICKNESSES OF GYPSUM BOARD FOR EACH WALL ASSEMBLY WHERE FRAME OCCURS. NOT EVERY CONDITION IS DETAILED, THOUGH CONSTRUCT ALL SIMILARLY. PROVIDE TWO STUDS AT EACH DOOR JAMB. FASTEN BOTH STUDS TOGETHER 16" O.C. TO UNITIZE MEMBERS. SEE A802/10.
 - 3. FOR DOOR FRAME JAMB ANCHORS, SEE SPECIFICATIONS AND A802/11.
 - 4. FLASH EXTERIOR DOORS PER MANUFACTURER'S RECOMMENDATIONS. FLASH WITH PRODUCT RECOMMENDED BY FLUID-APPLIED AIR AND WATER BARRIER MANUFACTURER. COORDINATE COMPATIBILITY WITH EIFS INSTALLER AND STRICTLY FOLLOW EIFS MANUFACTURER'S DRAINAGE SYSTEM DETAILS.
 - 5. INSTALL FLUID APPLIED AIR AND WATER BARRIER, FLASHINGS, TAPES AND WEEPS TO CONTINUALLY SHED WATER DOWN, OVER AND OUT OF WALL CAVITIES. MINIMIZE VERTICAL SEAMS AND OVERLAP FLASHINGS 16" MINIMUM WHERE VERTICAL SEAMS MUST OCCUR.
 - 6. ALL STOREFRONTS SHALL HAVE THERMAL-BREAK FRAMES.
 - 7. ALL THRESHOLDS AND FLOORING EDGE TRIM SHALL BE WHEELCHAIR ACCESSIBLE. SEE A855/05.
 - 8. WEATHERSTRIP ALL EXTERIOR DOOR/FRAMES AT HEAD, JAMB AND SILL.
- WINDOW NOTES
- 1. COORDINATE WINDOW ROUGH OPENINGS WITH WINDOW MANUFACTURER.
 - 2. PROVIDE TWO STUDS AT EACH WINDOW JAMB. FASTEN BOTH STUDS TOGETHER 16" O.C. TO UNITIZE MEMBERS.
 - 3. FLASH WINDOWS AND SEAL FASTENER FINN PER MANUFACTURER'S RECOMMENDATIONS. FLASH WITH DUPONT STRAIGHTFLASH OR FLEXWRAP FLASHING SYSTEMS. COORDINATE COMPATIBILITY WITH EIFS INSTALLER AND STRICTLY FOLLOW EIFS MANUFACTURER'S DRAINAGE SYSTEM DETAILS.
 - 4. INSTALL FLUID APPLIED AIR AND WATER BARRIER, FLASHINGS, TAPES AND WEEPS TO CONTINUALLY SHED WATER DOWN, OVER AND OUT OF WALL CAVITIES. MINIMIZE VERTICAL SEAMS AND OVERLAP FLASHINGS 16" MINIMUM WHERE VERTICAL SEAMS MUST OCCUR.
 - 5. ALL ALUMINUM WINDOWS AND STOREFRONT SHALL HAVE THERMAL-BREAK FRAMES.

HAMPTON INN
NEW HOTEL
ASHLAND CITY, TENNESSEE
WWW.DAVIDRCARTER.NET
DAVID R. CARTER AND ASSOCIATES



ISSUE DATE 05-30-19
REVISION LOG



DOOR AND WINDOW DETAILS- EXTERIOR A802

30 x 42