



Order Plans Online.com

1 LIGHTING - FIRST FLOOR PLAN
SCALE: 1/8" = 1'-0"

LOW LEVEL EXIT LIGHTING
1. THE CONTRACTOR SHALL PROVIDE AND INSTALL AN ADDITIONAL EXIT SIGN PER IBC 1013.2 WHERE EXIT SIGNAGE IS INDICATED. BOTTOM OF SIGN SHALL BE NOT MORE THAN 17" AND NOT MORE THAN 12" FROM THE FLOOR. SIGN SHALL BE FLUSH MOUNTED TO DOOR OR WALL. WHERE MOUNTED ON WALL, SIGN SHALL BE MOUNTED WITH IN 4" OF DOOR FRAME ON LATCH SIDE.

GENERAL NOTES THIS SHEET
1. EMERGENCY EGRESS FIXTURES SHALL BE CONNECTED TO LOCAL CIRCUIT SERVING RESPECTIVE AREA AND AHEAD OF ALL CONTROLS.
2. JUNCTION BOXES SHALL BE FIELD LOCATED. THE CONTRACTOR SHALL COORDINATE ANY ACCESS PANELS REQUIRED FOR JUNCTION BOX ACCESS WITH CEILING VENDOR PRIOR TO ANY ROUGH IN WORK.

KEYED NOTES THIS SHEET
1. LUTRON GRAPHIC EYE CONTROL STATION. PROVIDE AND INSTALL ALL CABLING, CONTROLS, & PANEL.
2. OCCUPANCY SENSOR SHALL BE SET TO 30 MINUTE TIME OUT UNLESS DIRECTED OTHERWISE BY OWNER OR OPERATIONS.
3. LIGHTING SHALL NOT SHUT DOWN THIS ROOM. LIGHTING SHALL REDUCE TO 50% TO ACHIEVE CODE WHEN NOT IN USE. HOWEVER LIGHTING MUST REMAIN ON.
4. SEE SWITCHING DETAIL THIS SHEET. FIXTURE SHALL HAVE REMOTE TEST SWITCH ACCESSIBLE FOR THE INSPECTOR TO TEST.
5. PROVIDE AUTOMATIC DIMMING OCCUPANCY SENSOR TO 50%.