



- SHEET KEY NOTES**
- (QTY. OF 6) 20A 120VAC CIRCUITS ON QUAD RECEPTACLES MOUNTED IN BACK PLANE OF EQUIPMENT RACK BY E.C.
  - (QTY. OF 2) 20A 120VAC CIRCUITS ON QUAD RECEPTACLES MOUNTED IN BACK PLANE OF EQUIPMENT RACK BY E.C.
  - (QTY. OF 1) 20A 120VAC CIRCUIT ON DUPLEX RECEPTACLE MOUNTED ON WALL XX' A.F.F. BY E.C.
  - (QTY. OF 1) 20A 120VAC CIRCUIT ON DUPLEX RECEPTACLE MOUNTED ON WALL 18" A.F.F. BY E.C.
  - (QTY. OF 1) 20A 120VAC CIRCUIT ON DUPLEX RECEPTACLE MOUNTED ON WALL XX' A.F.F. BY E.C.
  - (QTY. OF 1) 20A 120VAC CIRCUIT ON QUAD RECEPTACLE MOUNTED A.F.C. BY E.C.
  - (QTY. OF 1) 20A 120VAC CIRCUIT ON DUPLEX RECEPTACLE MOUNTED IN FLOOR BOX BY E.C.

Order Plans @ [www.LDILine.com](http://www.LDILine.com)

www.LDILine.com

1 FIRST FLOOR - AV INFRASTRUCTURE FLOOR PLAN  
1/8" = 1'-0"

2 SECOND FLOOR - AV INFRASTRUCTURE FLOOR PLAN  
1/8" = 1'-0"

NOT RELEASED FOR CONSTRUCTION  
FACILITY CODE: 625-0312

JOB NAME: BEACH HIGH SCHOOL AUDITORIUM  
3001 Hopkins Street  
Savannah, Georgia 31405  
Chatham County Public Schools System

SHEET NAME: AV INFRASTRUCTURE FP

J. W. ROBINSON & ASSOCIATES, INC.  
ARCHITECTS • INTERIOR DESIGNERS • URBAN PLANNERS •  
1020 RALPH DAVID ABERNATHY BLVD., S.W., ATLANTA, GEORGIA 30310  
PHONE: (404) 753-4129 FAX: (404) 753-4435



In Association With  
**COMMERCIAL KOLMAN SMITH ARCHITECTS**  
301 W. Broughton St. #301  
Savannah, GA 30401  
Ph: 912-232-5561

DATE	BY	REVISIONS
SEPT. 4, 2018	EAH	100% SCHEMATIC DESIGN
OCT. 29, 2018	EAH	100% DESIGN DEVELOPMENT
APRIL 5, 2019	EAH	80% CONSTRUCTION DOCS
MAY 15, 2019	EAH	100% CONSTRUCTION DOCS

JOB NO. 201801

SHEET NUMBER  
EPS-1.1