

1315 Peachtree St NE
Atlanta, GA 30309
404.873.2300
404.952.5523
www.perkinswill.com

CONSULTANTS

CIVIL
Breedlove Land Planning
15 Simpson St NW, Atlanta, GA 30309

STRUCTURAL
Uzun-Caspe
1220 Peachtree St NE, Suite 2500, Atlanta, GA 30309

MEP
Matheson Ball & Associates
11285 Elkins Rd., Suite F3, Roswell, GA 30076

LANDSCAPING
Perkins+Will
1315 Peachtree St NE, Atlanta, GA 30309

KITCHEN
Camacho
3103 Medlock Bridge Road, Norcross, GA 30071

KIPP Metro Atlanta Schools 1448
Maynard Road, NW Atlanta, GA 30331

FACILITY
CONTRACTOR




PROJECT

**KIPP ATLANTA
COLLEGIATE - Addition
and Renovations**

RELEASED FOR CONSTRUCTION 06/07/2019

KEYPLAN



ISSUE CHART

DATE	ISSUE	BY

**FLOOR PLAN- FIRST
FLOOR- PART C**

SHEET NUMBER

M11-01C

Copyright © 2018 Perkins+Will

- KEYNOTES (APPLIES TO THIS SHEET ONLY):**
1. NEW SUPPLY AIR DISTRIBUTION DEVICE AND NEW FLEX DUCT SHALL BE INSTALLED IN SAME LOCATION AS EXISTING AIR DISTRIBUTION DEVICE. CONNECT NEW FLEX DUCT TO EXISTING BRANCH DUCT. SEAL AND INSULATE CONNECTION. FIELD VERIFY EXACT LOCATION. (TYPICAL)
 2. NEW RETURN AIR DISTRIBUTION DEVICE SHALL BE INSTALLED IN SAME LOCATION AS EXISTING RETURN AIR DISTRIBUTION DEVICE. WHERE EXISTING RETURN IS CONNECTED TO EXISTING DUCT SYSTEM, CONNECT NEW GRILLE TO EXISTING DUCT. INSULATE AND SEAL CONNECTION. WHERE EXISTING RETURN IS OPEN TO PLENUM, PROVIDE NEW RETURN AIR SOUND BOOT PER DETAIL 7M31-01. (TYPICAL)
 3. EXISTING UNIT SHALL REMAIN FOR REUSE. BALANCE UNIT TO CFMs SHOWN. MAINTAIN CONTROLS. CONTRACTOR SHALL EXAMINE UNIT FOR ANY DAMAGE TO UNIT OR ASSOCIATED PIPING, DUCT, DRAIN PAN, INSULATION, ETC. DAMAGE SHALL BE REPAIRED PRIOR TO UNIT BEING REUSED. (TYPICAL)
 4. EXISTING CHILLER SHALL BE RELOCATED TO HERE AND LOCATED ON NEW CONCRETE PAD. EXISTING CONTROLS SHALL BE MAINTAINED. NEW CHILLER PIPING SHALL BE INSTALLED AS REQUIRED TO CONNECT TO EXISTING UNDERGROUND PIPING. INSULATE AND SEAL CONNECTION. NEW RETURN GRILLE IN SAME LOCATION AS EXISTING GRILLE. MOUNT AT SAME ELEVATION AND CONNECT TO EXISTING DUCT. CONTRACTOR SHALL FIELD VERIFY SIZE OF EXISTING GRILLE AND INSTALL NEW GRILLE OF SAME SIZE.
 - 5.

Order Plans @ www.LDILine.com

1 FLOOR PLAN - FIRST FLOOR - PART C
3/32" = 1'-0"