



Geary Engineering
 5502 Walsh Lane Suite 102
 Rogers, AR. 72758
 Phone: (479) 464-8006
 E-mail: tgeary@gearyeng.com
 Web: www.gearyeng.com

THESE DRAWINGS ARE PRELIMINARY IN NATURE AND INTENDED FOR REVIEW AND PERMITTING. DRAWINGS ARE NOT TO BE USED FOR CONSTRUCTION WITHOUT ARCHITECT'S AND ENGINEER'S SIGNATURE AND THEIR DATE OF ISSUE FOR CONSTRUCTION.



9726 E. 42nd St. SUITE 153
 TULSA, OK 74146
 918.640.6800
 JHNSANFORD@AOL.COM

Copyright 2019 John Sanford

JOHN SANFORD,
 AIA, NCARB
 TN LICENSE #106056

NOT VALID FOR CONSTRUCTION UNLESS SIGNED IN THIS BLOCK

PROPOSED HOLIDAY INN LI9383
 215 CRACKER BARREL DR., CLARKSVILLE, TN
 MONTGOMERY COUNTY, TENNESSEE

PERMIT NO: _____

GE18002

No.	Description	Date

SHEET

E601
 Power Floor Plan -
 Enlarged Kitchen

WWW.LDILine.com

ANSUL ALARM NOTE:
 A MANUALLY ACCESSIBLE MEANS FOR MANUAL ACTIVATION SHALL BE LOCATED BETWEEN 42IN AND 60IN AFF AND CLEARLY IDENTIFY THE HAZARD PROTECTED. THE AUTOMATIC AND MANUAL MEANS OF SYSTEM ACTIVATION EXTERNAL TO THE CONTROL HEAD OR RELEASING DEVICE SHALL BE SEPARATE AND INDEPENDENT OF EACH OTHER SO THE FAILURE OF ONE WILL NOT IMPAIR THE OPERATION OF THE OTHER. UPON ACTIVATION OF ANY ANSUL SYSTEM, THE FIRE ALARM SIGNALING SYSTEM SHALL BE ACTIVATED AND ALL SOURCES OF ELECTRICAL POWER THAT PRODUCES HEAT TO ALL EQUIPMENT REQUIRING PROTECTION BY THAT SYSTEM SHALL AUTOMATICALLY SHUT OFF AND CLOSE THE SOLENOID VALVE ON THE SUPPLYING GAS LINE.

