

- GENERAL POWER PLAN NOTES:
1. VERIFY AND COORDINATE EXACT ELECTRICAL REQUIREMENTS OF ALL EQUIPMENT WITH MANUFACTURER'S RECOMMENDATIONS PRIOR TO INSTALLATION OF EQUIPMENT. MODIFY LAYOUT AS REQUIRED PER MANUFACTURER'S SPACE REQUIREMENTS.
 2. REFER TO ARCHITECTURAL ELEVATIONS AND CASEWORK DRAWINGS FOR FINAL MOUNTING HEIGHTS AND INSTALLATION REQUIREMENTS OF ALL DEVICES. UNLESS NOTED OTHERWISE, ARCHITECTURAL ELEVATIONS SHALL DICTATE MOUNTING HEIGHTS OF ALL FIXTURES AND DEVICES.
 3. COORDINATE FINAL LOCATIONS OF ALL DIVISION 21 EQUIPMENT IN FIELD WITH DIVISION 23 EQUIPMENT. FIELD LOCATIONS SHALL DICTATE.
 4. COORDINATE MOUNTING HEIGHTS AND LOCATIONS OF ALL DEVICES WITH ARCHITECTURAL ELEVATIONS AND CASEWORK.
 5. CRITICAL BRANCH WIRING FROM ANY PANEL DOWNSTREAM OF AUTOMATIC TRANSFER SWITCHES ATS-27 AND ATS-22 SHALL BE SEPARATE RACEWAY. CONTRACTOR SHALL MAINTAIN SEPARATION OF THESE FROM THESE TRANSFER SWITCHES AND THEIR DISTRIBUTION ALL THE WAY TO THE LOADS.




Project
THE CENTER FOR ADVANCED SURGICAL SERVICES (CASS)
88 JESSE HILL DRIVE
ATLANTA, GA 30303

Prepared For
GRADY HEALTH SYSTEM
80 JESSE HILL DR. SE
ATLANTA, GA 30303



Hillmuth, Obata & Kassabaum, Inc.
191 Peachtree Street, NE, Suite 2250
Atlanta, GA 30303 USA
+1 404 439 9000 F +1 404 439 9001

All reproduction & intellectual property rights reserved © 2019
in Association with
TLC ENGINEERING
255 S. Orange Avenue
Suite 1900
Orlando, FL 32801
P: 407.841.0390
COA PE# 022880
www.tlc-engineering.com
TLC No. 118548
T: 200.286.162200, 208.94.219



Professional Seal
Emory Neal Boothe, P.E.
Georgia License #PE039005

NOT FOR CONSTRUCTION

| No. | Description | Date |
|-----|-------------|------------|
| 1 | ED - GMP | 2019-07-03 |

Project No: 18.16013.00
Sheet Title
LEVEL 8 FLOOR PLAN - EAST - POWER

Original is 30 x 42. Do not scale contents of this drawing
Sheet Number

E208B

1 FLOOR PLAN - LEVEL 8 - EAST - POWER
1/8" = 1'-0"