

- GENERAL FIRE ALARM PLAN NOTES:
- REFER TO FIRE ALARM SYMBOL LEGEND FOR DETAILED REQUIREMENTS FOR ALL FIRE ALARM DEVICE INSTALLATIONS.
 - REFER TO ARCHITECTURAL ELEVATIONS FOR FINAL MOUNTING HEIGHTS OF ALL DEVICES. UNLESS NOTED OTHERWISE, ARCHITECTURAL ELEVATIONS SHALL Dictate MOUNTING HEIGHTS OF ALL DEVICES.
 - VERIFY AND COORDINATE EXACT ELECTRICAL REQUIREMENTS OF ALL EQUIPMENT WITH MANUFACTURER'S RECOMMENDATIONS PRIOR TO INSTALLATION OF EQUIPMENT.
 - FIRE ALARM CONTRACTOR SHALL FULLY TEST ALL INITIATING DEVICES WITHIN THE SMOKE COMPARTMENT TO ENSURE THAT ALL DEVICES ARE CORRECTLY INITIATING THE CORRECT SMOKE COMPARTMENT IDENTIFICATION, AS SHOWN ON THE LIFE SAFETY PLANS. CONTRACTOR SHALL CORRECT ANY AND ALL DISCREPANCIES FOUND DURING SAID TESTING PROCEDURE.
 - REFER TO THE FIRE ALARM SYSTEM RISER DIAGRAMS AND SCHEDULES FOR ADDITIONAL INFORMATION.
 - UNLESS NOTED OTHERWISE, EACH SMOKE COMPARTMENT SHALL BE AS A FIRE EVACUATION ZONE.
 - REFER TO MECHANICAL DRAWINGS FOR QUANTITIES AND LOCATIONS OF ALL FLOW AND RETURN AIR HANDLING UNITS. THESE DEVICES SHALL BE PROVIDED BY THE FIRE ALARM CONTRACTOR UNLESS OTHERWISE NOTED.
 - REFER TO MECHANICAL DRAWINGS FOR QUANTITIES AND LOCATIONS OF ALL FLOW AND RETURN AIR HANDLING UNITS. THESE DEVICES SHALL BE PROVIDED BY THE FIRE ALARM CONTRACTOR UNLESS OTHERWISE NOTED.

KEY NOTES

- CONTRACTOR SHALL PROVIDE A 2ND FIRE ALARM ANNUNCIATOR PANEL IN THE MAIN HOSPITALS DESIGNATED 24-HOUR LOCATION. COORDINATE EXACT LOCATION WITH OWNER.



Project
**THE CENTER FOR
 ADVANCED SURGICAL
 SERVICES (CASS)**
 88 JESSE HILL DRIVE
 ATLANTA, GA 30303


Prepared For
GRADY HEALTH SYSTEM
 80 JESSE HILL DR. SE
 ATLANTA, GA 30303



Heilmuth, Obata & Kassabaum, Inc.
 191 Peachtree Street, NE, Suite 2250
 Atlanta, GA 30303 USA
 T+1 404 439 9000 F+1 404 439 9001

All reproduction & intellectual property rights reserved © 2019
 In Association with

TLC ENGINEERING
 258 S. Orange Avenue
 Suite 1800
 Orlando, FL 32801
 P: 407.841.0392
 F: 407.841.0392
 CDA: PE#1022860
 www.tlc-engineering.com
 TLC No. 118548
 TPN005, L167206, C265A119



Professional Seal
 Emory Neal Boothe, P.E.
 Georgia License #PE039005

**NOT FOR
 CONSTRUCTION**

No.	Description	Date
1	ED - GMP	2019-07-03

Project No: 18.16013.00
 Sheet Title
**LEVEL 5 FLOOR PLAN -
 EAST - FIRE ALARM**

Original is 20 x 42. Do not scale contents of this drawing.
 Sheet Number

E405B

Order Plans @

WWW.LDILine.com

1 FLOOR PLAN - LEVEL 5 - EAST - FIRE ALARM
 1/8" = 1'-0"