


- GENERAL FIRE ALARM PLAN NOTES:
- REFER TO FIRE ALARM SYMBOL LEGEND FOR DETAILED REQUIREMENTS FOR ALL FIRE ALARM DEVICE INSTALLATIONS.
 - REFER TO ARCHITECTURAL ELEVATIONS FOR FINAL MOUNTING HEIGHTS OF ALL DEVICES. UNLESS NOTED OTHERWISE, ARCHITECTURAL ELEVATIONS SHALL Dictate MOUNTING HEIGHTS OF ALL DEVICES.
 - VERIFY AND COORDINATE EXISTING ELECTRICAL REQUIREMENTS OF ALL EQUIPMENT WITH MANUFACTURER'S RECOMMENDATIONS PRIOR TO INSTALLATION OF EQUIPMENT.
 - FIRE ALARM CONTRACTOR SHALL FULLY TEST ALL INITIATING DEVICES WITHIN THE SMOKE COMPARTMENT TO ENSURE THAT ALL DEVICES ARE CORRECTLY INITIATING THE CORRECT SMOKE COMPARTMENT IDENTIFICATION, AS SHOWN ON THE LIFE SAFETY PLANS. CONTRACTOR SHALL CORRECT ANY AND ALL DISCREPANCIES FOUND DURING SAID TESTING PROCESSES.
 - REFER TO THE FIRE ALARM SYSTEM RISER DIAGRAMS FOR ADDITIONAL INFORMATION.
 - UNLESS NOTED OTHERWISE, EACH SMOKE COMPARTMENT SHALL BE AS A FIRE EVACUATION ZONE.
 - REFER TO MECHANICAL DRAWINGS FOR QUANTITIES AND LOCATIONS OF ALL FLOW AND TEST DEVICES. THESE DEVICES SHALL BE PROVIDED BY THE FIRE ALARM CONTRACTOR, REGARDLESS OF IF THEY ARE SHOWN ON THE FIRE ALARM DRAWING OR NOT.

KEY NOTES



Project
**THE CENTER FOR
 ADVANCED SURGICAL
 SERVICES (CASS)**
 88 JESSE HILL DRIVE
 ATLANTA, GA 30303

Prepared For
GRADY HEALTH SYSTEM
 80 JESSE HILL DR. SE
 ATLANTA, GA 30303




Hellmuth, Obata & Kassabaum, Inc.
 191 Peachtree Street, NE, Suite 2250
 Atlanta, GA 30303 USA
 T+1 404 439 9000 F+1 404 439 9001

All reproduction & intellectual property rights reserved © 2019
 in Association with

255 S. Orange Avenue
 Suite 1500
 Orlando, FL 32801
 P 407.841.0050

COA PE022860
 www.tlc-engineers.com
 TLC No. 118548
 TPN005, L167206, C262418



Professional Seal
 Emory Neal Boothe, P.E.
 Georgia License #PE039005

**NOT FOR
 CONSTRUCTION**

| No. | Description | Date |
|-----|-------------|------------|
| 1 | ED - GMP | 2019-07-03 |

Project No: 18.16013.00
 Sheet Title
**LEVEL 6 FLOOR PLAN -
 EAST - FIRE ALARM**

Original is 20 x 42. Do not scale contents of this drawing.
 Sheet Number
E406B

Order Plans @

1 FLOOR PLAN - LEVEL 6 - EAST - FIRE ALARM
 1/8" = 1'-0"