

TECHNOLOGY SYSTEMS SYMBOL LEGEND

GENERAL NOTES

| BASIC MATERIALS | |
|-----------------|---|
| SYMBOL | DESCRIPTION |
| | JUNCTION BOX |
| | FLOOR MOUNTED JUNCTION BOX |
| | PEDESTAL MOUNTED JUNCTION BOX |
| | INGROUND PULL BOX |
| | EXISTING CONDUIT ABOVE HARD CEILING BETWEEN CEILING BOXES |
| | CONDUIT CONCEALED ABOVE CEILING OR IN WALL |
| | CONDUIT CONCEALED IN SLAB, UNDERGROUND OR UNDER FLOOR |
| | CONDUIT EXPOSED |
| | CONDUIT TURNING UP |
| | CONDUIT TURNING DOWN |
| | CONDUIT STUB |
| | CONDUIT CONTINUED |
| | FLEXIBLE CONDUIT |
| | GROUND OR GROUND ROD AS NOTED |
| | SLEEVE TURNING UP |
| | SLEEVE TURNING DOWN |
| | EXISTING TO BE REMOVED |
| | EXISTING TO REMAIN |
| | EXISTING AFFECTED BY THIS PROJECT |
| | CABLE TRAY FOR HORIZONTAL CABLING |
| | PENETRATION CONDUIT SLEEVE WITH BUSHINGS |

| BROADBAND TELEVISION SYSTEM | |
|-----------------------------|---------------------|
| SYMBOL | DESCRIPTION |
| | 2 PORT TAP |
| | 4 PORT TAP |
| | 6 PORT TAP |
| | 8 PORT TAP |
| | TERMINATION TAP |
| | 2 WAY SPLITTER |
| | 3 WAY SPLITTER |
| | 4 WAY SPLITTER |
| | AMPLIFIER |
| | DIRECTIONAL COUPLER |

| AUDIO/VIDEO SYSTEM | |
|--------------------|--|
| SYMBOL | DESCRIPTION |
| | OVERHEAD PROJECTOR WITH SCREEN, SCREEN SIZE SHOWN ON PLANS |
| | FLAT PANEL DISPLAY - XX DENOTES THE SCREEN SIZE |
| | OVERHEAD PROJECTOR - CEILING MOUNTED |
| | X DENOTES TYPE CEILING MOUNTED DOCUMENT CAMERA |
| | AUDIO/VIDEO CAMERA |
| | PULL-DOWN PROJECTION SCREEN, SIZE SPECIFIED ON PLANS |
| | MOTORIZED PROJECTION SCREEN, SIZE SPECIFIED ON PLANS |
| | OVERHEAD PROJECTION SCREEN MOTOR |
| | WALL SWITCH FOR MOTORIZED SCREEN X = A, B, C - INTERFACE TYPE |
| | AUDIO VISUAL OUTLET - WALL MOUNTED WITH ADJACENT DEDICATED DUPLEX RECEPTACLE BY DIVISION 27 |
| | TELEVISION OUTLET - WALL MOUNTED AT 7" ABOVE FINISHED FLOOR, ADJACENT DUPLEX RECEPTACLE BY ELECTRICAL INSTALLER (1) GAVY-1" TYPE CONNECTOR (2) DATA "RJ45" CONNECTOR |
| | CEILING MOUNTED SPEAKER x DENOTES TYPE y DENOTES ZONE |
| | WALL MOUNTED SPEAKER x DENOTES TYPE y DENOTES ZONE NO ZONE DENOTES LOCAL AUDIO/VIDEO SYSTEM |
| | VOLUME CONTROL, PROVIDE 3/4" CONDUIT STUB UP ABOVE CEILING AND SINGLE STANDARD ELECTRICAL BOX AT 52" ABOVE FINISHED FLOOR |
| | SEE PODIUM DETAILS |

| INTERCOM & PAGING SYSTEM | |
|--------------------------|---|
| SYMBOL | DESCRIPTION |
| | ADMINISTRATIVE PHONE |
| | HANDSET |
| | CALL STATION |
| | CEILING MOUNTED SPEAKER x DENOTES TYPE y DENOTES ZONE |
| | WALL MOUNTED SPEAKER x DENOTES TYPE y DENOTES ZONE NO ZONE DENOTES LOCAL AUDIO/VIDEO SYSTEM |

| VOICE & DATA SYSTEM | |
|---------------------|---|
| SYMBOL | DESCRIPTION |
| | MOUNTING 2' ABOVE COUNTER OR BACK SPLASH |
| | X = MOUNTING (FLUSH, SURFACE, MODULAR FURNITURE ADAPTER (POLE, RACEWAY), (DOUBLE GANG FLUSH, IPD) PEDESTAL |
| | N = # OF VOICE JACKS |
| | N = # OF DATA JACKS |
| | N = # OF COAX CONNECTORS "F" TYPE CONNECTOR |
| | N = # OF FIBER OPTIC CONNECTORS SC, ST, LC |
| | COMMUNICATIONS "INFORMATION OUTLET" MOUNTED AT RECEPTACLE HEIGHT UNLESS OTHERWISE NOTED, MODULE AND FACEPLATE DESCRIPTIONS ON DETAIL SHEETS |
| | 1. VOICE JACKS EACH RJ45 CAT6 JACK FOR VOICE SHALL BE CONNECTED TO A DEDICATED UTP 4PR CAT6 CABLE. |
| | 2. DATA JACKS EACH RJ45 CAT6 JACK FOR DATA SHALL BE CONNECTED TO A DEDICATED UTP 4PR CAT6 CABLE. |
| | WALL TELEPHONE OUTLET FOR HOUSE PHONE MOUNTED AT 52" ABOVE FINISHED FLOOR TO TOP |
| | WALL TELEPHONE OUTLET FOR PAY PHONE MOUNTED AT 48" ABOVE FINISHED FLOOR |
| | WALL TELEPHONE OUTLET FOR PAY PHONE, ADA COMPLIANT 42" ABOVE FINISHED FLOOR |
| | WIRELESS ACCESS POINT OUTLET, ACTUAL QUANTITY AND LOCATIONS OF WIRELESS ACCESS POINTS BASED ON SIGNAL SURVEY BY WLAN VENDOR. PROVIDE CAT 6A CABLE X = MOUNTING (FLUSH, SURFACE), (CEILING) N = # OF DATA JACKS, MAXIMUM CABLE LENGTH 262 FT |
| | WALL TELEPHONE OUTLET FOR TELEPHONE IN ELEVATOR MACHINE ROOM, (SURFACE MOUNTED AT 52" ABOVE FINISHED FLOOR) |
| | DUAL DATA LOCATION DEDICATED TO BAS EQUIPMENT, COORDINATE EXACT BAS LOCATIONS PRIOR TO INSTALLATION |
| | COMBINED VOICE/DATA, AUDIO/VIDEO AND POWER OUTLETS IN FLOOR BOX. POWER RECEPTACLE IS SHOWN FOR REFERENCE ONLY. CONDUIT BOX AND POWER RECEPTACLE PROVIDED BY DIVISION 27. X = A, B, C - FLOOR BOX TYPE. NS ARE DESCRIBED ABOVE. |
| | TABLE TOP POP-UP WITH VOICE/DATA, AUDIO/VIDEO AND POWER INTERFACE. X = A, B, C - FLOOR BOX TYPE. NS ARE DESCRIBED ABOVE. |
| | POKE THRU WITH COMBINED VOICE/DATA, AUDIO/VIDEO AND POWER. X = A, B, C - FLOOR BOX TYPE. NS ARE DESCRIBED ABOVE. |
| | 3/4" PLYWOOD BACKBOARD, BY DIVISION 16 |
| | IDF - 2 POST RACK |
| | IDF - 4 POST RACK |
| | TELECOMM PANEL |
| | TELECOMMUNICATIONS ENTRANCE FACILITY |
| | TELECOMMUNICATIONS ROOM |
| | TELECOMMUNICATIONS EQUIPMENT ROOM |
| | STRUCTURED CABLING SYSTEM BY DIVISION 27 (CABLES INSTALLED) |

| SECURITY SYSTEM | |
|-----------------|---|
| SYMBOL | DESCRIPTION |
| | FIXED CCTV CAMERA - PROVIDE CAT6A CABLE |
| | PAN/TILT/ZOOM CCTV CAMERA CAT6A CABLE |
| | CAMERA NUMBER DESIGNATION |
| | SECURITY PANEL |
| | DOOR POSITION SWITCH |
| | BALANCED MAGNETIC SWITCH |
| | CARD READER |
| | KEYPAD |
| | COMBINED CARD READER/KEYPAD |
| | HRSH SCRAMBLE KEYPAD |
| | INTRUSION ALARM KEYPAD |
| | BIOMETRIC READER |
| | LOCAL HORN STROBE ALARM |
| | ELECTRIC LATCH |
| | ELECTRIC MORTISE/RIM LOCK |
| | ELECTRIC STRIKE |
| | MAGNETIC LOCK |
| | SHEAR LOCK |
| | DELAYED EGRESS |
| | DETENTION LOCK |
| | DOOR INTERLOCK |
| | REMOTE DOOR RELEASE BUTTON |
| | REX OR ADA DOOR OPEN BUTTON |
| | ASSISTANCE STATION |
| | INTERCOM SUBSTATION |
| | SPEAKER PHONE |
| | DURESS BUTTON MOUNTED UNDER COUNTER |
| | CCTV MONITOR |
| | PHOTO ELECTRIC BEAM |
| | INTERCOM MASTER STATION |
| | DIRECTIONAL MOTION DETECTOR |
| | 360° MOTION DETECTOR |
| | GLASS BREAK SENSOR |
| | REQUEST TO EXIT MOTION SENSOR |
| | ASSOCIATED DOOR DETAIL REFERENCE |
| | PERSONAL COMPUTER WORKSTATION |

NOTES:
 1. ALL RACEWAYS AND BOXES SHOWN ARE IN CONTRACT BY THE ELECTRICAL INSTALLER.
 2. SECURITY DEVICES AND EQUIPMENT BY DIVISION 28 SECURITY INSTALLER.

| GENERAL SYSTEM NOTES | |
|----------------------|--|
| SYMBOL | DESCRIPTION |
| | PRODUCTS SHALL BE OF MATERIALS THAT ARE SUITABLE FOR THE ENVIRONMENT IN WHICH THEY ARE TO BE INSTALLED. |
| | WORKING CLEARANCES AROUND ELECTRICAL EQUIPMENT SHALL BE MAINTAINED IN COMPLIANCE WITH THE NATIONAL ELECTRICAL CODE, ARTICLE 110. COORDINATE EQUIPMENT INSTALLATION TO MAINTAIN REQUIRED CLEARANCES. |
| | IF AN OUTLET BOX IS REQUIRED TO BE LOCATED IN AN ASSEMBLY OR PARTITION RATED AS "FIRE/SMOKE" OR "SMOKE" OR IDENTIFIED AS EITHER "FIRE/SMOKE" OR "SMOKE", THEN ALL OF THE FOLLOWING CONDITIONS SHALL BE MET: A. THE OUTLET BOX SHALL BE METALLIC. B. THE OUTLET BOX OPENINGS SHALL OCCUR ONLY ON ONE SIDE OF THE FRAMING SPACE. C. THE OUTLET BOX OPENINGS SHALL NOT EXCEED 16 SQUARE INCHES. D. ALL CLEARANCES BETWEEN THE OUTLET BOX AND THE WALL BOARD MATERIAL SHALL BE COMPLETELY SEALED WITH APPROVED MATERIALS IN ACCORDANCE WITH THE APPLICABLE CODES AND STANDARDS FOR THE PROJECT. E. PROVIDE A SUPPLEMENTAL BARRIER AROUND OUTLETS LARGER THAN 16 INCHES SO THAT THE ORIGINAL RATING OF THE PENETRATION IS MAINTAINED. F. THE TOTAL AGGREGATE SURFACE AREA OF THE OUTLET BOX SHALL NOT EXCEED 100 SQUARE INCHES PER 100 SQUARE FEET. G. THE OUTLET BOX SHALL BE SEPARATED FROM OPENINGS ON THE OPPOSITE SIDE OF THE RATED PARTITION BY A MINIMUM HORIZONTAL DISTANCE OF 24 INCHES. H. THE OUTLET BOX SHALL BE SECURELY FASTENED TO A PARTITION FRAMING MEMBER BY MEANS OF AN APPROVED ATTACHMENT METHOD. I. OPENINGS CUT INTO THE WALL BOARD MATERIAL SHALL NOT EXCEED 1/8 INCH BETWEEN THE EDGES OF THE OUTLET BOX AND THE EDGES OF THE OPENING. |
| | LOCATIONS OF EQUIPMENT SHOWN ON THE DRAWINGS ARE APPROXIMATE. COORDINATE EXACT EQUIPMENT LOCATION AND CONNECTION REQUIREMENTS WITH THE APPROPRIATE TRADE PRIOR TO INSTALLATION. |
| | FOR EXACT LOCATION OF CEILING MOUNTED EQUIPMENT REFER TO THE ARCHITECTURAL REFLECTED CEILING PLAN. LOCATIONS OF EQUIPMENT NOT INCLUDED ON THE REFLECTED CEILING PLAN SHALL BE COORDINATED WITH THOSE ITEMS SHOWN. COORDINATION OF CEILING MOUNTED EQUIPMENT SHALL BE PRIOR TO ANY ROUGH-IN. NOTIFY ENGINEER OF ANY DISCREPANCY. |
| | PROVIDE FINAL CONNECTIONS TO OWNER PROVIDED EQUIPMENT WHERE INDICATED ON THE PLAN DRAWINGS. |
| | PRIOR TO ROUGH-IN AND INSTALLATION OF ANY FLOOR MOUNTED DEVICE, VERIFY LOCATION WITH THE OWNER AND ARCHITECT. |
| | VERIFY AND COORDINATE THE LOCATION OF REQUIRED OUTLETS WITH OTHER TRADE DRAWINGS AND OWNER PROVIDED EQUIPMENT. |
| | EACH TELEVISION OUTLET LOCATION SHOWN SHALL HAVE A DOUBLE GANG OUTLET BOX WITH A SINGLE GANG PLASTER AND (1) 1" CONDUIT STUBBED UP TO AN ACCESSIBLE LOCATION ABOVE THE FINISHED CEILING OR TO AN ACCESSIBLE CABLE TRAY WHERE PROVIDED. |
| | THE DESIGNATION "N.I.C." SHALL DENOTE ITEMS WHICH ARE "NOT IN CONTRACT". |
| | THE DESIGNATION "S" SHALL DENOTE ITEMS WHICH ARE "UNDER SEPARATE CONTRACT". |
| | THE DESIGNATION "F.O.D." SHALL DENOTE ITEMS WHICH ARE FURNISHED BY OTHERS. |
| | THE DESIGNATION "O.F.E." SHALL DENOTE ITEMS WHICH ARE "OWNER FURNISHED EQUIPMENT". |
| | THE DESIGNATION "D.H.C." SHALL DENOTE "OWNER HARDWARE INSTALLER". |
| | THE DESIGNATION "O.F.C.I." SHALL DENOTE ITEMS WHICH ARE FURNISHED BY THE OWNER AND INSTALLED BY THE CONTRACTOR. |
| | ALL WALKWAYS SYSTEMS SHOWN TO SUPPORT THE INSTALLATION OF THE PHOTO ELECTRIC BEAM SHALL BE PROVIDED BY THE ELECTRICAL INSTALLER. PROVIDE INFORMATION FOR THE INSTALLATION OF THIS BE PROVIDED BY THE ELECTRICAL INSTALLER. |
| | ALL SYMBOLS SHOWN ON THIS SHEET ARE ALL INCLUSIVE. ITEMS NOT SHOWN IN THE LEGENDS MAY OR MAY NOT BE USED IN THE PROJECT DRAWINGS. |
| | EACH VOICE/DATA OUTLET LOCATION SHOWN SHALL HAVE A DOUBLE GANG OUTLET BOX WITH A SINGLE GANG PLASTER KINGS AND (1) 1" CONDUIT STUBBED UP TO AN ACCESSIBLE LOCATION ABOVE THE FINISHED CEILING, TO AN ACCESSIBLE CABLE TRAY WHERE PROVIDED OR HOMERUN IN SLAB TO NEAREST COMMUNICATIONS ROOM. WORK BY ELECTRICAL INSTALLER PER SPECS. |
| | EACH FLOOR MOUNTED VOICE/DATA OUTLET SHALL HAVE A SINGLE GANG SPACE WITHIN THE FLOOR BOX AND (1) 1" CONDUIT CONCEALED IN SLAB STUBBED UP TO AN ACCESSIBLE LOCATION ABOVE THE FINISHED CEILING OR TO AN ACCESSIBLE CABLE TRAY WHERE PROVIDED. WORK BY ELECTRICAL INSTALLER PER SPECS. |
| | ALL BONDING AND GROUNDING ELEMENTS UTILIZED FOR STRUCTURED CABLING SYSTEM SHALL BE IN COMPLIANCE WITH SPECIFICATION SECTION 270526. |
| | PROVIDE ALL SLEEVES AS REQUIRED FOR ALL LOW VOLTAGE CABLE PATHWAYS. RE-STORE THE FIRE RATING OF THE SURFACE. |
| | ALL CABLES SHALL BE SUITABLE TO THE ENVIRONMENT TO WHERE THEY WILL BE INSTALLED. |
| | ALL INDOOR CONDUITS NO LARGER THAN 1" SHOWN ON THE GROUND FLOOR SHALL BE INSTALLED EMBEDDED IN THE SLAB. CONDUITS SHALL BE KEPT DRY AND CLEAN PRIOR TO PULLING CABLES. |
| | ANYTHING NOT DESIGNATED AS ROUGH-IN AND SUPPORT RESPONSIBILITY ON THESE DRAWINGS IS IN THE SYSTEM INSTALLER SCOPE OF WORK. |
| | SEE DETAIL SHEETS FOR DEVICE MOUNTING REQUIREMENTS AND ADDITIONAL INFORMATION. |
| | IN ELECTRICAL AND MECHANICAL ROOMS, CONDUIT FOR LOW VOLTAGE OUTLETS SHALL BE EXTENDED TO ACCESSIBLE CEILING OUTSIDE OF THE ROOM. |

| SECURITY SYSTEM NOTES | |
|-----------------------|--|
| SYMBOL | DESCRIPTION |
| | ALL DOUBLE DOORS ARE TO RECEIVE (1) DOOR POSITION SWITCH ON EACH DOOR LEAF AND SHALL REPORT AS ONE ALARM POINT. |
| | ALL 120V POWER WIRING SHALL BE INSTALLED IN A SEPARATE CONDUIT. |
| | FIBER CCTV LOCATION WHICH EXCEEDS 3000 FEET SHALL BE EQUIPPED WITH 2 FIBER CONNECTIONS 1 VIDEO, 1 DATA. |
| | ALL POWER CIRCUITS, 120VAC AND 24VAC, SHALL INCLUDE AN EQUIPMENT GROUNDING CONDUCTOR WHICH IS EQUAL IN SIZE TO THE PHASE AND NEUTRAL CONDUCTORS. |
| | ALL CONDUIT ABOVE GRADE SHALL BE METALLIC. ALL CONDUIT BELOW GRADE SHALL BE PVC UNLESS OTHERWISE NOTED ON DRAWINGS. |
| | ALL CARD READERS AND KEYPADS DEDICATED FOR ELEVATOR FLOOR SELECTION CONTROL ARE SHOWN INSIDE THE ELEVATOR CAB ON THE LOWEST LEVEL FLOOR PLAN TO WHICH THE ELEVATOR TRAVELS. |
| | ALL CONDUIT, WIRING, AND ASSOCIATED BACK BOXES SHALL BE FULLY CONCEALED WITHIN WALLS, FLOORS, AND CEILINGS. |
| | INSTALLATION OF CATEGORY 6A UTP CABLE SHALL BE IN ACCORDANCE WITH ENITA GUIDELINES. CABLE INSTALLATION AND TERMINATIONS THAT DO NOT COMPLY SHALL BE REPLACED BY THE INSTALLER. A. THE MAXIMUM PULLING TENSION SHALL NOT EXCEED 25 POUNDS TO AVOID STRETCHING OF THE CONDUCTORS. B. THE MINIMUM BENDING RADIUS OF THE CABLE SHALL NOT BE LESS THAN 4X THE OUTSIDE DIAMETER OF THE CABLE. C. THE CABLE SHALL BE INSTALLED WITHOUT KINKS OR TWISTS AND THE APPLICATION OF CABLE TIES SHALL NOT DEFORM THE CABLE BUNDLE. D. STRIP BACK ONLY AS MUCH CABLE JACKET AS IS REQUIRED TO TERMINATE THE CABLE. CABLE PARS SHALL NOT BE UNWITTINGLY MORE THAN 1/2 INCH. E. INSTALLATION OF FIBER OPTIC CABLES SHALL BE IN ACCORDANCE WITH ENITA GUIDELINES. CABLE INSTALLATION AND TERMINATIONS THAT DO NOT COMPLY SHALL BE REPLACED BY THE INSTALLER. A. THE BEND RADIUS OF A STRAIGHT DRAWING OF A FIBER OPTIC CABLE SHALL NOT BE LESS THAN 1 INCH UNDER NO LOAD CONDITIONS AND UNDER A MAXIMUM TENSILE LOAD OF 50 LBF, THE BEND RADIUS SHALL NOT BE LESS THAN 2 INCHES. B. THE BEND RADIUS FOR A BUNDLING OPTICAL FIBER BACKBONE SHALL NOT BE LESS THAN THAT RECOMMENDED BY THE MANUFACTURER IF NO RECOMMENDATION IS KNOWN, THEN THE APPLIED BEND RADIUS SHALL NOT BE LESS THAN 10 TIMES THE CABLE OUTSIDE DIAMETER. C. THE BEND RADIUS FOR WHEN THE CABLE IS UNDER TENSILE LOAD, THE BEND RADIUS FOR INTER BUILDING (OSP) OPTICAL FIBER BACKBONE SHALL NOT BE LESS THAN THAT RECOMMENDED BY THE MANUFACTURER IF NO RECOMMENDATION IS KNOWN, THEN THE APPLIED BEND RADIUS SHALL NOT BE LESS THAN 10 TIMES THE CABLE OUTSIDE DIAMETER. NO LOAD CONDITIONS AND NOT LESS THAN 15 TIMES THE CABLE OUTSIDE DIAMETER WHEN THE CABLE IS UNDER A TENSILE LOAD UP TO THE RATING OF THE CABLE, USUALLY 600 LBF. |
| | COORDINATE LOCATION OF ALL FIRE RATED PENETRATIONS PRIOR TO PROCEEDING WITH INSTALLATION. ALL PENETRATIONS THROUGH FIRE RATED BARRIERS SHALL BE COMPLETELY SEALED WITH APPROPRIATE FIRE STOP MATERIAL IN ACCORDANCE WITH NFPA AND FIRE AUTHORITY HAVING JURISDICTION. 11. ALL DELAYED EGRESS LOCKS AND MAGNETIC LOCKS SHALL RECEIVE A FIRE ALARM RELAY TO RELEASE THE DOOR UPON ALARM AS REQUIRED BY CODE. |

| TECHNOLOGY DRAWING INDEX | | |
|--------------------------|---------------------------------------|--------|
| SHEET | DESCRIPTION | ISSUED |
| T001 | GENERAL INFORMATION - TECHNOLOGY | Yes |
| T002 | SITE PLAN - VOICE/ATA | Yes |
| T003 | SITE PLAN - AV/SECURITY | Yes |
| T004 | GROUND FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T005 | GROUND FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T006 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T007 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T008 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T009 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T010 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T011 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T012 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T013 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T014 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T015 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T016 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T017 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T018 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T019 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T020 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T021 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T022 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T023 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T024 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T025 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T026 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T027 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T028 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T029 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T030 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T031 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T032 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T033 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T034 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T035 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T036 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T037 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T038 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T039 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T040 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T041 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T042 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T043 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T044 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T045 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T046 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T047 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T048 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T049 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T050 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T051 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T052 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T053 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T054 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T055 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T056 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T057 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T058 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T059 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T060 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T061 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T062 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T063 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T064 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T065 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T066 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T067 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T068 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T069 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T070 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T071 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T072 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T073 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T074 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T075 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T076 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T077 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T078 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T079 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T080 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T081 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T082 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T083 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T084 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T085 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T086 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T087 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T088 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T089 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T090 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T091 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T092 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T093 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T094 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T095 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T096 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T097 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T098 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T099 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T100 | LEVEL 1 FLOOR PLAN - WEST - VOICE/ATA | Yes |
| T101 | LEVEL 1 FLOOR PLAN - EAST - VOICE/ATA | Yes |
| T102 | LEVEL 1 | |