



GENERAL NOTES

- A. REFER TO SHEET E101A FOR EXACT FIXTURE LOCATIONS.
- B. REFER TO SHEET E301 FOR LIGHT FIXTURE SCHEDULE, TIME CLOCK / CONTACTOR, AND LIGHTING DETAILS. SHEET E202 FOR DIMMING PANEL SCHEDULE.
- C. REFER TO SHEET E401 FOR GENERAL NOTES.
- D. REFER TO SHEET E200 FOR BLDG. SIGN CIRCUITS.
- E. DAY LIGHT CONTROL DEVICES IN THE FRC SECTION 405.2.3 HAS NOT BEEN DESIGNED INTO THE PROJECT. REFER TO THE OPERATIONAL PROCEDURES OF THIS RESTAURANT. IN THE DINING AREA IT IS THE RESTAURANT'S INTENT TO OPERATE THEIR LIGHTS AT HALF BRIGHT DURING DAYTIME HOURS. HOWEVER AT NIGHTTIME OR LATE EVENING THE INTERIOR LIGHTS ARE DIMMED TO LOWER LIGHT LEVELS. SINCE THE DINING AREA LIGHTS ARE INTENDED TO OPERATE CONTINUOUSLY DURING OPERATING HOURS DAY LIGHT CONTROLS WERE NOT DESIGNED. FOR EXCEPTION 405.2.4 (a), ADDITIONAL CONTROLS NEED NOT BE PROVIDED IN SPACES WHERE LIGHTING IS INTENDED FOR CONTINUOUS OPERATION. EVEN THOUGH DAY LIGHT CONTROL WAS NOT PROVIDED IN THIS DESIGN, THE INTERIOR LIGHTING IS STILL CONTROLLED AUTOMATICALLY SO THAT DURING NON-OPERATIONAL HOURS THE LIGHTS WILL BE AUTOMATICALLY SHUT OFF.
- F. ALL CONDUITS IN THE EXPOSED CEILING AREAS SHALL BE IN METAL CONDUIT AND RUN PERPENDICULAR AND PARALLEL TO OVERHEAD STRUCTURE IN OPEN CEILING AREAS. NO MC ALLOWED.

EMERGENCY LIGHT NOTE

DIMMER CIRCUIT IN FRONT OF HOUSE ARE USED TO POWER EMERGENCY EXIT LIGHTS. THE OUTPUT OF THE DIMMER MODULE HAS (4) THAT DIM AND (1) THAT IS INSTANT HOT ON CIRCUITS THAT HAVE EMERGENCY / EXIT LIGHTS. RUN CONDUIT INSTANT TO THE EMERGENCY / EXIT DEVICES.

PRIORITY OF CONSTRUCTION

- A. FIRST DUCTWORK
- B. SECOND FRI PROTECTION WORKING
- C. THIRD ANY OTHER ELECTRICAL REQUIREMENTS
- D. FOURTH OTHER PLYNG
- E. FIFTH CONDUIT

SITE LIGHTING NOTES

REFER TO SHEET LIGHTING PHOTOMETRIC, AND/OR SITE UTILITY FOR SITE LIGHTING LAYOUT. REFER TO LOCATION, REFER TO SITE LIGHTING SCHEMATIC, SHEET E301 FOR CIRCUITS.

ADDITIONAL LIGHT NOTES

REFER TO SHEET E200 FOR UPPER LIGHT LOCATIONS.

SHEET KEYNOTES

- 1. SECURITY NIGHT LIGHT, FIXTURE REMAIN ON 24 HR / 7 DAYS A WEEK. CONNECT TO UN-SWITCHED CONDUCTORS.
- 2. GROUND MOUNTED FLOOD LIGHTS. SEE FIXTURE SCHEDULE FOR MORE INFORMATION.
- 3. EMERGENCY LIGHTS EXITS TO BE CONNECTED AHEAD OF LOCAL SWITCHING.
- 4. RESTROOM LIGHT WALL SWITCH LOCATION. SEE RESTROOM LIGHTING & TOILET EXHAUST FAN CONTROL DIAGRAM.
- 5. ROUTE THROUGH LIGHTING CONTACTOR & TIME SWITCH. REFER TO LIGHTING CONTROL DIAGRAM SHEET E301.
- 6. DIMMER CONTROL STATION & PANEL, "DH". REFER TO PANEL SCHEDULE.
- 7. CONNECT TO CEILING EXHAUST FAN. REFER TO ROOF PLAN ON SHEET E200.
- 8. REFER TO EXTERIOR ELEVATIONS FOR MOUNTING HEIGHT OF EXTERIOR WALL LIGHTS.
- 9. SWITCHES FOR PATIO FANS & LIGHTS. LIGHTS AND FANS TO BE ON SEPARATE SWITCH. MOUNT ABOVE WANSBOT.
- 10. KITCHEN WALL SWITCH LOCATION. PROVIDE DOUBLE SWITCHING AS SHOWN FOR KITCHEN. REFER TO RESTROOM EXHAUST FAN CONTROL DIAGRAM. COORDINATE SWITCHES TO WITH PANEL "C".
- 11. USE SPOT LIGHT IN THESE FIXTURES.
- 12. J-BOX AND TRANSFORMER FOR USE LED TAPE LIGHT IN ARTWORK. COORDINATE LOCATION WITH ARCHITECTURAL INTERIOR ELEVATION ON A420.
- 13. PROVIDE TIME SWITCHES AND CONTACTORS ON WALL. REFER TO DETAIL LIGHTING CONTROL DIAGRAM ON SHEET E301.
- 14. LIGHT WITH BATTERY PACK, CONNECT BATTERY PACK TO UN-SWITCHED CONDUCTORS.
- 15. TO PATIO LIGHT SWITCH LOCATION AT ALCOVE IN LOBBY.
- 16. J-BOX FOR CONNECTION TO OWNER FURNISHED CUSTOM OVERSIZE FEATURE LIGHTING FIXTURE. VERIFY WITH SUPPLIER PRIOR TO INSTALLATION.
- 17. CONNECTION POINT FOR LED COVE LIGHT L433 IN BOTTOM OF CANOPY.
- 18. THIS AREA IS CONTROLLED W/ BI-LEVEL SWITCHING.
- 19. FIXTURE LOCATION AS INDICATED ON ARCHITECTURAL EXTERIOR ELEVATIONS.
- 20. LED DRIVER MOUNTED INSIDE IN ACCESSIBLE LOCATION WITH CONNECTION TO LIGHTING SYSTEM PER MANUFACTURER'S REQUIREMENTS.
- 21. PROVIDE UN-SWITCHED CONDUCTOR FOR EXIT & EMERGENCY LIGHTS.
- 22. ALLIANCE OUTDOOR LIGHTING LANDSCAPE LIGHTING TRANSFORMER MODEL, EXF-300 WITH PHOTOCELL AND DIGITAL TIMER TRANSFORMER S 120V TO 12V WITH POWER DRAW 2 AMP. PHOTOCELL MOUNT TO WALL EXTERIOR. LOW VOLTAGE LANDSCAPE LIGHTING WIRE SHALL BE OUTDOOR RATED FOR DIRECT BURIAL, (10 AWG) RUN WIRE IN LANDSCAPE PLANTERS. UNDER PAVEMENT INSTALL 2" SLEEVES FOR WIRES. WIRE RUNS SHOWN ARE FOR VOLTAGE DROP.
- 23. ALL LIGHTING FIXTURES IN THE BACK BAR WALL WILL BE PROVIDED BY THE MELLOWORK VENDOR. INSTALLATION AND FINAL CONNECTIONS BY THE ELECTRICAL CONTRACTOR.
- 24. PROVIDE LED TAPE LIGHT L433 TO BE INSTALLED CONTINUOUS AT OUTER EDGE OF UPPER TRIM CAP. REFERENCE ARCHITECTURAL ELEVATIONS FOR METAL LOUVER SYSTEMS IN THIS AREA.
- 25. PROVIDE 1-AMP TRACK CURRENT LIMITER ON HOMERUN CIRCUITRY.
- 26. J-BOX FOR FIXTURE L433 DRIVER SHALL BE MOUNTED IN ACCESSIBLE CEILING. RUN CONDUIT AND CABLE FROM J-BOX TO EACH LED DRIVER AND THEN FROM DRIVER TO LENGTH OF LED COVE LIGHT.



BLOOMIN' BRANDS
OUTBACK STEAKHOUSE
 1751 W 49TH STREET
 HALEAH, FLORIDA 33012

SHEET ISSUE
 OUT TO PERMIT.

PRINCIPAL IN CHARGE: JC
 PROJECT ARCHITECT: MS
 DRAWN BY: BM

SHEET TITLE
ELECTRICAL LIGHTING PLAN

SHEET NO. PROJ. NO.
 E101 2018231.50