


- KEY NOTES**
1. INSTALL A SINGLE EMERGENCY POWER CUTOFF CONTROL TO REMOVE AC POWER FROM SITE DISPENSING EQUIPMENT. (THE CONTROL IS AN ADDITIONAL SAFETY FEATURE AND NOT A SUBSTITUTE FOR NEC/NFPA30 CIRCUIT BREAKER REQUIREMENTS.  
 \* LABEL THE EMERGENCY POWER CUTOFF SWITCH AND INSTRUCT OWNER TO KEEP AREA CLEAR OF OBSTACLES.
  2. CONNECT INSULATED GROUNDING CONDUCTOR FROM THE DISPENSER POWER PANEL TO THE SITE GROUNDING ELECTRODE. SIZE PER NEC.
  3. INSTALL POWER BREAKERS TO EACH CIRCUIT LEADING TO THE DISPENSING UNIT AND STP. THEY MUST BE CAPABLE OF SIMULTANEOUSLY DISCONNECTING HOT AND NEUTRAL INDUCTIONS.
  4. REFER TO INSTALLATION ADDENDA FOR SPECIFIC PRODUCT FIELD WIRING CONNECTIONS. CAP ALL UNUSED WIRES. LOCAL AND NEC MAY APPLY.
  5. INSTALL CONDUIT PER NEC FOR HAZARDOUS LOCATIONS.
  6. WIRES - ALL WIRES ARE 14AWG (STANDARD) UNLESS OTHERWISE NOTED. PUMP / DISP. GROUND - WIRE IS 12 AWG (STANDARD).  
 POWER LOADING AND DISTANCE RUN MAY REQUIRE LARGER WIRE SIZE.
  7. NOT USED
  8. STP ISOLATION RELAY BOXES ARE MANDATED BY THE NEC (ARTICLE 514.13 - PROVISIONS FOR MAINTENANCE AND SERVICE OF DISPENSING EQUIPMENT) AND ARE REQUIRED TO:  
 A. ALLOW SERVICE OF ONE UNIT SAFELY WITHOUT REMOVING POWER FROM ALL DISPENSING EQUIPMENT.  
 B. PREVENT DAMAGE TO EQUIPMENT FROM CROSS-PHASING.  
 DAMAGE CAUSED BY CROSS-PHASING IS NOT COVERED BY WARRANTY.  
 GILBARCO STP ISOLATION BOX PA0287 IS NOT AVAILABLE FOR 220/230/240VAC UNITS. (THIS IS A 7-ELEVEN SUPPLIED ITEM.)
  9. FOR STPs GREATER THAN 1-1/2HP (SINGLE OR THREE PHASE) CONNECT TO MOTOR CONTRACTOR COIL OF SEPARATE STP RELAY BOX.
  10. L1 FEEDS STP BOX CONTRACTOR COIL. THEREFORE L1 & EMC MUST BE ON THE SAME PHASE OR DAMAGE TO EMC WILL RESULT. WHEN EMC IS NOT USED, JUMPER STP BOX TERMINALS P0 AND P1 TOGETHER TO COMPLETE THIS CIRCUIT.
  11. V.F.C. or STP C.B.S.

Rev. #	Date	Description


Proto 11-05-18  
 7-ELEVEN, INC.  
 3200 HACKBERRY ROAD, IRVING TEXAS 75063  
 7-ELEVEN #38777  
 US 301 & FORT HAMER ROAD  
 PARRISH, FL 34219  
 ISOLATION RELAY BOX DETAIL



**CORE STATES GROUP**  
 1700 Industrial Drive, Suite B  
 Rogers, AR 72756  
 FAX (479) 688-4407

Job#:	SEI-26848
Scale:	AS NOTED
Date:	05/06/19
Drawn By:	RMK
Checked By:	KMS

Documents prepared by Core States Group are to be used only for the specific project and no other project. Any extension of use to other projects, by owner or any other party, without the written consent of Core States Group is done at the user's own risk. If used in a manner not intended, user will hold Core States Group harmless from all claims and losses.



Order Plans @ WWW.LDILLINE.COM

1 WIRING DIAGRAM FOR ISOLATION RELAY BOX  
 NTS