



NOTES *:
 NOTE THAT THE LOW PRESSURE TAP IS PLACED APPROXIMATELY 3' FROM THE PUMP AND THE HIGH PRESSURE TAP IS 1/3 THE DISTANCE DOWN STREAMS OF THE PUMP. THIS ASSUMES THAT THERE ARE NO EXISTING TAPS FOR THE EXISTING SYSTEM.

7 CHILLED WATER FLOW DIAGRAM (TYPICAL)
 M303 SCALE: N.T.S.

HAMMOND & ASSOCIATES, INC.
 CONSULTING ENGINEERS
 7348 NW 5TH STREET
 PLANTATION, FLORIDA 33317
 TEL: (954) 327-7111 FAX (954) 327-7154
 ERIC J. HAMMOND P.E.
 MECHANICAL / ELECTRICAL ENGINEER
 P.E. #39048
 EB 5315

CRAIN ATLANTIS
 ENGINEERING, INC.
 CONSULTING ENGINEERS & ARCHITECTS
 2710 SW 14TH AVENUE
 DEERFIELD BEACH, FLORIDA 33441
 AA 26001859 EB - 27488

NO.	REVISIONS

SEA CASTLE
 ELEMENTARY SCHOOL
 9600 MIRAMAR BOULEVARD
 MIRAMAR, FLORIDA 33025
 THE SCHOOL BOARD OF BROWARD COUNTY

RECEIVED
 DEC 19 2017
 BUILDING DEPARTMENT
 BCPS

Order Plans @ www.LDILine.com

Bid Documents Only
 Not For Construction

MECHANICAL DETAILS CONTD.

JOB PHASE: 100% SUBMITTAL
 SBPC PROJECT: P.001632
 DATE: 12.13.16
 SCALE: AS SHOWN
 DRAWN BY: HA
 CHECKED BY: E.H.
 ICAE PROJECT No. 2016.55

FL. LICENSE PE# 39048

ERIC HAMMOND
 PROFESSIONAL ENGINEER
 SEAL

DRAWING No.
 M-303

Handwritten signature and date: 12-19-17

THIS IS A VIOLATION OF THE LAW FOR ANY PERSON UNLESS ACTING UNDER THE DIRECTION OF A LICENSED ARCHITECT, TO ALTER THESE PLANS AND SPECIFICATIONS. THIS DOCUMENT CONTAINS PROPERTY INFORMATION AND SHALL NOT BE USED OR REPRODUCED, OR ITS CONTENTS DISCLOSED, IN WHOLE OR IN PART, WITHOUT THE PRIOR WRITTEN CONSENT OF CRAIN ATLANTIS ENGINEERING, INC. COPYRIGHT 2014 CRAIN ATLANTIS ENGINEERING, INC.