



**A**  
 M2.5 MECHANICAL ROOF PLAN  
 SCALE: 1/8" = 1'-0"

- NEW WORK KEYED NOTES:
- ① INSTALL CONDENSING UNIT ON PATE EQUIPMENT SUPPORT RAILS, MODEL ES-2, 12" HIGH. PROVIDE PATE PIPING PORTAL, MODEL PCC-5, 12" HIGH, 15"x15" CURB WITH ALL REQUIRED BOOTS AND CLAMPS FOR REFRIGERANT PIPING, CONDUITS AND CONTROL WIRING.
  - ② RELIEF HOOD INSTALLED OVER INDIVIDUAL 4" EXHAUST DUCTWORK. REFER TO DETAIL.

NOTE:  
 ALL 4" EXHAUST DUCTWORK TO BE MINIMUM 26 GAUGE GALVANIZED STEEL (MINIMUM WALL THICKNESS 0.187 INCHES).

NOTE:  
 FIRE CAULK ALL EXHAUST DUCT PENETRATIONS WITHIN FIRE RATED ASSEMBLIES AT BOTH SIDES OF ALL PENETRATIONS.

No.	Description	Date

**MEISTER-COX ARCHITECTS**  
 INFO@MEISTER-COX.COM  
 PHONE: 610-375-1331 FAX: 610-375-4555  
 1522 PENN AVENUE WYOMISSING, PA 19610  
 WWW.MEISTER-COX.COM

SEAL:

**MECHANICAL ROOF PLAN**  
 HOLIDAY INN EXPRESS & SUITES  
 INTERSECTION OF HAYNES PLACE & LAMM RD.  
 WILSON, NC 27883

STATUS:	FOR BID
PROJ. DATE:	06/06/2019
PROJ. NO.:	19-116
PRINTED:	06/06/2019
DRAWN BY:	jlm/brm/jpk
CHECKED BY:	brm
SHEET NO.:	<b>M2.5</b>
SCALE:	AS NOTED