



DRY PIPE RISER, REFER TO RISER DETAIL
 WET PIPE RISER, REFER TO RISER DETAIL
 6" FIRE PROTECTION BACKFLOW PREVENTER AND SERVICE. REFER TO DETAIL
 6" FIRE SERVICE WATER LINE FROM UTILITY. EXTEND TO SITE PIPING AND MAKE FINAL CONNECTION. REFER TO CIVIL DRAWINGS.
 FIRE PUMP TEST HEADER WITH THREE 2-1/2" THREADED CONNECTIONS
 FIRE DEPARTMENT CONNECTIONS AND SPRINKLER ALARMS. COORDINATE FINAL LOCATION WITH AHJ.

- CONSTRUCTION PLAN GENERAL NOTES:**
- REFER TO SHEET FP0.0 FOR ALL SYMBOLS AND APPLICABLE GENERAL NOTES.
- CONSTRUCTION PLAN KEY NOTES**
- STANDPIPE WITH HOSE VALVE. REFER TO DETAIL.
 - FLOOR CONTROL VALVE ASSEMBLY. REFER TO DETAIL.
 - PROVIDE SPRINKLER HEAD IN LAUNDRY CHUTE. COORDINATE WITH CIVIL.
 - FP-1: PACKAGED FIRE PUMP SKID. A-C FIRE PUMP MODEL 100, FIRE PUMP AND JOCKEY PUMP. PUMP TO BE RATED FOR 750 GPM TO MAINTAIN 200 PSI AT TOP OF STANDPIPE, 3550 RPM, 208V, 3 PHASE. ENTIRE UNIT TO BE MOUNTED ON COMMON SKID WITH FIRE PUMP AND JOCKEY PUMP CONTROL. ENTIRE UNIT TO BE UL/FM LISTED. ENTIRE ASSEMBLY TO MEET NFPA 13 AND 20.

NOTE:
 ALL SPRINKLER HEADS IN POOL ROOM, POOL EQUIPMENT ROOM, AND STORAGE TO BE CORROSION RESISTANT.

WWW.LDILine.com

Order Plans @

No.	Description	Date

MEISTER-COX ARCHITECTS
 INFO@MEISTER-COX.COM
 PHONE: 610-375-1331 FAX: 610-375-4555
 1522 PENN AVENUE WYOMISSING, PA 19610
 WWW.MEISTER-COX.COM

SEAL:

FIRE PROTECTION FIRST FLOOR PLAN
 HOLIDAY INN EXPRESS & SUITES
 INTERSECTION OF HAYNES PLACE & LAMM RD.
 WILSON, NC 27883

STATUS:	FOR BID
PROJ. DATE:	06/06/2019
PROJ. NO.:	19-116
PRINTED:	06/06/2019
DRAWN BY:	jlm/brm/jpk
CHECKED BY:	brm
SHEET NO.:	FP2.1
SCALE:	AS NOTED