



A ELECTRICAL THIRD FLOOR PLAN - POWER
 E2.5 SCALE: 1/8" = 1'-0"

Order Plans @

- NEW WORK KEMD NOTES:**
- ① FOR HEARING IMPAIRED ROOMS, PROVIDE THE FOLLOWING DEVICES:
 - DOOR BELL AT SUITE ENTRANCE
 - STROBE IN SUITE TO IDENTIFY DOOR BELL ACTIVATION WITH CUT OFF SWITCH (SEPARATE FROM FIRE ALARM SYSTEM)
 - 177 CO/HEN/STROBE CONNECTED TO BUILDING FIRE ALARM SYSTEM IN BEDROOM
 - 177 CO STROBE CONNECTED TO BUILDING FIRE ALARM SYSTEM IN BATHROOM
 - ADDRESSIBLE SMOKE DETECTOR WITH SOUNDER BASE AND STROBE WHICH ACTIVATES JUPON SMOKE ALARM
 - ② FIRE DEPARTMENT 2-WAY COMMUNICATION/HOUSE PHONE
 - ③ PROVIDE 20 AMP, 208 VOLT PLUG FOR PTAC-1. SEE ENLARGED ROOM PLANS FOR WIRING.
 - ④ PROVIDE 20 AMP, 208 VOLT PLUG FOR PTAC-2. SEE ENLARGED ROOM PLANS FOR WIRING.

- GENERAL NOTES:**
1. REFER TO MECHANICAL DRAWINGS FOR SMOKE DAMPER LOCATIONS. ALL SMOKE DAMPERS SHALL BE WIRED TO 120 VOLT AVAILABLE DEDICATED CIRCUIT. ALL SMOKE DAMPERS SHALL BE CONTROLLED VIA FIRE ALARM SYSTEM ACTIVATION. PROVIDE ALL LINE VOLTAGE WIRING AND FIRE ALARM WIRING AS REQUIRED TO MEET IBC SECTION 716 REQUIREMENTS.
 2. PROVIDE SOUND SYSTEM PER FRANCHISE REQUIREMENTS. COORDINATE ALL WORK WITH FRANCHISE AND OWNER PRIOR TO INSTALLATION.
 3. REFER TO ENLARGED PLANS FOR POWER CIRCUITING, LIGHTING CIRCUITING, EXHAUST FAN REQUIREMENTS, AND PTAC REQUIREMENTS.

No.	Description	Date

MEISTER COX ARCHITECTS

INFO@MEISTER-COX.COM
 PHONE: 610-375-1331 FAX: 610-375-4555
 1522 PENN AVENUE WYOMISSING, PA 19610
 WWW.MEISTER-COX.COM

SEAL:

ELECTRICAL THIRD FLOOR PLAN - POWER

HOLIDAY INN EXPRESS & SUITES
 INTERSECTION OF HAYNES PLACE & LAMMI RD.
 WILSON, NC 27883

STATUS:	FOR BID
PROJ. DATE:	06/06/2019
PROJ. NO.:	19-116
PRINTED:	06/06/2019
DRAWN BY:	jlm/brm/jpk
CHECKED BY:	brm
SHEET NO.:	E2.5
SCALE:	AS NOTED