2018 APPENDIX B

BUILDING CODE SUMMARY

FOR ALL COMMERCIAL PROJECTS

Assembly (303)

(EXCEPT I AND 2-FAMILY DWELLINGS AND TOWNHOUSES)

Name of Project: HUSTLE HOUSE FITNESS

Address: 560 S STONEWALL STREET Zip Code: 28277

Owner or Authorized Agent: DESTINY WELLENREITER Phone # 704.488.0828

E-Mail: DESTINY@HUSTLEHOUSE.COM

Owned By: ☐ City/County ☑ Private ☐ State

Code Enforcement Jurisdiction: ☐ City ☑ County ☐ State

CONTACT:

Designer	Firm	Name	License #	Phone #	Email
Architectural	OVERCASH DEMMITT ARCHITECTS	STEPHEN OVERCASH	3676	704.332.1615	SOVERCASH@ODA.US.COM
Civil	--	--	--	--	--
Electrical	WAVE ENGINEERING	MICHAEL BENUTA	37734	980.256.7726	INFO@WAVE-ENGINEERING.COM
Fire Alarm	--	--	--	--	--
Plumbing	WAVE ENGINEERING	MICHAEL BENUTA	37734	980.256.7726	INFO@WAVE-ENGINEERING.COM
Mechanical	WAVE ENGINEERING	SANDON DILLARD	46619	980.256.7726	INFO@WAVE-ENGINEERING.COM
Sprinkler-Standpipe	--	--	--	--	--
Structural	--	--	--	--	--
Precast	--	--	--	--	--
Trusses	--	--	--	--	--
Retaining Walls > 5'	--	--	--	--	--
Landscape	--	--	--	--	--
Other	--	--	--	--	--

2018 NC BUILDING CODE: ☐ New Building ☐ Shell/ Core ☑ 1st Time Interior Completions ☐ Addition ☐ Phased Construction – Shell Core

2018 NC EXISTING BUILDING CODE ☐ Prescriptive ☐ Alteration Level 1 ☐ Historic Property ☐ Repair ☐ Alteration Level 2 ☐ Change of Use ☐ Chapter 14 ☐ Alteration Level 3

CONSTRUCTED: (date) CURRENT USE(S) (Ch. 3) :

RENOVATED: (date) PROPOSED USE(S) (Ch. 3) :

OCCUPANCY CATEGORY (Table 1604.5): Current: II Proposed: II

BASIC BUILDING DATA YEAR BUILT: 2001

Construction Type: ☑ I-A ☐ I-B ☐ II-A ☐ II-B ☐ III-A ☐ III-B ☐ IV ☐ V-A ☐ V-B

Sprinklers: ☐ No ☑ Yes ☐ Partial Class ☑ I ☐ II ☐ III ☐ Wet ☐ Dry ☑ NFPA 13 ☐ NFPA 13R ☐ NFPA 13D

Standpipes: ☐ No ☑ Yes

Fire District: ☑ No ☐ Yes Flood Hazard Area ☑ No ☐ Yes

Special Inspections Required ☑ No ☐ Yes

GROSS BUILDING AREA TABLE

FLOOR	EXISTING (SQ FT)	NEW (SQ FT)	SUB-TOTAL
6th Floor	10,823	--	--
5th-19th Floor	13,037	--	--
4th Floor	13,835	--	--
3rd Floor	14,175	--	--
2nd Floor	10,780	--	--
1st Floor A	2,153	--	--
1st Floor B	3,780	2,796 (upfit)	--
TB	1,071	--	--
TOTAL	251,702	2,796 SF	--

ALLOWABLE AREA

Occupancy:

Assembly ☐ A-1 ☐ A-2 ☐ A-3 ☐ A-4 ☐ A-5

Business ☑

Educational ☐

Factory ☐ F-1 Moderate ☐ F-2 Low

Hazardous ☐ H-1 Detonate ☐ H-2 Deflagrate ☐ H-3 Combust ☐ H-4 Health ☐ H-5 HPM

Institutional ☐ I-1 ☐ I-2 ☐ I-3 ☐ I-4

I-1 Condition ☐ 1 ☐ 2

I-2 Condition ☐ 1 ☐ 2

I-3 Condition ☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5

Mercantile ☐

Residential ☐ R-1 ☐ R-2 ☐ R-3 ☐ R-4

Storage ☐ S-1 Moderate ☐ S-2 Low ☐ High-piled ☐ Parking Garage ☐ Open ☐ Enclosed ☐ Repair Garage

Utility and Miscellaneous ☐

Accessory Occupancy Classification(s):

Incidental Uses (Table 509): This separation is not exempt as a Non-Separated Use (see exceptions).

Special Uses (Chapter 4 – List Code Sections):

Special Provisions: (Chapter 5 – List Code Sections):

Mixed Occupancy: ☐ No ☑ Yes Separation : ☐ 1 HR ☐ 2 HR ☐ 3 HR ☐ 4 HR Exception:

☑ Non-Separated Use (508.3)

☐ Separated Use (508.4) - See below for area calculations for each story, the area of the occupancy shall be such that the sum of the ratios of the actual floor area of each use divided by the allowable floor area for each use shall not exceed 1.

Actual Area of Occupancy A / Allowable Area of Occupancy A + Actual Area of Occupancy B / Allowable Area of Occupancy B ≤ 1

-- / -- + -- / -- = -- ≤ 1.00

STORY NO.	DESCRIPTION AND USE	(A) BLDG AREA PER STORY (ACTUAL)	(B) TABLE 506.2 AREA	AREA FOR FRONTAGE INCREASE	(D) ALLOWABLE AREA PER STORY OR UNLIMITED
1	BUSINESS	5,780	9,000	6,750	15,750
1 A	BUSINESS	2,153	9,000	6,750	15,750
2	BUSINESS	10,780	9,000	6,750	15,750
3	R-2	14,175	9,000	6,750	15,750
4	R-2	12,939	9,000	6,750	15,750
5-19	R-2	13,037	9,000	6,750	15,750
20	A-3	1,990	--	--	--
20	R-2	8,691	--	--	--
TOTAL		--	--	--	31,500

1. Frontage area increases from Section 506.2 are computed thus:
   a. Perimeter which fronts a public way or open space having 20 feet minimum width ____ ft (F)
   b. Total Building Perimeter ____ ft (P)
   c. Ratio (F/P) ____ (F/P)
   d. W = Minimum width of public way N/A ____ ft (W)
2. Unlimited area applicable under conditions of Section 507.
3. Maximum Building Area = total number of stories * the building x D (maximum3 stories) (506.2).
4. The maximum area of open parking garages must comply with Table 406.5.4. The maximum area of air traffic control towers must comply with Table 412.3.1.
5. Frontage increase is based on the unsprinklered area value in Table 506.2.

ALLOWABLE HEIGHT

	ALLOWABLE HEIGHT (TABLE 503)	SHOWN ON PLANS	CODE REFERENCE
Building Height in Feet	UL	241'-6"	504.2
Building Height in Stories	UL	20	504.2

1 Provide code reference if the "Shown on Plans" quantity is not based on Table 504.3 or 504.4.

FIRE PROTECTION REQUIREMENTS

BUILDING ELEMENT	FIRE SEPARATION DISTANCE (FEET)	RATING REQ'D	RATING PROVIDED (W - 1HR* RESTRICTION)	DETAIL # AND SHEET #	DESIGN # FOR RATED ASSEMBLY	SHEET # FOR RATED PENETRATION	SHEET # FOR RATED JOINTS
Structural frame, including columns, girders, trusses		3HR	3HR EX	REFERENCE SHELL PERMIT SET FOR DETAILS ON EXISTING CONSTRUCTION RATINGS			
Bearing Walls		3HR	3HR EX				
Exterior		--	--				
North		3	N/A				
East		3	N/A				
West		3	N/A				
South		3	N/A				
Interior		0					
Nonbearing Walls and Partitions							
Exterior walls							
North	>30	0	0				
East	15'-0"	0	0				
West	>30	0	0				
South	18'-11"	1	1 EX				
Interior walls and partitions		0	0				
Floor Construction including supporting beams and joists		2	2 EX				
Roof construction, including supporting beams and joists		1 1/2	2 ROOF EX - 1.5 SECON. EX				
Shafts - Exit Enclosures		2	2 EX				
Shafts - Other		2	2 EX				
Corridor Separation		1/2	1 EX				
Occupancy/Fire Barrier Separation		0	0				
Parity/Fire Wall Separation		1	n/a				
Smoke Barrier Separation		1	1 EX				
Smoke Partition							
Tenant/Dwelling Unit/ Sleeping Unit Separation		1	1 EX				
Incidental Use Separation		2	2 EX				

* Indicate section number permitting reduction

PERCENTAGE OF WALL OPENING CALCULATIONS

Fire Separation Distance (Feet) from Property lines	Degree of openings Protection (Table 705.8)	Allowable area (%)	Actual shown on plans (%)
N X> 30'-0"	UP,S	NO LIMIT	N/A
E 10'-0"< X > 15'-0"	UP,S	45%	<45%
E 20'-0"< X < 25'-0"	UP,S	NO LIMIT	75%
S 10'-0"< X < 15'-0"	UP,S	45%	<45%
S 15'-0"< X < 20'-0"	UP,S	75%	<75%
S 20'-0"< X < 25'-0"	UP,S	NO LIMIT	<75%
W X> 30'-0"	UP,S	NO LIMIT	N/A
--	--	--	--
--	--	--	--
--	--	--	--
--	--	--	--

LIFE SAFETY SYSTEM REQUIREMENTS

Emergency Lighting: ☐ No ☑ Yes

Exit Signs: ☐ No ☑ Yes

Fire Alarm: ☐ No ☑ Yes

Smoke Detection Systems: ☐ No ☑ Yes ☐ Partial

Panic Hardware: ☐ No ☑ Yes

LIFE SAFETY PLAN REQUIREMENTS

Life Safety Plan Sheet #: G-101

☑ Fire and/or smoke rated wall locations (Chapter 7)

☑ Assumed and real property line locations (if not on the site plan)

☑ Exterior wall opening area with respect to distance to assumed property lines (705.8)

☑ Occupancy Use for each area as it relates to occupant load calculation (Table 1004.1.1)

☑ Occupant loads for each area

☑ Exit access travel distances (1017)

☑ Common path of travel distances (Tables 1006.2.1 & 1006.3.2(1))

☑ Dead end lengths (1020.4)

☑ Clear exit widths for each exit door

☑ Maximum calculated occupant load capacity each exit door can accommodate based on egress width (1005.3)

☑ Actual occupant load for each exit door

☐ A separate schematic plan indicating wall and floor/ceiling and/or roof structure is provided for purposes of occupancy separation

☑ Location of doors with panic hardware (1010.1.10)

☐ Location of doors with delayed egress locks and description of release mechanism (1010.1.9.7)

☑ Location of doors with electromagnetic egress locks (1010.1.9.8)

☑ Location of doors equipped with hold-open devices

☐ Location of emergency escape windows

☐ Square footage of each occupancy (202)

☐ The allowable square footage of each occupancy shall be in accordance with the occupancy group(s) as determined by the building official and shall be such that the occupancy group(s) is not changed unless approved by the building official.

☑ No exception or table modification has been utilized regarding the items above

ACCESSIBLE DWELLING UNITS (Section 1107)

TOTAL UNITS	ACCESSIBLE UNITS REQUIRED	ACCESSIBLE UNITS PROVIDED	TYPE A UNITS REQUIRED	TYPE A UNITS PROVIDED	TYPE B UNITS REQUIRED	TYPE B UNITS PROVIDED	TOTAL ACCESSIBLE UNITS PROVIDED
143	143	143	6	6	137	137	143

ACCESSIBLE PARKING (Section 1106)

LOT OR PARKING AREA	TOTAL # OF PARKING SPACES		# OF ACCESSIBLE SPACES PROVIDED			TOTAL # ACCESSIBLE SPACES PROVIDED
	REQUIRED	PROVIDED	REGULAR WITH 5' ACCESS AISLE	VAN SPACES WITH 132" access aisle	VAN SPACES WITH 8' access aisle	
	REFER TO LOW RISE PACKAGE IN SHELL PERMIT SET FOR DEVELOPMENT DETAILS					

PLUMBING FIXTURE REQUIREMENTS (TABLE 2902.1)

USE	WATER CLOSETS			URINALS	LAVATORIES			SHOWERS/ TUBS	DRINKING FOUNTAINS	
	MALE	FEMALE	UNISEX		MALE	FEMALE	UNISEX		REGULAR	ACCESSIBLE
1ST FLOOR REQUIRED	1	1	0	0	1	1	0	0	1	1
PROVIDED	1	1	0	0	1	1	0	2	1	1

SPECIAL APPROVALS

Special approval: (Local Jurisdiction, Department of Insurance, describe below) ORC, DFI, DHHS, ICC, etc.,

N/A

ENERGY SUMMARY BELOW IS EXISTING AND APPROVED UNDER SHELL BUILDING PERMIT

ENERGY REQUIREMENTS:
The following data shall be considered minimum and any special attribute required to meet the energy code shall also be provided. Each Designer shall furnish the required portions of the project information for the plan data sheet. If performance method, state the annual energy cost for the standard reference design vs annual energy cost for the proposed design.

Existing building envelope complies with code: ☐ No ☐ Yes (The remainder of this section is not applicable)

Exempt Buildings: ☐ No ☐ Yes

Climate Zone: ☐ N/A ☑ 3A ☐ 4A ☐ 5A

Method of Compliance: ☐ Energy Code - Prescriptive ☐ ASHRAE 90.1 - Prescriptive ☑ Energy Code - Performance ☐ ASHRAE 90.1 - Performance ☐ Other - Performance (If "Other" specify source here)

THERMAL ENVELOPE: REFER TO MECHANICAL DRAWINGS OF SHELL PERMIT

Roof/Ceiling Assembly (each assembly)
Description of assembly: FULLY ADHERED SINGLE PLY ROOF MEMBRANE OVER TAPERED RIGID INSULATION BOARD (5" MIN) ON CONCRETE ROOF DECK
U-Value of total assembly: MAX U-FACTOR: 0.032
R-Value of Insulation: MIN R-25 CONTINUOUS INSULATION
Skylights in each assembly: NONE
U-Value of skylight: NONE
total square footage of skylights in each assembly: NONE

Exterior Walls (each assembly)
Description of assembly: INTERIOR INSULATION FINISHING SYSTEM: (2) LAYER GYP BD ON R-13 BATT INSULATION W/ VAPOR RETARDER ON INTERIOR SIDE OF EXTERIOR WALL & STICK MOUNT SYSTEMS
U-Value of assembly: MAX U-FACTOR FOR METAL FRAME WALL: 0.064
R-Value of Insulation: MIN R-13 + R-7.5 CONTINUOUS INS FOR MTL FRAMED WALL
Openings (windows & doors with glazing): WINDOWS & DOORS 15% OF ABOVE GRADE WALLS. 6.15% @ 0.35 & 7.74% @ 0.61
U-Value of assembly: 0.064 FOR MTL FRAMED WALL. 0.45 FOR CURTAIN WALL
SHGC: 0.40 FOR PF FACTORS ABOVE 0.5
Visible Transmittance (VT): AVERAGE OF 0.61
R-Value of assembly: 0.77
Walls Below Grade (each assembly)
Description of assembly: C.I.P. CONC WALL (WIGRAN FILL ON PROTECT. BD. ON FULLY ADH WTRPRFNG MEMB @EXT), 5/8" GWB ON 2 1/2" MTL STD ON 2" RIGID INS. BD @ BELOW-GRADE LOCATIONS
U-Value of total assembly: MAX. U FACTOR = 0.104
R-Value of Insulation: MIN. R-9.5 CONTINUOUS INSULATION

Floors Over Unconditioned Space (each assembly)
Description of assembly: 12" P.T. CONCRETE SLAB OVER TRASH ROOM
U-Value of total assembly: MAX U VALUE = 0.064
R-Value of Insulation: MIN. R-12.5 CONTINUOUS INSULATION

Floors Slab on Grade (each assembly)
Description of assembly: 4" CONC SLAB ON MIN. 15 MIL. VAPOR BARRIER ON 6" GRAVEL BASE
U-Value of total assembly: N/A
R-Value of Insulation: R-10 FOR 24" - UNHEATED SLAB
Horizontal / Vertical Requirement
Slab Heated

2018 APPENDIX B

BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS

STRUCTURAL DESIGN

(PROVIDE ON SHEET 1 OR 2 OF THE STRUCTURAL SHEETS)

DESIGN LOADS:

Importance Factors: Wind (I_W) ☐ 1.0 Snow (I_S) ☐ 0.8 ☐ 1.0 ☐ 1.1 ☐ 1.2 Seismic (I_E) ☐ 1.0 ☐ 1.25 ☐ 1.5

Live Loads: Roof: ____ psf Mezzanine: ____ psf Floor: ____ psf

Ground Snow Load: ____ psf

Wind Load: Basic Wind Speed ____ mph (ASCE-7) Exposure Category ☐ N/A ☐ B ☐ C ☐ D

SEISMIC DESIGN CATEGORY: ☐ A ☐ B ☐ C ☐ D

Provide the following Seismic Design Parameters:

Occupancy Category (Table 1604.5) ☐ I ☐ II ☐ III ☐ IV

Spectral Response Acceleration S_S ____ %g S_1 ____ %g

Site Classification (ASCE 7) ☐ A ☐ B ☐ C ☐ D ☐ E ☐ F

Data Source: ☐ Field Test ☐ Presumptive ☐ Historical Data

Basic Structural System (check one)

☐ Bearing Wall ☐ Dual with Special Moment Frame

☐ Building Frame ☐ Dual with Intermediate R/C or Special Steel

☐ Moment Frame ☐ Inverted Pendulum

Analysis Procedure ☐ Simplified ☐ Equivalent Lateral Force ☐ Dynamic

Architectural, Mechanical, Components anchored? ☐ Yes ☐ No

LATERAL DESIGN CONTROL: ☐ Earthquake ☐ Wind

SOIL BEARING CAPACITIES:

Field Test (provide copy of test report) ____ psf

Presumptive Bearing capacity ____ psf

Pile size, type, and capacity ____

2018 APPENDIX B

BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS

MECHANICAL DESIGN

(PROVIDE ON THE MECHANICAL SHEETS IF APPLICABLE)

MECHANICAL SUMMARY

MECHANICAL SYSTEMS, SERVICES, UNITS, AND EQUIPMENT

Thermal conditions: winter dry bulb ____ --; summer dry bulb ____ --

Interior design conditions: winter dry bulb ____ --; summer dry bulb ____ --; relative humidity ____ --

Building heating load ____ --

Building cooling load ____ --

Mechanical Spacing Conditioning System

Unitary: description of unit ____ --; heating efficiency ____ --; cooling efficiency ____ --; size category of unit ____ --

Boiler: Size category, if oversized state reason.. ____ --

Chiller: Size category, if oversized state reason.. ____ --

List equipment efficiencies ____ --

2018 APPENDIX B

BUILDING CODE SUMMARY FOR ALL COMMERCIAL PROJECTS

ELECTRICAL DESIGN

(PROVIDE ON THE ELECTRICAL SHEETS IF APPLICABLE)

ELECTRICAL SUMMARY

ELECTRICAL SYSTEM AND EQUIPMENT

Method of Compliance: ☐ Energy Code - Prescriptive ☐ ASHRAE 90.1 - Prescriptive ☐ Energy Code - Performance ☐ ASHRAE 90.1 - Performance

Lighting Schedule (each fixture type)

Lamp type required in fixture ____ --

Number of lamps in fixture ____ --

Ballast type used in fixture ____ --

Number of ballasts in fixture ____ --

Total wattage per fixture ____ --

Total interior wattage specified vs. allowed (whole building or space by space) ____ --

Total exterior wattage specified vs. allowed ____ --

Additional Efficiency Package Options
(When using the 2018 NCECC, not required for ASHRAE 90.1)

☐ C406.2 More Efficient HVAC Equipment Performance

☐ C406.3 Reduced Lighting Power Density

☐ C406.4 Enhanced Digital Lighting Controls

☐ C406.5 On-Site Renewable Energy

☐ C406.6 Dedicated Outdoor Air System

☐ C406.7 Reduced Energy Use in Service Water Heating

NUMBER AND ARRANGEMENT OF EXITS (TABLE 1021.1)

FLOOR, ROOM, OR SPACE DESIGNATION	MINIMUM NUMBER OF EXITS		TRAVEL DISTANCE		ARRANGEMENT MEANS OF EGRESS	
	REQUIRED	SHOWN ON PLANS	ALLOWABLE TRAVEL DISTANCE	ACTUAL TRAVEL DISTANCE SHOWN ON PLANS	EQ'D DISTANCE BETWEEN EXIT DOORS	ACTUAL DISTANCE SHOWN ON PLANS
BUSINESS	2	2	300'	56.11'* 71'-5"	26'-2"	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--
--	--	--	--	--	--	--
--	--	--	--	--	--	--
--	--	--	--	--	--	--

1 - CORRIDOR DEAD ENDS (SECTION 1018.4)
2 - BUILDINGS WITH SINGLE EXITS (TABLE 1021.2) SPACES WITH ONE MEANS OF EGRESS (TABLE 1015.1)
3 - COMMON PATH OF TRAVEL (SECTION 1014.3)

OCCUPANT LOAD AND EXIT WIDTH (TABLE 1004.1.1)

USE GROUP OR SPACE DESCRIPTION	(A) AREA (sq. ft.) 1	(B) AREA PER OCCUPANT	(C) EGRESS WIDTH PER OCCUPANT		EXIT WIDTH (in) REQUIRED WIDTH (A/B) x C		ACTUAL WIDTH SHOWN ON PLANS	
			STAIR	LEVEL	STAIR	LEVEL	STAIR	LEVEL
BUSINESS	984	100= 9.8 PEOPLE	.3	.2	--	8.06	---	136
EXERCISE	1525	50= 30.5 PEOPLE	--	--	--	--	--	--
--	--	--	--	--	--	--	--	--
--	--	--	--	--	--	--	--	--
--	--	--	--	--	--	--	--	--
TOTAL	--	41 PEOPLE	--	--	--	--	--	--

1 - SEE TABLE 1004.1.1 TO DETERMINE WHETHER NET OR GROSS AREA IS APPLICABLE. SEE DEFINITION "AREA, GROSS" AND "AREA, NET" (SECTION 1002)
2 - MINIMUM STAIRWAY WIDTH (SECTION 1009.1) MIN CORRIDOR WIDTH (SECTION 1018.2) MIN DOOR WIDTH (SECTION 1008.1.1)
3 - MINIMUM WIDTH OF EXIT PASSAGEWAY (SECTION 1023.2)
4 - SEE SECTION 1004.5 FOR CONVERGING EXITS.
5 - THE LOSS OF ONE MEANS OF EGRESS SHALL NOT REDUCE THE AVAILABLE CAPACITY TO LESS THAN 50 PERCENT OF TOTAL REQUIRED (SECTION 1005.1)
6 - ASSEMBLY OCCUPANCIES (SECTION 1029)
7 - SPACES WITHIN OCCUPANCIES OR USE GROUPS SHALL BE CALCULATED INDEPENDENTLY. (EX. LOBBIES, LOUNGES, BREAKROOMS, CONFERENCE ROOMS)

Order Plans @ WWW.LDI.line.com

ODA
overcash demmitt
2010 south tryon st. suite 1a
charlotte north carolina 28203
office. 704.332.1615
web.www.odarch.com

STEPHEN F. OVERCASH
REGISTERED ARCHITECT
NORTH CAROLINA
06.27.2019

Hustle House

ODA Project No. 183324

Charlotte, NC

FOR CONSTRUCTION

06.28.2019

REVISIONS

No.	Description	Date
	FOR CONSTRUCTION	06.28.19

CODE SUMMARY

G-001