

1 LIFE SAFETY PLAN - GROUND FLOOR PLAN
BUILDING ONE

Order Plans @ WWW.LDILine.com

TRUSS SIGNAGE REQUIREMENTS

- MALTESE CROSS MEASURING 8" HORIZONTALLY AND 8" VERTICALLY, OF A BRIGHT RED REFLECTIVE COLOR, DESIGNED IN ACCORDANCE WITH NFPA 101, 2009 EDITION.
- THE APPROVED SYMBOL SHALL BE PLACED WITHIN 24" TO THE LEFT OF THE MAIN ENTRY DOOR AND:
 - BE PERMANENTLY ATTACHED TO THE FACE OF THE STRUCTURE ON A CONTRASTING BACKGROUND OR
 - BE MOUNTED ON A CONTRASTING BASE MATERIAL WHICH IS THEN PERMANENTLY ATTACHED TO THE FACE OF THE STRUCTURE.
- THE DISTANCE ABOVE THE GRADE, WALKING SURFACE, OR THE FINISHED FLOOR TO THE BOTTOM OF THE SYMBOL SHALL BE NOT LESS THAN 4 FEET (48 INCHES).
- THE DISTANCE ABOVE THE GRADE, WALKING SURFACE, OR FINISHED FLOOR TO THE TOP OF THE SYMBOL SHALL BE NOT MORE THAN 6 FEET (72 INCHES).

LIFE SAFETY LEGEND



SCALE: 1/16" = 1'-0"

- INDICATES 3 HOUR RATED WALL
- INDICATES 2 HOUR RATED WALL
- INDICATES 1 HOUR RATED WALL
- INDICATES PATH OF TRAVEL (250 FEET MAXIMUM - PER IBC 1014.2)
INDICATES COMMON PATH OF TRAVEL (125 FEET MAXIMUM - PER IBC 1014.3)
- INDICATES EXIT SIGN
- INDICATES REQUIRED PANIC HARDWARE AT DOORS (PER IBC 1008.1.10)
- INDICATES HORIZONTAL EXIT
- INDICATES FIRE EXTINGUISHER - TYPE A-1 IN SEMI-RECESSED FIRE RATED CABINET. DISTANCE BETWEEN CABINETS 75'-0" MAX. MOUNT TOP OF CABINET NOT MORE THAN 5'-0" A.F.F.; BOTTOM NOT LESS THAN 4" A.F.F.

NOTE: FIRE EXTINGUISHERS WILL ALSO BE PLACED IN EACH UNIT.

POSTING OF OCCUPANT LOAD
PER IBC 1004.3

EVERY ROOM OR SPACE THAT IS AN ASSEMBLY OCCUPANCY SHALL HAVE THE OCCUPANT LOAD OF THE ROOM OR SPACE POSTED IN A CONSPICUOUS PLACE, NEAR THE MAIN EXIT OR EXIT ACCESS DOORWAY FROM THE ROOM OR SPACE. POSTED SIGNS SHALL BE OF AN APPROVED LEGIBLE PERMANENT DESIGN AND SHALL BE MAINTAINED BY THE OWNER OR AUTHORIZED AGENT. POSTED OCCUPANCY NUMBER SHALL NOT EXCEED ONE OCCUPANT PER SEVEN SQUARE FEET (IBC 1004.2) OR BE GREATER THAN THE NUMBER OF OCCUPANTS THAT CAN BE ACCOMMODATED BY THE SPACE'S NARROWEST EGRESS COMPONENT (IBC 1005)



Lyric at Norton Commons
Prospect, Kentucky

Bristol Development Group
381 Mallory Station Rd, Suite 204
Franklin, TN 37067

charlan • brock
associates

architects • planners

1770 fennell street
maitland florida 32751-7208
407.660.8900 | f.407.875.9948
www.cbarchitects.com

LIFE SAFETY PLAN
(00) BUILDING ONE - GROUND FLOOR PLAN

date: 06/04/2019
job #: 3789.15
drawn by: EGR, JAC, TQT
reviewed by: CBA
issue history:
Δ Date