


PROVIDE 4" CLASS III MANUAL WET STANDPIPE, AND BFC CONTROL VALVE WITH TAMPER SWITCH. PROVIDE 2 1/2" FHV (W NATIONAL STANDARD THREADS) AT 48" AFF WITH 2 1/2x1 1/2" REDUCER, CAP AND CHAIN. PROVIDE 24x24 ACCESS PANEL.

SPRINKLER ZONE 1A
 PROVIDE 2 1/2" SYSTEM CONTROL VALVE, TAMPER SWITCH, AND FLOW SWITCH.

PROVIDE 4" CLASS III MANUAL WET STANDPIPE, AND BFC CONTROL VALVE WITH TAMPER SWITCH. PROVIDE 2 1/2" FHV (W NATIONAL STANDARD THREADS) AT 48" AFF WITH 2 1/2x1 1/2" REDUCER, CAP AND CHAIN. PROVIDE 24x24 ACCESS PANEL.

1 PARTIAL BUILDING PLAN D - (01) FIRST FLOOR - FIRE PROTECTION PLAN
 SCALE: 1/8" = 1'-0"
 18025-F-BLDG



Common North, Prospect, KY
 KY
 MiGre
 Engineers LLC
 780 FLORIDA CENTRAL PARKWAY
 SUITE 224
 LONGWOOD, FL 32750
 PH: 407.336.7999
 PROJECT #: 18025

Lyric at Norton Commons
 Prospect, Kentucky
 Bristol Development Group
 381 Malloy Station Rd, Suite 204
 Franklin, TN 37067

charlan • brock
 associates
 architects • planners
 1770 fennell street
 maitland florida 32751-7208
 407.660.8900 • 407.875.5948
 www.cbaarchitects.com

PARTIAL BUILDING
 PLAN D - 1ST FLOOR
 FIRE PROTECTION
 PLAN
 date: 06-04-2019
 job no: 3789.16
 drawn by: GNIK
 reviewed by: GNIK
 file: 18025-F-BLDG
 issue history:
 07-03-2019
F1.11D

Order Plans @ WWW.DIline.com

Vertical text on the far left edge of the page, likely a project or drawing identifier.

Vertical text on the far right edge of the page, likely a disclaimer or copyright notice.