


- GENERAL MECHANICAL NOTES**
- M.C. TO LABEL ALL EXISTING AND NEW HEAT PUMPS AND AIR HANDLERS WITH ENGRAVED NAMEPLATE.
 - M.C. TO PUSH ALL CONDENSATE LINES AND VERIFY THEY ARE FULLY FUNCTIONAL.
 - M.C. TO FURNISH AND INSTALL CONDENSATE PUMPS WITH PUMP CONDENSATE TO NEAREST ANTIOR SINK OR DRAIN PAN ON THE FIRST FLOOR AND NEAREST HUB DRAIN ON SECOND FLOOR.
 - M.C. TO COORDINATE NEW THERMOSTAT LOCATIONS WITH DEMOUNTABLE PARTITION SUPPLIER.
 - M.C. TO REMOVE INDIVIDUAL THERMOSTAT SWITCH AT EACH THERMOSTAT AND REWIRE TO SHUNT CIRCUIT SHUT-DOWN SWITCH FOR ALL AHU'S. LEAD AT THERMOSTAT ANNUNCIATOR PANEL, FURNISH AND INSTALL THERMOSTAT RELAYS, ETC. FOR APPROPRIATE OPERATION.
 - M.C. TO VERIFY EXISTING THERMOSTAT LOCATIONS THROUGH RATE ASSEMBLIES WHEN APPLICABLE.
 - M.C. TO THOROUGHLY CLEAN ALL EXHAUST DUCTWORK AND RELOUVERS PRIOR TO CONNECTING TO NEW. REPAIR AS NEEDED.

Order Plans


LOWER LEVEL MECHANICAL PLAN
SCALE: 1/4" = 1'-0"



222 cloister court
chapel hill, nc 27514
919.401.8586
www.cra-ae.com



Renovation of
920 Corporate Drive
Orange County Schools
920 Corporate Drive
Hillsborough, North Carolina



no.	revisions

The user of these plans and specifications shall be responsible for providing all information necessary for the proper construction of the work. The user shall verify the accuracy of all information provided in these plans and specifications. The user shall be responsible for obtaining all necessary permits and approvals. The user shall be responsible for providing all necessary information for the proper construction of the work. The user shall be responsible for providing all necessary information for the proper construction of the work.

drawn **DM** checked **WRM**

LOWER LEVEL MECHANICAL PLAN

sheet

M2.1

project no. 2019016.00

date 7.22.19