

1 ROOF PLAN - MECHANICAL
1/4" = 1'-0"

GENERAL NOTES:


- A. MOUNT ALL HVAC EQUIPMENT ON ROOF PER DETAILS ON SHEET MS.1.
- B. CONTRACTOR TO MAINTAIN MINIMUM MANUFACTURER RECOMMENDED SERVICE CLEARANCE AROUND EACH PIECE OF EQUIPMENT.
- C. CONTRACTOR TO ENSURE A MINIMUM OF 10' CLEARANCE BETWEEN ALL OA INTAKES AND ANY EXHAUST FANS, VENTS, FLUES, ETC.
- D. CONTRACTOR TO ENSURE ALL MECHANICAL EQUIPMENT IS INSTALLED A MINIMUM OF 10' FROM THE ROOF EDGE.
- E. COORDINATE EXHAUST LOCATION OF RTUS WITH STRUCTURE TO ENSURE DUCT DROPS ARE LOCATED WITHIN TRUSS.

CODED NOTES: #

- 1. NOT USED.
- 2. PLUMBING VENT PIPING SHOWN FOR REFERENCE. MAINTAIN A MINIMUM OF 10'-0" CLEARANCE TO ANY OA INTAKE.
- 3. RTU'S MOUNTED ON CHIMNEY ROOF. REFER TO DETAIL ON SHEET MS.1 FOR FURTHER INFORMATION.
- 4. ZONE LOCATED 10' FROM EDGES OF CHIMNEY ROOF SHOWN FOR REFERENCE ONLY.
- 5. WATER HEATER FLUE PENETRATIONS SHOWN FOR REFERENCE.

red
architecture + planning
174 east long street
suite 300
columbus, ohio 43215
tel: 614.487.8770
fax: 614.487.8777

PROPRIETARY INFORMATION NOTICE
THESE PROTOTYPICAL DOCUMENTS MAY REQUIRE REVISIONS TO CONFORM TO LOCAL, STATE, AND FEDERAL CODES, ORDINANCES OR OTHER CONDITIONS. THE DESIGN CONCEPTS EMBODIED IN THESE DOCUMENTS ARE SPECIFICALLY FOR THIS PROJECT. INFORMATION CONTAINED HEREIN REMAINS THE SOLE PROPERTY OF ARBY'S RESTAURANT GROUP. IS CONFIDENTIAL AND PROPRIETARY AND IS NOT TO BE COPIED, REPRODUCED, DISCLOSED OR OTHERWISE TRANSMITTED TO OTHER PARTIES IN ANY FORM WHATSOEVER WITHOUT THE EXPRESS WRITTEN CONSENT OF ARBY'S RESTAURANT GROUP.



ARBY'S RESTAURANT
INSPIRE WORKSMART 2400
2385 LEN PATTERSON RD
FORT MILL, SC 29708
FOR
BRUMMIT RESTAURANT GROUP, LLC
40 SEMINOLE STREET, ASHEVILLE, NC 28803

PROJECT NUMBER:		ARF149
ISSUE	DATE	
OWNER REVIEW	AUG 7, 2019	

ROOF PLAN
MECHANICAL

SHEET:
M3.1

Order Plans @ www.LDILine.com

NOT FOR CONSTRUCTION, FOR REFERENCE ONLY