

CONTROL INFORMATION		ELECTRICAL CONTROL PACKAGE		USER INTERFACE		FANS CONTROLLED			
MARK	MODEL	LOCATION	TYPE	LOCATION	MARK	TYPE	VOLT	PHASE	HP
M-4F - EC	XFCC	SHIP LOOSE	SWITCHES	ON CONTROL PACKAGE	M-4E - MAU1	SUPPLY	208	3	5
					M-4C - EF1	EXHAUST	208	3	2
					M-4C - EF2	EXHAUST	208	3	2

**CONTROL FEATURES**  
 CONTROL PANEL ENCLOSURE - 16 GA 300 SERIES STAINLESS STEEL ENCLOSURE (NEMA-1) - DIMENSIONS 18 X 20 X 6  
 STARTERS PROVIDED IN CONTROL PANEL - QTY 2  
 2 POSITION LIGHT SWITCH - QTY 1  
 2 POSITION (HEAT) SWITCH - QTY 1  
 2 POSITION FAN SWITCH - QTY 1  
 -FACTORY MOUNTED EXHAUST TEMPERATURE SENSORS - QTY 2  
 TURN ON EXHAUST IN FIRE  
 DPDT RELAY WITH SUPPLY - QTY 1  
 LIGHTS OUT IN FIRE  
 MUA INTERFACE  
 POWER FOR SHUNT TRIP  
 THERMAL OVERLOADS IN CABINET

PROJECT: 5/31/2019  
 MARK: M-4F - EC  
 ACCUREX KS NE WESTERN MO  
 BENJAMIN.OBRIEN@ACCUREX.COM  
 (816)888 9742

ACCUREX  
 BAD DADDYS - MARIETTA GA

ACCUREX

Consultant:  
 ARWIN PRIEST P.E., P.Eng.  
 MECHANICAL \* ENGINEER \* ELECTRICAL  
 242 MOUNTAIN CLOUD CIRCLE  
 HIGHLANDS RANCH, CO 80126  
 (303) 898-2664 pc3744@gmail.com

5280 Engineering  
 www.DesignMEP.com  
 720-320-7744 rpg@5280engineering.com

DATE :

**Bad Daddy's BURGER BAR**  
 GOOD TIMES RESTAURANTS, INC.  
 141 Union Blvd, Suite 400  
 Lakewood, CO 80228  
 tel: (303) 384-1430

**BAD DADDY'S BURGER BAR**  
 "SANDY PLAINS"  
 3460 SANDY PLAINS RD  
 SUITE 110  
 MARIETTA, GA 30062

Issue Record:  
 06.07.2019 FOR PLAN REVIEW  
 08.01.2019 BAR FIXT. TO GREASE WST.  
 08.28.2019 QCR

Drawn:  
 DRAWN BY: F Long  
 Checked:  
 CHFCCKFD BY: R Blank  
 Project No.  
 PROJECT#: 2019-041  
 Consultant:  
 ACCUREX HOOD DESIGN

