

SIGN: VERIFY LOCATION WITH OWNER PRIOR TO INSTALLATION. CONTROL WITH PHOTOCELL. PROVIDE LOCAL DISCONNECT PER CODE.

SIGN: VERIFY LOCATION WITH OWNER PRIOR TO INSTALLATION. CONTROL WITH PHOTOCELL. PROVIDE LOCAL DISCONNECT PER CODE.

SIGN: VERIFY LOCATION WITH OWNER PRIOR TO INSTALLATION. CONTROL WITH PHOTOCELL. PROVIDE LOCAL DISCONNECT PER CODE.

REFER TO ARCHITECTURAL ELEVATIONS FOR ELECTRICAL ROUGH-IN LOCATIONS

DISFUNCTION DIMMING SWITCH AND VARIABLE SPEED SWITCH TO CONTROL CEILING FANS

SIGN: VERIFY LOCATION WITH OWNER PRIOR TO INSTALLATION. CONTROL WITH PHOTOCELL. PROVIDE LOCAL DISCONNECT PER CODE.

- KEY NOTES:**
- 1 LIGHTS AT WALK-IN COOLER / FREEZER FURNISHED WITH LIGHTING PACKAGE, INSTALL BY ELECTRICAL CONTRACTOR.
 - 2 PROVIDE WALL VACANCY SWITCH WITH OCCUPANCY SENSOR AND MANUAL ON/OFF SWITCH.
 - 3 CEILING OCCUPANCY SENSOR. UTILIZE WATTSTOPPER DT-300 DUAL TECHNOLOGY CEILING SENSOR OR EQUAL.
 - 4 3 GANG J. BOX MARLIN LIGHTING CONTROL STATION (RMSB KEY PANEL) FOR DINING AREA.


NOTE: CONNECT ALL BATTERY PACK EXIT LIGHTS AND BATTERY PACK EMERGENCY LIGHTS TO LOCAL LIGHTING CIRCUIT HEAD OF SWITCH.

NOTE ON THE OUTSIDE EMERGENCY LIGHTS
EXCEPT FOR THE NEW PATIO THE OUTSIDE EMERGENCY LIGHTS ARE PROVIDED AS PART OF OUTSIDE BUILDING LIGHTING BY THE LANDLORD.


LIGHTING PLAN

Order Plans

www.dine.com



08.28.2019



GOOD TIMES RESTAURANTS, INC.
141 Union Blvd, Suite 400
Lakewood, CO 80226
303-384-1430

BAD DADDY'S BURGER BAR
"SANDY PLAINS"
3460 SANDY PLAINS RD N.E.
SUITE 110
MARIETTA, GA 30062

Issue Record:

6.7.2019	FOR PLAN REVIEW

Revisions:

08.28.2019	QCR

Drawn:
DRAWN BY: VR

Checked:
CHECKED BY: VR

Project No.
PROJECT#: 19-213

Contractor:
LIGHTING PLAN

E2.0