Design No. X526

Ratings---1, 2, 3 and 4 Hr.







SNAP-LOCK





PITTSBURG SEAM

LAP



LAP JOINT

1. **Steel Column**---Min sizes of W shape and tubular steel columns in the AISC Steel Construction Manual as shown under Item 2.
2. **Wallboard, Gypsum**---Any 5/8 in. thick or 1/2 in. thick wallboard bearing the Underwriters Laboratories Inc. Fire Resistance Classification Marking. Min total thicknesses of layers in inches for the various ratings and min column sizes are as follows:

W Shape Columns

Designation	Outside Dimensions (In.)	Min Column Size Flange Thickness (In.)	Min Column Size Web Thickness (In.)	(In.²) Area	Rating (Hr) 1	2	3	4
					Total Thickness Of Layers Of Wallboard (In.)			
W4x13	4-1/8x4	0.345	0.280	3.82	1	1-1/2	2-1/4	—
W6x15.5	6x6	0.260	0.235	4.56	1	1-1/2	2-1/4	3-1/8
W10x49	10x10	0.558	0.340	14.4	1/2	1-1/8	1-7/8	2-1/2

Tubular Shape Columns

Designation	Outside Dimensions (In.)	Min Column Size Wall Thickness (In.)	(In.²) Area	Rating (Hr) 1	2	3	4
				Total Thickness Of Layers Of Wallboard (In.)			
TS4x4x0.188	4x4	0.188	2.74	1	1-5/8	2-1/2	—
TS8x8x0.250	8x8	0.250	7.48	5/8	----	----	----

Applied in layers as shown in above illustration. Each layer held together with paper masking adhesive tape during erection to allow placement of succeeding layers.

For column ratings of 2 hr or less, one layer of wallboard may be applied to the outer surface of steel cover. Boards applied vertically, without horizontal joints, attached to cover with screws located 1 in. from the board edge and 8 in. OC.

See **Wallboard, Gypsum (CKNX)** category for names of manufacturers.

2A. **Wallboard, Gypsum***---As an alternate to Item 2, 3 in. thick applied as described in Item 2.

Canadian Gypsum Company---ULTRACODE or Type SHX.
United States Gypsum Co.---ULTRACODE or Type IP-X3.
Yeso Panamericano SA de CV---ULTRACODE or Type SHX-3.

3. **Steel Covers---For seamed joints**---0.020 in. min thickness (No. 24 MSG) uncoated, galv, or stainless steel, for column ratings of 3 hr or less. For 4 hr ratings, only stainless steel cover may be used. Covers consist of two L-shaped sections with Snap-Lock or Pittsburgh sheet steel joints. Width to be determined on the basis of protection thickness and column size. Length of sections to provide 1/8 in. clearance per lineal foot of column length between ends and any restraint.

   For lapped joints---(Max ratings 2 hr)---No. 22 MSG (0.027 in. thick) uncoated or galv steel. Fasteners used at laps to be No. 8 by 1/2 in. steel sheet metal screws spaced a max of 12 in. O.C. Other details to be the same as those stated for seamed joints as shown above.
4. **Corner Bead**---For columns with outer layer of wallboard attached to outside surface of metal cover, No. 28 MSG galv steel, 1-1/2 in. legs corner beads attached to wallboard with screws spaced 12 in. O.C.
5. **Screws**---For columns with outer layer of wallboard attached to outside surface of metal cover, self-drilling Phillips bugle head, 1 in. long screws for 1/2 or 5/8 in. thick wallboard (1-1/4 in. long screws for 3/4 in. thick wallboard) are used to attach wallboard to steel cover, and corner bead to wallboard.
6. **Sodium Silicate Solution**---(Not shown, optional)---Used to adhere one layer of wallboard to inside of steel cover prior to assembly.
7. **Finishing System**---(Not shown)---Joint compound applied over corner beads to a thickness of 1/16in

*Bearing the UL Classification Marking

Fire Resistance Ratings - ANSI/UL 263

See General Information for Fire Resistance Ratings - ANSI/UL 263

Design No. X650

Revised July, 2002

Ratings - 1, 1-1/2, 2 and 3 Hr. (See Item 2)



1. **Steel Column** — Wide flange, W8 or steel pipe 10 in. OD and heavier, square or rectangular tubing, Columns shall be floor to floor, bolted ends and at 12 in. intervals shall be enclosed with a prefabricated sleeved mesh grating.

2. **Wood, and Intumescent Coatings*** — Coating series, thickness and wood support shall be as follows for designated thickness. See latest applicable classification listing for thicknesses and applicable rating.

FOR STEEL PIPE

Steel Size	A/P	Hp/t	1 Hr		1-1/2 Hr		2 Hr	
			in.	mm	in.	mm	in.	mm
10" A53-A-53/53	0.29	4.95	0.140	3.56				
10" S-5-0.675	0.29	4.44	0.140	3.56	0.249	6.327	0.345	8.763
10" S-265-H-5	0.47	285	0.140	3.56	0.249	6.327	0.345	8.763

FOR SQUARE AND RECTANGULAR STEEL TUBE

Shape Size	A/P	Hp/t	1 Hr		1-1/2 Hr		2 Hr		3 Hr	
			in.	mm	in.	mm	in.	mm	in.	mm
STC 6x6x0.125	0.38	48	0.140	3.56						
STC 6x6x1/4	0.38	48	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 10x10x1/4	0.29	75	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 6x6x3/8	0.38	48	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 6x6x1/2	0.38	48	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 10x10x1/2	0.29	75	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 6x6x5/8	0.38	48	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 10x10x5/8	0.29	75	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 6x6x3/4	0.38	48	0.140	3.56	0.249	6.350	0.35	8.900	0.45	
STC 10x10x3/4	0.29	75	0.140	3.56	0.249	6.350	0.35	8.900	0.45	

ISOLATEK CO STP — Type 300 Intumescent Fire Resistive Coating for Exterior Exposure, Type 400 Intumescent for Exterior General Purposes, Type 900 Intumescent for Exterior Use with Top Coat as described in Item 3.

ISOLATEK INTERNATIONAL — Type Specification 400 and Type 900 Intumescent for Interior General Purposes, Type Specification 400 and Type 900 Intumescent for Interior Exposure Purpose. Type Specification 900 Grade Type 900.4, Intumescent for Exterior use with Top Coat as described in Item 3.

3. **Top Coat** — Type Specification 7 (DTM200), and Type (DTM200) required for Exterior Use, applied at a minimum dry film thickness of 1.4 mils (0.04 mm) over the intumescent material. See Classification Information for the Grade and Identification Marking (Color), designers, Isolatek International, for mixing instructions.

Investigated for Interior General Purposes.

*Bearing the UL Classification Mark

ISOLATEK

ONLINE CERTIFICATIONS DIRECTORY

BXUV.X750

Fire Resistance Ratings - ANSI/UL 263

See General Information for Fire Resistance Ratings - ANSI/UL 263

Design/System/Construction/Assembly Usage Disclaimer

- Information having restrictions should be considered in all cases to the many economic requirements covering fire symbolism and use of all types of specified products, equipment, systems, devices and materials.
- Authorities having jurisdiction should be consulted before construction.
- Fire resistance ratings are determined by tests conducted in accordance with procedures promulgated by UL or in accordance with appropriate alternative tests. The published information cannot cover all the applications and circumstances encountered in the field.
- When additional information is required, users should contact UL at the address shown on the report covering the product concerned or visit the UL website at http://www.ul.com for assistance. For additional general information on UL and its certification services, users should visit the UL website at http://www.ul.com/certification.
- Only products which bear UL's Mark are recognized as classified under our certification program.

Fire Resistance Ratings - ANSI/UL 263

See General Information for Fire Resistance Ratings - ANSI/UL 263

Design No. X750

Revised [illegible]

Ratings - 1, 1-1/2, 2, 3 and 4 Hr.





1. **Steel Column, Steel Pipe or Steel Tube** — Wide flange steel columns ... or steel tubular pipe (10" or less) square or rectangular tubing (HSS) conforming to ASTM A500, Grade B.

2. **Spray-Applied Fire Resistive Materials*** — Applied by machine with a fan and spraying in one or more coats to the required thickness. Any method of density, adhesion, and design thickness. See General Material.

The thicknesses of spray-applied fire resistive materials required for various fire resistance ratings of various sections or hollow rectangular columns are shown in the table below.

Column Size	W/D	Min Thickness in. 1 Hr	1-1/2 Hr	2 Hr	3 Hr	4 Hr
W4x13	0.35	1 3/8	1 5/8	2 1/16	3 1/8	
W6x15.5	0.43	1 3/8	1 5/8	2 1/16	3 1/8	
W10x49	0.89	1 3/8	1 5/8	2 1/16	3 1/8	
W8x35	0.71	1 3/8	1 5/8	2 1/16	3 1/8	
W8x24	0.48	1 3/8	1 5/8	2 1/16	3 1/8	
W8x67	1.37	1	1 3/16	1 5/8	2 1/16	
HSS6x6	0.9	1 3/16	1 3/16	1 3/8	1 3/4	
HSS10x8	0.9	1	1	1 3/16	1 3/4	
HSS12x8	0.9	1	1	1 3/16	1 3/4	

*As the thickness of spray-applied fire resistive materials required for various fire resistance ratings of certain sections with steel ages or types are shown on the tables below:

W6 Shapes Size/Lbs	A/P	1 Hr	1-1/2 Hr	Min Fillet In. 2 Hr	3 Hr	4 Hr
W4x13/20	0.47	1 1/16	1	1 5/8	2 1/16	2 5/8
W4x13/25	0.47	1	1 1/16	1 5/16	2 1/16	2 11/16
W4x13/30	0.47	1	1 1/16	1 5/16	2 1/16	2 7/8
W4x13/35	0.47	1	1	1 5/16	2 1/16	2 7/8
W4x13/5	0.44	1	1	1 5/16	2 1/16	2 7/8
W4x13/40	0.44	1	1	1 5/16	2 1/16	2 7/8

*As an alternate to the table above, the required thickness of Spray-Applied Fire Resistive Materials is as applied to all surfaces of the steel sections (Items 2) all rating periods may be determined from the following equation:

$$h = \frac{R}{(0.5W/D) + 49}$$

Where:

h = Spray-applied fire resistive materials thickness in inches (to 1/16 in. increments) for the required fire rating,

R = Fire resistance rating in minutes (60 min/hrs.),

D = Equivalent heated perimeter of the steel column in inches,

W = Nominal weight of steel per foot,

W/D = 0.9 to 0.45

*As the perimeter of a rectangular tube or pipe may be determined by:

$$A/P = \frac{1}{(2d + 2b - 1.5t)}$$

$$d + b$$

Where:

d = The outer dimension of the steel pipe (in.)

b = The wall thickness of the pipe (in.)

t = The wall thickness of the tube (in.)

ISOLATEK INTERNATIONAL — Type 300, Type 3000, Type 3005 or Type 50.

2A. **(As an alternate to Item 2) Spray-Applied Fire Resistive Materials*** — Applied by machine with nozzle and spraying in one or more coats to the thicknesses shown below, to steel surfaces which are clean and free of dirt, loose scale, and oil. The average wet mix unit-mixed density of 17.1 and 22 lbs. respectively, for Type 300/50. The average wet mix unit-mixed density of 22 and 28 lbs. respectively, for Type 400. For method of density determination, see Density Determination Section, Sprayed Material.

The min thickness of Spray-Applied Fire Resistive Materials required for various fire resistance ratings is as shown in Item 2.

ISOLATEK INTERNATIONAL — Type 300/50 or Type 400.

2B. **(As an alternate to Item 2 and 2A) — Spray-Applied Fire Resistive Materials*** — Prepared for mixing with water and applied by spray density, dry, to the thicknesses shown below, to steel surfaces which are free of dirt, oil or rust. The average wet mix unit-mixed density of 17 lbs. per cubic foot and the average dry density of 15 lbs. per cubic foot. For method of density determination, see Density Determination Section, Sprayed Material.

*As min thickness of Spray-Applied Fire Resistive Materials required for various fire resistance ratings is shown in Item 2.

ISOLATEK INTERNATIONAL — Type 200.

3. **Metal Lath** — Optional (for cement application) — 3.4 lbs/s.y. gal. or painted expanded steel lath. Lath shall be secured to the steel framework on 6in. (6.35mm) steel wire spaced vertically at 6 in. (6...

*Bearing the UL Classification Mark

ISOLATEK
Corporate Headquarters

Isolatek International
41 Furnace Street
Stanhope, NJ 07874
Telephone: 973.347.1200

March 18, 2019

Mr. Yi "Tom" Ho
Phillips Partnership
5901 Peachtree Dunwoody Road
Atlanta, GA 30328

Re: Fairfield Inn – Cape Coral, FL 33909

Dear Mr. Ho:

This is regarding the application of CAFCO® SprayFilm® Intumescent Coatings for the above referenced project.

It is our understanding that wood nailers are running directly above structural steel beams that support floor-ceiling assembly. The assembly is as shown in *Figure 1* shown below. The structural steel beams require a fire resistive rating that is in accordance with ANSI/ UL 263, ASTM E119. You have inquired as to a fire protection method that would achieve the desired fire resistive rating for the structural steel beams since there are no UL Designs that conform to above described assembly.



Figure 1 – Beam supporting wood nailer.

Based on the information presented above, we propose that the structural steel beams supporting ceiling assembly be treated using column thicknesses to achieve the desired fire resistive rating.

ISOLATEK Brand

www.isolatek.com

ISOLATEK Brand

X868-Y814

Structural Steel Support Tube Columns

CAFCO® SprayFilm® MK 3 and MK 4 & ISOLATEK® Type MK 3 and MK 4

ASTM Desig.	Wall Thk	A/P	Metric Desig.	MD	Hp/t	1-Hour	1-1/2 Hour	2-Hour	3-Hour
30 x 30	5/8	0.61	762 x 762 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
28 x 28	5/8	0.65	711 x 711 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
26 x 26	5/8	0.61	660 x 660 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
24 x 24	5/8	0.61	610 x 610 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
	1/2	0.48	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
22 x 22	5/8	0.61	559 x 559 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
20 x 20	5/8	0.61	508 x 508 x 15.9	113.8	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
18 x 18	5/8	0.86	457 x 457 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
16 x 16	5/8	0.49	406 x 406 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
14 x 14	5/8	0.61	356 x 356 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
12 x 12	5/8	0.86	305 x 305 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
10 x 10	5/8	0.86	254 x 254 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.37	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
8 x 8	5/8	0.86	203 x 203 x 15.9	113	66.2	0.074	0.099	0.164	0.327
	1/2	0.49	x 12.7	90.1	84.9	0.074	0.099	0.164	0.327
	3/8	0.36	x 9.5	70.3	112.4	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
7 x 7	1/2	0.48	178 x 178 x 12.7	67.6	95.4	0.074	0.127	0.207	NR
	3/8	0.35	x 9.5	68.0	118.8	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
6 x 6	1/2	0.48	152 x 152 x 12.7	67.4	80.4	0.074	0.127	0.207	NR
	3/8	0.35	x 9.5	68.0	118.8	0.074	0.173	0.286	NR
	5/16	0.30	x 7.9	57	138.7	0.074	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
5 x 5	1/2	0.48	127 x 127 x 12.7	65.5	62.5	0.074	0.127	0.207	NR
	3/8	0.35	x 9.5	68.0	118.8	0.074	0.173	0.286	NR
	5/16	0.28	x 7.9	53.1	143.5	0.084	0.218	0.353	NR
	1/4	0.24	x 6.4	45.6	173.4	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR
4 x 4	1/2	0.48	102 x 102 x 12.7	65.8	64.6	0.074	0.127	0.207	NR
	3/8	0.34	x 9.5	64.6	122.4	0.084	0.218	0.353	NR
	5/16	0.28	x 7.9	53.1	143.5	0.084	0.218	0.353	NR
	1/4	0.23	x 6.4	43.7	180.8	0.104	0.252	0.400	NR
	3/16	0.18	x 4.8	34.2	231.1	0.165	0.307*	0.538*	NR

Note: A/P, MD & Hp/t radius based on design formula. Note: * = Thickness derived from UL Design X818

Note: All thicknesses are expressed in inches. To convert to kilos, multiply by 10kg. To convert to mm, multiply by 25.4

BEAMS- INDIVIDUAL FIRE PROTECTION



B1 1 HR. PROTECTION - INTUMESCENT PAINT

NOTES: FIRE-RESISTANCE RATING OF STRUCTURAL MEMBERS

A. COLUMN PROTECTION (S 704.2 FBC 2017)
WHERE COLUMNS ARE REQUIRED TO BE FIRE RESISTANCE RATED, THE ENTIRE COLUMN SHALL BE PROVIDED INDIVIDUAL ENCASEMENT PROTECTION BY PROTECTING IT ON ALL SIDES FOR THE FULL COLUMN LENGTH, INCLUDING CONNECTIONS TO OTHER STRUCTURAL MEMBERS, WITH MATERIALS HAVING THE REQUIRED FIRE-RESISTANCE RATING. WHERE THE COLUMNS EXTENDS THROUGH A CEILING, THE ENCASEMENT PROTECTION SHALL BE CONTINUOUS FROM THE TOP OF THE FOUNDATION OR FLOOR/CEILING ASSEMBLY BELOW THROUGH THE CEILING SPACE TO THE TOP OF THE COLUMN.

B. PROTECTION OF THE PRIMARY STRUCTURAL FRAME OTHER THAN COLUMNS (S 704.3 FBC 2017)
MEMBERS OF THE PRIMARY STRUCTURAL FRAME OTHER THAN COLUMNS THAT ARE REQUIRED TO HAVE A FIRE-RESISTANCE AND SUPPORT MORE THAN TWO FLOORS OR ONE FLOOR AND ROOF, OR SUPPORT A LOAD-BEARING WALL OR A NON-LOAD-BEARING WALL MORE THAN TWO STORIES HIGH, SHALL BE PROVIDED INDIVIDUAL ENCASEMENT PROTECTION BY PROTECTING THEM ON ALL SIDES FOR THEIR FULL LENGTH, INCLUDING CONNECTIONS TO OTHER STRUCTURAL MEMBERS, WITH MATERIALS HAVING THE REQUIRED FIRE RESISTANCE RATING.
EXCEPTION: INDIVIDUAL ENCASEMENT PROTECTION ON ALL SIDES SHALL BE PERMITTED ON ALL EXPOSED SIDES PROVIDED THE EXTENT OF PROTECTION IS IN ACCORDANCE WITH THE REQUIRED FIRE RESISTANCE RATING, AS DETERMINED IN SECTION 703

COLUMNS- FIRE RATED ASSEMBLIES



1 HR. FIRE RATED COLUMN ASSEMBLY	UL DESIGN #X790
C1	1 HR. COLUMN PROTECTION- SFRM

1 HR. FIRE RATED COLUMN ASSEMBLY	UL DESIGN #X526
C2	1 HR. COLUMN PROTECTION- GYP. BD.

1 HR. FIRE RATED STEEL TUBE ASSEMBLY	UL DESIGN #X650
EXPOSED TS COLUMNS & BEAMS @ DRIVE UNDER CANOPY	
C3	

PHILLIPS

KEYPLAN

CONSULTANT

SEAL

ISSUE & REVISION RECORD

#	DATE	DESCRIPTION

This Document is © Phillips Partnership, PC and is considered an Instrument of Service and is solely for use with respect to the project as indicated below. All rights reserved. This document may not be reproduced without the prior written consent of Phillips Partnership, PC.

PROJECT

Fairfield
BY MARRIOTT
INN & SUITES

DAWSONVILLE, GEORGIA

PROTOTYPE VERSION 2016
REV 7 12-21-18

4 STORY, 92 UNITS
w/ INDOOR POOL

FAIRFIELD
DAWSON FOREST ROAD
DAWSONVILLE, GA
30534

CLIENT

RIMROCK COMPANIES
10000 RIVERSIDE AVE
SUITE 32201
JACKSONVILLE, FL 32204

PHILLIPS JOB NUMBER 1972101

ISSUE DATE 08/23/2019

DRAWN BY/CHECKED BY ZS / JU

DRAWING TITLE
FIRE RATED ASSEMBLIES - INDIVIDUAL ENCASEMENT

SHEET NUMBER
A-0.4

5901 PEACHTREE DUNWOODY RD.
BUILDING A, SUITE 450
ATLANTA, GEORGIA 30328
PHILLIPSPART.COM 770-394-1616

WWW.LDILine.com
Order Plans @