

Order Plans @ www.LDilLine.com

GENERAL NOTES

ALL EXIT SIGNS, NIGHT LIGHTS AND EMERGENCY BALLAST CHARGING CIRCUITS SHALL BE CONNECTED TO UNSWITCHED PORTION OF LIGHTING CIRCUIT SHOWN.

FIXTURE TYPE INDICATED BY UPPER CASE CHARACTERS, SWITCHING AND GROUPING DESIGNATED BY LOWER CASE LETTER AND CIRCUIT BY NUMBER (WHERE APPLICABLE).

WHEN CONDUCTOR OR CONDUIT SIZE IS INDICATED FOR BRANCH CIRCUIT HOME RUN, THE CONDUCTOR AND CONDUIT SIZE INDICATED SHALL BE USED FOR THE COMPLETE CIRCUIT.

REFER TO THE ARCHITECTURAL/INTERIORS DOCUMENTS FOR ACTUAL DEVICE LOCATIONS AND DIMENSIONS.

REFER TO THE APPROPRIATE DRAWINGS FOR THE EXACT LOCATION OF EQUIPMENT INSTALLED UNDER OTHER DIVISIONS OF THE DOCUMENTS, WHICH REQUIRE ELECTRICAL SERVICE.

REFER TO APPROPRIATE DRAWINGS AND MANUFACTURER'S INSTALLATION MANUAL TO PROVIDE ALL SUPPLEMENTARY AND CONTROL CIRCUITS TO BRING EQUIPMENT TO FULL WORKING CONDITION.

EQUIPMENT GROUNDING CONDUCTORS SHALL BE INSTALLED IN ALL RACEWAYS.

WALL SWITCHES CONTROLLING CIRCUITS OF OPPOSITE PHASES SHALL NOT BE INSTALLED IN COMMON BOX UNLESS PERMANENT BARRIER IS PROVIDED.

ALL RACEWAY AND EQUIPMENT SUPPORTS AND HANGERS SHALL BE FULLY COORDINATED WITH STRUCTURAL DRAWINGS.

REFER TO THE ARCHITECTURAL/INTERIORS REFLECTED CEILING PLANS FOR EXACT FIXTURE PLACEMENT AND DIMENSIONS.

REFER TO THE ARCHITECTURAL/INTERIORS DOCUMENTS FOR ACTUAL DEVICE LOCATIONS AND DIMENSIONS. FIELD VERIFY LAYOUT WITH EXISTING CONDITIONS AND STRUCTURE PRIOR TO BEGINNING INSTALLATION.

SEE HVAC DRAWINGS FOR LOCATIONS OF EQUIPMENT TO BE POWERED.

COORDINATE WITH EQUIPMENT CUTSHEETS AND PROVIDE ADDITIONAL CONTROL CIRCUITS IF REQUIRED BY MANUFACTURER.

GENERAL DIAGRAMMATIC RACEWAY INTERCONNECTIONS OF EQUIPMENT, FIXTURES AND DEVICES ARE INDICATED ON FLOOR AND REFLECTED CEILING PLANS. REFER TO STRUCTURAL AND ARCHITECTURAL PLANS FOR ELEVATION CHANGES AND RACEWAY ROUTES.

EACH PENETRATION OF A FIRE RESISTANT RATED ASSEMBLY BY A PIPE, TUBE WIRE OR CONDUIT SHALL BE PROTECTED BY A THROUGH PENETRATION FIRE STOP SYSTEM THAT HAS BEEN TESTED ACCORDING TO ASTM E814 OR E 199.


ELECTRIC RECEPTACLES, SWITCHES, OUTLETS, ETC. SHALL NOT BE INSTALLED BACK TO BACK ON FIRE RESISTANCE RATED WALLS. THEY SHALL BE AT LEAST 24" APART.

LEGEND

SYMBOLS	DESCRIPTION	MOUNTING
	DUPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	1'8" AFF
	DUPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	4'2" AFF OR 6" ABOVE COUNTER TOP
	QUADPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	1'8" AFF
	QUADPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	4'2" AFF OR 6" ABOVE COUNTER TOP
	DUPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	FLUSH WITH FINISHED FLOOR
	DUPLEX RECEPTACLE, 120V, 20A, NEMA 5-20R	IN CEILING
	SPECIAL RECEPTACLE, CONFIGURATION AND ELECTRICAL CHARACTERISTIC AS NOTED ON DWG	1'8" AFF
	JUNCTION BOX FLUSH IN WALL WITH COVER, SIZE PER NEC.	1'8" AFF
	JUNCTION BOX FLUSH IN CEILING WITH COVER, SIZE PER NEC.	IN CEILING
	JUNCTION BOX FLUSH IN FINISHED FLOOR WITH COVER, SIZE PER NEC.	FLUSH WITH FINISHED FLOOR
	SWITCH	1'8" AFF
	SWITCH - 3 WAY	1'8" AFF
	SWITCH - WALL MTD, INTEGRAL OCCUPANCY SENSOR	4'2" AFF
	SWITCH - WALL MTD, LOW VOLTAGE, NIGHT LIGHT	4'2" AFF
	SWITCH - WALL MTD, DIMMING	4'2" AFF
	CEILING MOUNTING OCCUPANCY SENSOR	IN CEILING
	DATA OUTLET	1'8" AFF
	TELEPHONE OUTLET	1'8" AFF
	TELEPHONE OUTLET, SUBSCRIPT: F - FIREMAN'S PHONE, H - HOUSE PHONE, F - PAY PHONE	4'2" AFF OR 6" ABOVE COUNTER TOP
	TELEPHONE / DATA COMBINATION OUTLET	1'8" AFF
	TELEPHONE / DATA COMBINATION OUTLET	FLUSH WITH FINISHED FLOOR
	TELEPHONE / DATA COMBINATION OUTLET	4'2" AFF OR 6" ABOVE COUNTER TOP
	DATA OUTLET	1'8" AFF
	DATA OUTLET	4'2" AFF OR 6" ABOVE COUNTER TOP
	MAGNETIC DOOR LOCKS	TO BE COORDINATED WITH DOOR
	DISCONNECT SWITCH, SUBSCRIPT: AMP / # OF POLES / ENCLOSURE	AS INDICATED ON DWG
	FUSED DISCONNECT SWITCH, SUBSCRIPT: AMP / # OF POLES / ENCLOSURE / FUSE	AS INDICATED ON DWG
	ELECTRICAL PANELBOARD, REFER TO PANELBOARD SCHEDULE.	SURFACE MOUNTED ON WALL
	EQUIPMENT AS NOTED ON DRAWING.	SURFACE MOUNTED ON WALL
	MOTOR	
	HOME RUN WITH WIRE TICS, XX - PANEL DESIGNATION, # - CIRCUIT DESIGNATION, WIRE TICS - (1) NEUTRAL, (3) HOT # # (1) GROUND	
	SMOKE DETECTOR, CEILING / WALL MOUNTED	CEILING
	HEAT DETECTOR, CEILING/WALL MOUNTED	CEILING
	FIRE ALARM NOTIFICATION DEVICE, AUDIO AND VISUAL	8'0" AFF
	FIRE ALARM NOTIFICATION DEVICE, AUDIO	8'0" AFF
	FIRE ALARM NOTIFICATION DEVICE, VISUAL	8'0" AFF
	FIRE ALARM INITIATION DEVICE, FULL STATION	4'2" AFF

ABBREVIATIONS

AC	6" ABOVE COUNTER SPACE OR 4'2" AFF	IG	ISOLATED GROUND
AF	AMP FUSE	ISC	SHORT CIRCUIT CURRENT
AFF	ABOVE FINISHED FLOOR	LTG	LIGHTING
AL	ALUMINUM	MTD	MOUNTED
BFC	BELOW FINISHED CEILING	N	NEUTRAL
BKR	BREAKER	NL	NIGHT LIGHT
CND	CONDUIT	NEC	NATIONAL ELECTRICAL CODE
CONN	CONNECTED OR CONNECTION	PNL	PANEL
CTB	CABLE TV TERMINAL BACKBOARD	RECPT	RECEPTACLE
CU	COPPER	TEL	TELEPHONE
DN	DOWN	TTB	TELEPHONE TERMINAL BOARD
EC	EMPTY CONDUIT	TV	TELEVISION
ELEC	ELECTRICAL	TVSS	TRANSIENT VOLTAGE SURGE SUPPRESSOR
FACP	FIRE ALARM CONTROL PANEL	TYP	TYPICAL
FAA	FIRE ALARM ANNUNCIATOR PANEL	XFMR	TRANSFORMER
G OR GRND	GROUND	UG	UNDERGROUND
GFCI OR GF	GROUND FAULT CIRCUIT INTERRUPTER	WP	WEATHERPROOF



KEYPLAN _____

CONSULTANT _____



SEAL _____



ISSUE & REVISION RECORD

#	DATE	DESCRIPTION
	08.10.2019	30% DESIGN REVIEW SET
	08.16.2019	90% REVIEW SET
	08.23.2019	PERMIT SET

This document is the property of Phillips Partnership, P.C. and is considered an instrument of service and is loaned to you with respect to the project as indicated below. All rights reserved. This document may not be reproduced without the prior written consent of Phillips Partnership, P.C.

PROJECT

Fairfield BY MARRIOTT INN & SUITES
DAWSONVILLE, GEORGIA

PROTOTYPE VERSION 2016
 REV 7 12-21-16

4 STORY, 92 UNITS
 w/ INDOOR POOL

FAIRFIELD DAWSON FOREST ROAD DAWSONVILLE, GA 30534

CLIENT _____

RIMROCK COMPANIES
 10000 RIVERSIDE AVE
 SUITE 2201
 JACKSONVILLE, FL 32204

PHILLIPS JOB NUMBER 1972101

ISSUE DATE 08/23/2019

DRAWN BY/CHECKED BY AT/IRK

DRAWING TITLE GENERAL

SHEET NUMBER _____

E-0.1

5901 PEACHTREE DUNWOODY RD.
 BUILDING A, SUITE 450
 ATLANTA, GEORGIA 30328
 PHILLIPSPART.COM 770-394-1616