



NOTE: STEP FTG AS REQ'D PER NOTES THIS SHEET

NOTE: CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND COORDINATE BUILDING FINISHES AND LOCATIONS WITH ARCHITECTURAL DRAWINGS.

**FLOOR CONSTRUCTION**  
 4" CONCRETE SLAB W/ 6x6-W1.4x W1.4 W.W.R. OVER VAPOR BARRIER OVER 4" POROUS FILL.  
 FINISH FLOOR ELEVATION = 0'-0"  
 TOP OF INT. FTG EL. = -2'-0"  
 TOP OF EXT. FTG EL. = -2'-0"  
 TOP OF PIER EL. = -0'-8"

STEP FOOTING AS REQUIRED TO MAINTAIN DEPTHS PER GEOTECHNICAL REPORT PER SITE PLAN FINISH GRADES, BUT NOT LESS THAN 12" COVER BELOW GRADE, TYP.

NOTE: USE SECTION 1a/G-S3.0 WHERE FINISH GRADE ABUTTING THE BUILDING IS LOWER THAN 8 INCHES BELOW FINISH FLOOR.  
 CONTRACTOR SHALL CONFIRM LOCATION OF ALL UTILITIES BEFORE BEGINNING CONSTRUCTION.

1. PROVIDE FOOTING STEPS AS REQUIRED BY FINISHED GRADES. SEE G-S1.0 FOR TYPICAL DETAIL.
2. SLOPE SLABS TO DRAINS AND DEPRESS AS REQUIRED - SEE ARCH.
3. SEE G-S1.0 FOR SJ & C3 DETAILS.
4. PROVIDE BLOCKOUTS IN SLAB AS REQUIRED. COORDINATE WITH ARCH DWGS FOR EXACT SIZE, LOCATION, ETC.

NOTE: STEP FTG AS REQ'D PER NOTES THIS SHEET

FOUNDATION + LOWER FLOOR PLAN  
 1/8" = 1'-0"

FOOTING SCHEDULE			
MARK	SIZE	DEPTH	REINFORCEMENT
(A)	3'-0" x 3'-0"	12"	4-#5 EA. WAY T&B W/ STD. 180° HOOK EA. END
(B)	3'-6" x 3'-6"	12"	4-#5 EA. WAY T&B W/ STD. 180° HOOK EA. END

AUBURN STRUCTURAL DESIGN, INC.  
 ROY H. MAYO, JR., P.E.  
 2008 JANABROOKE LN  
 AUBURN, AL 36830  
 (334) 826-8040  
 engineer@asstructure.com  
 www.asstructure.com



**Pate Design Group, Inc.**  
 Architecture / Interiors  
 4168 Abbotts Bridge Road  
 Duluth, Georgia 30097  
 (p) 770.814.0885  
 (f) 770.814.0886  
 Kirby@patedesigngroup.com

**G-1 AND G-2**  
 WISTERIA RIDGE  
 Will-O-War LLC  
 75 North Main Street  
 Watkinsville, GA 30677

Issue & Revisions:

No.	Date	Description
1	06.19	CLARIFICATION

FOUNDATION & LOWER FLOOR PLAN

AS NOTED

G-S2.0

RELEASED FOR CONSTRUCTION