

**VENDOR BID GENERAL NOTES:**

- VENDOR SHALL REVIEW COMPRESSOR SELECTIONS SHOWN ON THE R11 REFRIGERATION GENERAL AND SPECIFICATIONS FROM THIS DATA MUST BE APPROVED BY THE KROGER CO. VENDOR SHALL PROVIDE LINE SIZES AND SCHEDULES FROM APPROVED LIST KROGER EQUIPMENT SPECIFICATIONS.
- ALL WINDUP GLASS DOOR AND MULTI-DECK MERCHANDISERS TO BE TOP FEED BY OR UNLESS NOTED OTHERWISE.
- ALL FOUR AND FIVE DECK MERCHANDISERS TO HAVE WINDUPS UNLESS NOTED OTHERWISE.

**VENDOR BID KEYNOTES:**

- ① NOT USED
- ② NOT USED
- ③ NOT USED
- ④ PARTS SHALL BE SUPPLIED BY THE MANUFACTURER AS LISTED BY THE KROGER PROJECT MANAGER.
- ⑤ TEMPERATURE CONTROLLER, SENSOR, SECTION AND END GUARDS SUPPLIED BY MANUFACTURER.

**INSTALLER GENERAL NOTES:**

- LOCATIONS SHOWN FOR THE ROUTING OF REFRIGERATION LINES SHOWN ON THIS PLAN ARE BASED ON THE ASSUMPTIONS THAT THE REFRIGERATION LINES WILL BE INSTALLED IN THE MOST EFFICIENT MANNER AND THAT THE REFRIGERATION LINES WILL BE INSTALLED IN THE MOST EFFICIENT MANNER AND THAT THE REFRIGERATION LINES WILL BE INSTALLED IN THE MOST EFFICIENT MANNER.
- REFRIGERATION PIPING TO BE INSTALLED WHERE PRACTICAL, ITS INSTALLATION IS THE RESPONSIBILITY OF THE REFRIGERATION CONTRACTOR. THE REFRIGERATION CONTRACTOR SHALL BE RESPONSIBLE FOR THE REFRIGERATION CONTRACTOR TO BE INSTALLED IN ACCORDANCE WITH THE REFRIGERATION CONTRACTOR'S RECOMMENDATIONS FOR THE REFRIGERATION CONTRACTOR.

**INSTALLER KEYNOTES:**

- ① NOT USED
- ② NOT USED
- ③ INSTALL SELF-CONTAINED EQUIPMENT
- ④ NOT USED
- ⑤ INSTALL CASE END GUARDS SUPPLIED BY MANUFACTURER
- ⑥ NOT USED
- ⑦ NOT USED
- ⑧ CASE REQUIRES ONE TEMPERATURE SENSOR FOR REMOTE MONITORING

**CONTROL NOTE:**

- ANY NEW GROUP CONTROLS REQUIRED TO ACCOMPLISH REMOVAL TO BE USED AND PROVIDED BY REFRIGERATION CONTRACTOR. RELIABILITY OF REMOVAL SYSTEM CONTROLS FOR WINDUP SYSTEMS TO BE CONFIRMED BY REFRIGERATION CONTRACTOR. SYSTEMS SHALL BE PROVIDED WITH A LOCKS OFF FROM REMOVAL CONTROLS TO BE INSTALLED IN ACCESSIBLE LOCATIONS PROTECTED FROM DAMAGE.

**SHEET INDEX:**

- R11 (ONE SHEET) REFRIGERATION EQUIPMENT PLAN
- R11 REFRIGERATION STANDARD SCHEDULE
- R11 REFRIGERATION EQUIPMENT SCHEDULE

**LEGEND:**

- ☐ TEMPERATURE SENSOR


**GENERAL NOTES:**

ALL EQUIPMENT IS TO BE COMPARED (EXCEPTING UNLESS NOTED OTHERWISE) TO THE KROGER EQUIPMENT SPECIFICATIONS. THE COMPLETE RESPONSIBILITY OF THE VENDOR SHALL BE TO VERIFY THAT ALL EQUIPMENT IS COMPARED TO THE KROGER EQUIPMENT SPECIFICATIONS. THE COMPLETE RESPONSIBILITY OF THE VENDOR SHALL BE TO VERIFY THAT ALL EQUIPMENT IS COMPARED TO THE KROGER EQUIPMENT SPECIFICATIONS. THE COMPLETE RESPONSIBILITY OF THE VENDOR SHALL BE TO VERIFY THAT ALL EQUIPMENT IS COMPARED TO THE KROGER EQUIPMENT SPECIFICATIONS.

**ATLANTA (NEW) NEIGHBORHOOD**

2175 PARK LAKE DRIVE  
ATLANTA, GA

PHONE: (770) 496-7510  
FAX: (770) 496-7569



**WITHIN THE WALLS**

**GA-429**

730 NORTH MAIN ST  
CEDARTOWN, GA

OFFER PLAN DATE:	6/25/2019
ORIGINAL PLAN DATE:	5/25/2019
DESIGNER:	M. KAPPLER
CHECKED:	M. GILJO
REVISIONS:	
BRAND/NO PLATTED SCALE:	3/32"=1'-0"
<b>BUILDING STATS:</b>	
TOTAL SHEDDING:	2,382 LF
SALES AREA:	36,578 SF
8 X 8 SHED BUILDING:	41 X
BASE STORE:	50,088 SF
MEZZANINE:	
DOCK / UTILITY:	4,431 SF
<b>GROSS BUILDING:</b>	<b>58,607 SF</b>
<b>REFRIGERATION EQUIPMENT LAYOUT</b>	
DESIGN PACKAGE ID:	Not Applicable
<b>GA-429</b>	
<b>R11</b>	
GRID PLAN:	GA-429R11.DWG
DATE:	6/25/2019 10:50am BY: MCG