

Order Plans @ WWW.WWDLINE.COM

GENERAL NOTES

1. MEASURE AND RECORD AIRFLOW PRIOR TO START OF CONSTRUCTION IN ALL RENOVATION AREAS.
2. PATCH, SEAL AND INSULATE DUCTWORK WHERE BRANCH DUCTS ARE REMOVED AND NOT RE-USED. REMOVE UNUSED DUCT HANGERS.
3. WHERE EXISTING DIFFUSERS OR GRILLES ARE REINSTALLED IN NEW CEILINGS, CLEAN DIFFUSER OR GRILLE. FLEXIBLE DUCT CONNECTORS SHALL BE REPLACED.

SHEET KEYED NOTES

- 1 WORK IN THIS ROOM IS LIMITED TO REBALANCE OF SUPPLY AND EXHAUST. MEASURE AND RECORD SUPPLY AND EXHAUST AT PROJECT START TO ESTABLISH EXISTING BASELINE AIRFLOW. SUBMIT REPORT TO ENGINEER.
- 2 REMOVE AND REINSTALL THERMOSTAT IN NEW LOCATION.
- 3 REMOVE AND REINSTALL LINEAR SLOT DIFFUSER IN NEW CEILING.
- 4 REMOVE DIFFUSERS AND GRILLES IN THIS ROOM. REMOVE AND REPLACE FLEXIBLE DUCT CONNECTOR TO DIFFUSER. REMOVE EXHAUST DUCT BACK TO A POINT WHERE IT MAY BE EXTENDED TO NEW EXHAUST GRILLE.
- 5 EXISTING FUME HOOD TO REMAIN. EACH FUME HOOD IS PROVIDED WITH A DEDICATED EXHAUST FAN LOCATED ON THE ROOF. REFER TO M108 FOR FAN ID.
- 6 REMOVE DUCT BACK TO POINT INDICATED.
- 7 DISCONNECT EXHAUST DUCT TO FUME HOOD PRIOR TO DEMOLITION. FUME HOOD EXHAUST SHALL BE RE-PURPOSED FOR GROSSING STATION EXHAUST. TURN OFF EXISTING FAN F-35 WHICH IS DEDICATED TO THIS FUME HOOD UNTIL NEW WORK IS INSTALLED.

PARTITION AND WALL LEGEND

- 1-HOUR FIRE BARRIER
- 2-HOUR FIRE BARRIER

1 EIGHTH FLOOR PLAN - MECHANICAL DEMOLITION
M108 1/8" = 1'-0"



Kramer Engineering Services, plc
5517 Cascade Dr.
Chapel Hill, NC 27514
TEL: (919) 933-3350
email: Donna@KESplc.com
Firm License: P-1099



REVISION

MECHANICAL DEMOLITION
EIGHTH FLOOR PLAN -

UNC SCHOOL OF MEDICINE
NEUROSCIENCES RESEARCH BUILDING
7th & 8th FLOORS FOR DERMATOLOGY
LOCATION:
115 Mason Farm Road, Campus Box 7250
Chapel Hill, North Carolina 27598-7250

ISSUE DATE
09/25/2019
JOB NO.
10761-00
DWG. NO.

MD108

BID SET

LORD AECK SARGENT
A KATERRA COMPANY
© 2019 Lord Aeck Sargent. All rights reserved. This document is the sole property of Lord Aeck Sargent and is to be returned upon demand. The information herein is confidential and may not be used or divulged without the written permission of Lord Aeck Sargent.