



Order Plans @ www.LDILine.com

KEY NOTES
 ① SEE DRAWINGS E247A, E247B, E248A AND E248B FOR WORK INVOLVING REMOVING EXISTING CEILING RECESSED PERIMETER LIGHTING, AND EXACT QUANTITY AND LOCATION. FIXTURES SHALL BE REMOVED AND/OR SHIFTED FOR THE INSTALLATION OF ELECTRICAL PANELS AT CORRIDOR OUTER PERIMETER. PROVIDE TERMINATION/END CAP OF REMAINING FIXTURE PER MANUFACTURER'S RECOMMENDATION. A MAXIMUM OF ONLY ONE 4' FIXTURE SHALL BE REMOVED AT ANY ONE LOCATION.

PARTITION AND WALL LEGEND	
	1-HOUR FIRE BARRIER
	2-HOUR FIRE BARRIER
	3-HOUR FIRE BARRIER

1 EIGHTH FLOOR PLAN - LIGHTING - DEMOLITION
 ED118 SCALE: 1/8"=1'-0"



LORD AECK SARGENT
 A KATERRA COMPANY
 © 2019 Lord Aeck Sargent
 Unless otherwise noted, all information in this document is the sole property of Lord Aeck Sargent and is to be returned upon demand. The information herein is confidential and may not be used, nor divulged without the written permission of Lord Aeck Sargent.

Kramer Engineering Services
 5517 Cascade Dr,
 Chapel Hill, NC 27514
 TEL: (919) 953-3350
 email: donna@keapl.com
 Firm License: P-1089

REVISION:

NO.	DESCRIPTION

SHEET TITLE: EIGHTH FLOOR PLAN-LIGHTING-DEMOLITION
 SCALE (IN.): 1/8" = 1'-0"
 0 8 FT 16 FT

UNC SCHOOL OF MEDICINE
 NEUROSCIENCES RESEARCH BUILDING
 7th & 8th FLOORS FOR DERMATOLOGY
 LOCATION: 5 Wilson Farm Road, Campus, Box 7250
 Chapel Hill, North Carolina 27599-7250

ISSUE DATE: 9/25/2019
 JOB NO: 10761-00
 DWG NO: ED118

BID SET