


ALTERNATE #1: REPLACEMENT OF LAB BENCH WORK SURFACE--  
 REMOVE EXISTING LAB BENCH MOUNTED SERVICE FITTINGS, PROTECT AND MAINTAIN  
 SERVICE FITTINGS, REINSTALL SERVICE FITTINGS ON NEW WORK SURFACE. TYPICAL  
 FOR EACH LAB BENCH WORK SURFACE DESIGNATED BY ARCHITECTURAL DRAWINGS.

EXISTING SERVICE FITTING WITH TWO DUPLEX RECEPTACLES PER  
 SERVICE FITTING MOUNTED ON LAB BENCH--ONE SERVICE  
 FITTING ON EACH LAB BENCH IS 'OS' TYPE--TYPICAL



2 ENLARGED PLAN 'ELEC-7123'  
 ED127 SCALE: 1/4"=1'-0"

**PLAN NOTES**

- COORDINATE IN THE FIELD THE EXACT MOUNTING HEIGHT OF EXISTING SURFACE RACEWAY AND THE HEIGHT OF PROPOSED CASEWORK/BACKSPASH. RAISE EXISTING SURFACE RACEWAY WHERE REQUIRED FOR THE INSTALLATION OF CASEWORK AND BACKSPASH.
- THE CONTRACTOR SHALL COORDINATE WITH THE OWNER AND THE OWNER'S TELECOM GROUP TO REMOVE EXISTING WIRELESS ACCESS POINTS THROUGHOUT THE PROJECT SCOPE AREA PRIOR TO THE START OF DEMOLITION OR ANY WORK TO PREVENT DAMAGE TO THE EQUIPMENT DURING CONSTRUCTION. UPON COMPLETION OF ALL WORK THE CONTRACTOR SHALL COORDINATE WITH THE OWNER TO REINSTALL THE WIRELESS ACCESS POINTS. THE CONTRACTOR SHALL ASSIST THE OWNER IN LOCATING ALL WIRELESS ACCESS POINTS WITHIN THE PROJECT SCOPE AREA.

**KEY NOTES**

- EXISTING LAB BENCH IS BEING REMOVED. DISCONNECT ALL CIRCUITRY SERVING THE LAB BENCH AND ASSOCIATED DEVICES. DEVICES, CONDUIT AND ASSOCIATED CIRCUITRY WITHIN THE LAB BENCH SHALL REMAIN ATTACHED TO THE LAB BENCH.
- A NEW WALL IS PROPOSED IN THE VICINITY OF THESE DEVICES. COORDINATE IN THE FIELD WITH THE EXACT LOCATION OF THE NEW WALL AND THE EXISTING DEVICES. WHERE THE EXISTING DEVICES CAN REMAIN WITHOUT CONFLICTING WITH THE NEW WALL THE DEVICES MAY REMAIN. REMOVE DEVICES WHERE THEY CONFLICT WITH THE NEW WALL.

ROOM IS SERVED  
 BY X PNL 'L7B4'

Order Plans @ [www.kline.com](mailto:www.kline.com)

REMOVE EXIST TELECOM OUTLETS AND RECEPTACLES  
 IN RM '7109D' LOCATED AT 8" AFF--REINSTALL ALL  
 DEVICES AT SAME LOCATION ON PLAN AT 18" AFF

**PARTITION AND WALL LEGEND**

	1-HOUR FIRE BARRIER
	2-HOUR FIRE BARRIER
	3-HOUR FIRE BARRIER

1 SEVENTH FLOOR PLAN - POWER & TELECOM - DEMOLITION  
 ED127 SCALE: 1/8"=1'-0"



REVISION