

PLAN NOTES

- 1- EXISTING PANEL 'H8C' IS A 277/480V, 3Ø, 4W PANEL WHICH SERVES NORMAL LIGHTING ON THE FIFTH FLOOR.
- 2- EXISTING PANEL 'EH8C' IS A 277/480V, 3Ø, 4W PANEL WHICH SERVES EMERGENCY LIGHTING ON THE FIFTH FLOOR.
- 3- NORMAL LIGHTING SHALL BE CONNECTED TO THE EXISTING LOCAL NORMAL LIGHTING CIRCUITRY WHICH PREVIOUSLY SERVED LIGHTING IN THE RESPECTIVE AREA. EMERGENCY LIGHTING SHALL BE CONNECTED TO THE EXISTING LOCAL EMERGENCY LIGHTING CIRCUITRY WHICH PREVIOUSLY SERVED LIGHTING IN THE RESPECTIVE AREA.
- 4- CLEAN ALL EXISTING LIGHT FIXTURES AND LENSES. DO NOT USE HARSH CHEMICALS ON FIXTURES WHICH CAN DAMAGE LENS OR FINISH SURFACE. USE GLOVES WHEN HANDLING FIXTURES WITH PARABOLIC LOUVERS TO PREVENT DAMAGE TO PARABOLIC LOUVER FINISH. RELAMP EACH EXISTING FIXTURE AS FOLLOWS:
 TYPE 'XA3' - 3-32W, T8, 3500K, MINIMUM 82 CRI, MINIMUM 30,000 HOURS AVERAGE LIFE AT 3 HOURS PER START.
 TYPE 'XF3' - 3-32W, T8, 3500K, MINIMUM 82 CRI, MINIMUM 30,000 HOURS AVERAGE LIFE AT 3 HOURS PER START.
 TYPE 'XK' - 2-18W, 4 PIN CF, 3500K, MINIMUM 82 CRI, MINIMUM 12,000 HOURS AVERAGE LIFE AT 3 HOURS PER START.

KEY NOTES

- 1- COORDINATE IN THE FIELD WITH OFOI EQUIPMENT (BIOCAPINETS, FUME HOODS, CHEMICAL HOODS, ETC.) AND EXISTING FIELD CONDITIONS, AND SHIFT LIGHT FIXTURES WHERE THE FIXTURE CONFLICTS WITH THE INSTALLATION OF OFOI EQUIPMENT OR DOES NOT ALLOW EASE OF MAINTENANCE ON THE FIXTURE WHEN OFOI EQUIPMENT IS INSTALLED. THIS CONDITION MAY OCCUR AT LOCATIONS NOT SPECIFICALLY DESIGNATED ON THE PLAN. COORDINATE WITH OWNER AND ARCHITECT FOR PARTICULAR TYPE AND HEIGHT OF EQUIPMENT.

ONE SINGLE GANG TWO RELAY OCCUPANCY SENSORS WOULD BE PLACED TO SINGLE POLY SWITCHES WHICH WOULD BE PLACED TO FLUORESCENT FIXTURES - PROVIDE A DOUBLE SWITCH PLATE WITH ONE SWITCH AND ONE BLANK SIDE TO COVER DOUBLE GANG BOX-TYPICAL

1 EIGHTH FLOOR PLAN - LIGHTING - RENOVATION
E218 SCALE: 1/8"=1'-0"

PARTITION AND WALL LEGEND	
	1-HOUR FIRE BARRIER
	2-HOUR FIRE BARRIER
	3-HOUR FIRE BARRIER




UNC SCHOOL OF MEDICINE
 NEUROSCIENCES RESEARCH BUILDING
 7th & 8th FLOORS FOR DERMATOLOGY
 LOCATION:
 5000 Farm Road, Campus, Box 7250
 Chapel Hill, North Carolina 27599-7250

ISSUE DATE: 9/25/2019
 JOB NO: 10761-00
 DWG. NO: E218

Kramer Engineering Services
 5517 Cascade Dr,
 Chapel Hill, NC 27514
 TEL: (919) 953-3350
 email: dkraem@kesapllc.com
 Firm License P-1089



SHEET TITLE: EIGHTH FLOOR PLAN-LIGHTING-RENOVATION



LORD AECK SARGENT
 A KATERRA COMPANY
 Lord Aeck Sargent
 1000 S. Salisbury Street
 Raleigh, NC 27605
 www.lordaeck.com
 © 2010 Lord Aeck Sargent
 This document is the sole property of Lord Aeck Sargent and is to be returned upon demand. The information herein is confidential and may not be used or divulged without the written permission of Lord Aeck Sargent.

BID SET