

PANEL 'OS7105'

VOLTAGE, PHASE, WIRE AND AIC RATING : 120/208V, 3 PHASE, 4 WIRE, 10K AIC
 MOUNTING : SURFACE MOUNT
 PHASE BUSSING AND MAINS : 100A MAINS WITH 100A MAIN LUGS ONLY
 NEUTRAL AND GROUND BAR : NEUTRAL 100%, AND GROUND BAR
 OTHER : 9"W X 6"D, SINGLE ROW BRKRS

LOAD IN KVA			DESCRIPTION	TRIP	CKT	CKT	TRIP	DESCRIPTION	LOAD IN KVA		
A	B	C							A	B	C
0.00	---	---	SPARE		20	1					
---	0.00	---	SPARE		20	3					
---	---	0.00	SPARE		20	5					
1.44	---	---	RECEPTACLES		20	7					
---	0.60	---	RECEPTACLES		20	9					
---	---	0.18	RECEPTACLES		20	11					
0.18	---	---	RECEPTACLES		20	13					
---	0.18	---	RECEPTACLES		20	15					
---	---	0.18	RECEPTACLES		20	17					
0.18	---	---	RECEPTACLES		20	19					
---	0.18	---	RECEPTACLES		20	21					
---	---	0.72	RECEPTACLES		20	23					
0.00	---	---	SPARE		20	25					
---	0.00	---	SPARE		20	27					
---	---	0.00	SPARE		20	29					
0.18	---	---	SPARE		20	31					
---	0.00	---	SPARE		20	33					
---	---	0.00	SPARE		20	35					
0.00	---	---	SPARE		20	37					
---	0.00	---	SPARE		20	39					
---	---	0.00	SPARE		20	41					
0.00	---	---	SPARE		20	43					
---	0.00	---	SPARE		20	45					
---	---	0.00	SPARE		20	47					
0.00	---	---	SPARE		20	49					
---	0.00	---	SPARE		20	51					
---	---	0.00	SPARE		20	53					
0.00	---	---	SPARE		20	55					
---	0.00	---	SPARE		20	57					
---	---	0.00	---		2P-20	59					

NOTES
 #1 PROVIDE PRINTED LABEL ON INSIDE OF DOOR STATING FOR OPTIONAL STANDBY LOADS ONLY (PER NEC 702) IN ROOM 7105 ONLY.
 #2 PROVIDE PANEL TROUGH/SKIRT TO ABOVE FINISHED CEILING.

TOTAL CONNECTED LOAD			
PHASE	A	B	C
KVA PER PHASE	2.0	1.0	1.1
AMPS PER PHASE	17	8	9
TOTAL CONNECTED KVA	4.0		
DEMAND KVA / AMPS	3.4	7	9
FEEDER AMPERAGE	70		

PANEL 'OS7119'

VOLTAGE, PHASE, WIRE AND AIC RATING : 120/208V, 3 PHASE, 4 WIRE, 10K AIC
 MOUNTING : SURFACE MOUNT
 PHASE BUSSING AND MAINS : 100A MAINS WITH 100A MAIN LUGS ONLY
 NEUTRAL AND GROUND BAR : NEUTRAL 100%, AND GROUND BAR
 OTHER : 9"W X 6"D, SINGLE ROW BRKRS

LOAD IN KVA			DESCRIPTION	TRIP	CKT	CKT	TRIP	DESCRIPTION	LOAD IN KVA		
A	B	C							A	B	C
0.00	---	---	SPARE		20	1					
---	0.00	---	SPARE		20	3					
---	---	0.18	RECEPTACLES		20	5					
0.60	---	---	RECEPTACLES		20	7					
---	0.60	---	RECEPTACLES		20	9					
---	---	0.60	RECEPTACLES		20	11					
0.60	---	---	RECEPTACLES		20	13					
---	0.60	---	RECEPTACLES		20	15					
---	---	0.60	RECEPTACLES		20	17					
0.18	---	---	RECEPTACLES		20	19					
---	0.18	---	RECEPTACLES		20	21					
---	---	0.00	SPARE		20	23					
0.00	---	---	SPARE		20	25					
---	0.00	---	SPARE		20	27					
---	---	0.00	SPARE		20	29					
0.00	---	---	SPARE		20	31					
---	0.00	---	SPARE		20	33					
---	---	0.00	SPARE		20	35					
0.00	---	---	SPARE		20	37					
---	0.00	---	SPARE		20	39					
---	---	0.00	SPARE		20	41					
0.00	---	---	SPARE		20	43					
---	0.00	---	SPARE		20	45					
---	---	0.00	SPARE		20	47					
0.00	---	---	SPARE		20	49					
---	0.00	---	SPARE		20	51					
---	---	0.00	SPARE		20	53					
0.00	---	---	SPARE		20	55					
---	0.00	---	SPARE		20	57					
---	---	0.00	---		2P-20	59					

NOTES
 #1 PROVIDE PRINTED LABEL ON INSIDE OF DOOR STATING FOR OPTIONAL STANDBY LOADS ONLY (PER NEC 702) IN ROOM 7119 ONLY.
 #2 PROVIDE PANEL TROUGH/SKIRT TO ABOVE FINISHED CEILING.

TOTAL CONNECTED LOAD			
PHASE	A	B	C
KVA PER PHASE	1.4	1.4	1.4
AMPS PER PHASE	12	12	12
TOTAL CONNECTED KVA	4.1		
DEMAND KVA / AMPS	3.6	7	10
FEEDER AMPERAGE	70		

PANEL 'OS7131'

VOLTAGE, PHASE, WIRE AND AIC RATING : 120/208V, 3 PHASE, 4 WIRE, 10K AIC
 MOUNTING : SURFACE MOUNT
 PHASE BUSSING AND MAINS : 100A MAINS WITH 100A MAIN LUGS ONLY
 NEUTRAL AND GROUND BAR : NEUTRAL 100%, AND GROUND BAR
 OTHER : 9"W X 6"D, SINGLE ROW BRKRS

LOAD IN KVA			DESCRIPTION	TRIP	CKT	CKT	TRIP	DESCRIPTION	LOAD IN KVA		
A	B	C							A	B	C
0.00	---	---	SPARE		20	1					
---	0.00	---	SPARE		20	3					
---	---	0.00	SPARE		20	5					
0.60	---	---	RECEPTACLES		20	7					
---	0.60	---	RECEPTACLES		20	9					
---	---	0.60	RECEPTACLES		20	11					
0.60	---	---	RECEPTACLES		20	13					
---	0.18	---	RECEPTACLES		20	15					
---	---	0.18	RECEPTACLES		20	17					
0.18	---	---	RECEPTACLES		20	19					
---	0.72	---	RECEPTACLES		20	21					
---	---	0.00	SPARE		20	23					
0.00	---	---	SPARE		20	25					
---	0.00	---	SPARE		20	27					
---	---	0.00	SPARE		20	29					
0.00	---	---	SPARE		20	31					
---	0.00	---	SPARE		20	33					
---	---	0.00	SPARE		20	35					
0.00	---	---	SPARE		20	37					
---	0.00	---	SPARE		20	39					
---	---	0.00	SPARE		20	41					
0.00	---	---	SPARE		20	43					
---	0.00	---	SPARE		20	45					
---	---	0.00	SPARE		20	47					
0.00	---	---	SPARE		20	49					
---	0.00	---	SPARE		20	51					
---	---	0.00	SPARE		20	53					
0.00	---	---	SPARE		20	55					
---	0.00	---	SPARE		20	57					
---	---	0.00	---		2P-20	59					

NOTES
 #1 PROVIDE PRINTED LABEL ON INSIDE OF DOOR STATING FOR OPTIONAL STANDBY LOADS ONLY (PER NEC 702) IN ROOM 7131 ONLY.
 #2 PROVIDE PANEL TROUGH/SKIRT TO ABOVE FINISHED CEILING.

TOTAL CONNECTED LOAD			
PHASE	A	B	C
KVA PER PHASE	1.4	1.5	0.8
AMPS PER PHASE	12	13	7
TOTAL CONNECTED KVA	3.7		
DEMAND KVA / AMPS	2.9	7	8
FEEDER AMPERAGE	70		

PANEL 'OS7115'

VOLTAGE, PHASE, WIRE AND AIC RATING : 120/208V, 3 PHASE, 4 WIRE, 10K AIC
 MOUNTING : SURFACE MOUNT
 PHASE BUSSING AND MAINS : 100A MAINS WITH 100A MAIN LUGS ONLY
 NEUTRAL AND GROUND BAR : NEUTRAL 100%, AND GROUND BAR
 OTHER : 9"W X 6"D, SINGLE ROW BRKRS

LOAD IN KVA			DESCRIPTION	TRIP	CKT	CKT	TRIP	DESCRIPTION	LOAD IN KVA		
A	B	C							A	B	C
0.00	---	---	SPARE		20	1					
---	0.00	---	SPARE		20	3					
---	---	0.00	SPARE		20	5					
1.80	---	---	RECEPTACLES		20	7					
---	1.80	---	RECEPTACLES		20	9					
---	---	0.18	RECEPTACLES		20	11					
0.18	---	---	RECEPTACLES		20	13					
---	0.18	---	RECEPTACLES		20	15					
---	---	0.00	SPARE		20	17					
0.00	---	---	SPARE		20	19					
---	0.00	---	SPARE		20	21					
---	---	0.00	SPARE		20	23					
0.00	---	---	SPARE		20	25					
---	0.00	---	SPARE		20	27					
---	---	0.00	SPARE		20	29					
0.00	---	---	SPARE		20	31					
---	0.00	---	SPARE		20	33					
---	---	0.00	SPARE		20	35					
0.00	---	---	SPARE		20	37					
---	0.00	---	SPARE		20	39					
---	---	0.00	SPARE		20	41					
0.00	---	---	SPARE		20	43					
---	0.00	---	SPARE		20	45					
---	---	0.00	SPARE		20	47					
0.00	---	---	SPARE		20	49					
---	0.00	---	SPARE		20	51					
---	---	0.00	SPARE		20	53					
0.00	---	---	SPARE		20	55					
---	0.00	---	SPARE		20	57					
---	---	0.00	---		2P-20	59					

NOTES
 #1 PROVIDE PRINTED LABEL ON INSIDE OF DOOR STATING FOR OPTIONAL STANDBY LOADS ONLY (PER NEC 702) IN ROOM 7115 ONLY.
 #2 PROVIDE PANEL TROUGH/SKIRT TO ABOVE FINISHED CEILING.

TOTAL CONNECTED LOAD			
PHASE	A	B	C
KVA PER PHASE	2.0	2.0	0.2
AMPS PER PHASE	17	17	2
TOTAL CONNECTED KVA	4.1		
DEMAND KVA / AMPS	3.6	7	10
FEEDER AMPERAGE	70		

PANEL 'OS7122'

VOLTAGE, PHASE, WIRE AND AIC RATING : 120/208V, 3 PHASE, 4 WIRE, 10K AIC
 MOUNTING : SURFACE MOUNT
 PHASE BUSSING AND MAINS : 100A MAINS WITH 100A MAIN LUGS ONLY
 NEUTRAL AND GROUND BAR : NEUTRAL 100%, AND GROUND BAR
 OTHER : 9"W X 6"D, SINGLE ROW BRKRS

LOAD IN KVA			DESCRIPTION	TRIP	CKT	CKT	TRIP	DESCRIPTION	LOAD IN KVA		
A	B	C							A	B	C
0.00	---	---	SPARE		20	1					
---	0.00	---	SPARE		20	3					
---	---	0.00	SPARE		20	5					
1.44	---	---	RECEPTACLES		20	7					
---	0.60	---	RECEPTACLES		20	9					
---	---	0.18	RECEPTACLES		20	11					
0.18	---	---	RECEPTACLES		20	13					
---	0.18	---	RECEPTACLES		20	15					
---	---	0.00	SPARE		20	17					
0.00	---	---	SPARE		20	19					
---	0.00	---	SPARE		20	21					
---	---	0.00	SPARE		20	23					
0.00	---	---	SPARE		20	25					
---	0.00	---	SPARE		20	27					